

XCEL ENERGY STANDARD FOR ELECTRIC INSTALLATION AND USE SUMMARY OF SIGNIFICANT CHANGES

Section 4 - Service Facilities

Page

- Established conductor size limitations for single-phase, Commercial service installations fed from a Pad-mounted transformer 35
- All secondary connection cabinets with or without metering provisions shall have a 3-point latch with provisions for a Company padlock and door(s) shall be hinged on either the left or right side. **Effective March 1, 2016** 35
- **Effective March 1, 2016** Latching methods for CT compartments shall utilize captive fasteners 39, 41
- "Blue Handled" Eaton MSL (Meter Socket Lever Bypass) is **NOW APPROVED** with the "XCH" suffix after the catalog number **Effective April 15, 2015** 45