

Rush Creek Wind 345 kV Gen-Tie - Bundle Conductor

Cross-Section	Noise Fair L5 Bundle 1272 Bittern	Noise Wet L50 Bundle 1272 Bittern	
-180	20.5	42	
-170	20.8	42.3	
-160	21.1	42.6	
-150	21.4	42.9	
-140	21.7	43.2	
-130	22.1	43.6	
-120	22.5	44	
-110	22.9	44.4	
-100	23.4	44.9	EDGE of PROPOSED ROW + 25 FEET
-90	23.9	45.4	
-80	24.5	46	
-75	24.8	46.3	EDGE of PROPOSED ROW
-70	25.1	46.6	
-60	25.9	47.4	
-50	26.7	48.2	
-40	27.5	49	
-30	28.3	49.8	
-20	28.8	50.3	
-10	29.3	50.8	
0	29.5	51	
10	29.3	50.8	
20	28.8	50.3	
30	28.3	49.8	
40	27.5	49	
50	26.7	48.2	
60	25.9	47.4	
70	25.1	46.6	
75	24.8	46.3	EDGE of PROPOSED ROW
80	24.5	46	
90	23.9	45.4	
100	23.4	44.9	EDGE of PROPOSED ROW + 25 FEET
110	22.9	44.4	
120	22.5	44	
130	22.1	43.6	
140	21.7	43.2	
150	21.4	42.9	
160	21.1	42.6	
170	20.8	42.3	

Rush Creek Wind 345 kV Gen-Tie - Bundle Conductor

Cross- Section	Noise Fair L5 Bundle 1272 Bittern	Noise Wet L50 Bundle 1272 Bittern
180	20.5	42
190	20.2	41.7
200	20	41.5
210	19.7	41.2
220	19.5	41
230	19.3	40.8
240	19.1	40.6
250	18.9	40.4
260	18.7	40.2
270	18.5	40
280	18.3	39.8
290	18.1	39.6
300	17.9	39.4
310	17.8	39.3
320	17.6	39.1
330	17.5	39
340	17.3	38.8
350	17.2	38.7
360	17	38.5
370	16.9	38.4
380	16.8	38.3
390	16.6	38.1
400	16.5	38
410	16.4	37.9
420	16.3	37.8
430	16.2	37.7
440	16.1	37.6
450	15.9	37.4