

Public Service Company of Colorado  
 Future Test Year Peak Demand  
 12 months ending December 31, 2023

Weather Normalized Peak Demand (MW)

	<u>Jan</u>	<u>Feb</u>	<u>Mar</u>	<u>Apr</u>	<u>May</u>	<u>Jun</u>	<u>Jul</u>	<u>Aug</u>	<u>Sep</u>	<u>Oct</u>	<u>Nov</u>	<u>Dec</u>
Residential	2,064	2,044	1,828	1,450	1,906	2,838	3,123	2,733	2,621	1,861	1,743	2,200
Nonresidential	2,486	2,606	2,469	2,356	2,804	3,085	3,252	3,363	2,956	2,599	2,585	2,632
Total Retail	4,551	4,650	4,297	3,806	4,710	5,923	6,375	6,096	5,577	4,460	4,329	4,832
Firm Wholesale	540	487	404	216	167	384	490	416	383	296	375	562
Total System Obligation Load	5,091	5,137	4,701	4,022	4,877	6,307	6,865	6,511	5,960	4,756	4,703	5,394