Program	Measure Group	Measure Lifetime (years)	Rebate Amount (\$)	Incremental Cost (\$)	Annual Customer kWh Savings (kWh/yr)	Annual Customer Peak Coincident Demand Savings (PCkW)	Gas Savings (Dth)	Non-Energy O&M Savings (\$)	Electric NTG (%)	Gas NTG (%)	Install Rate (%)	2021 Electric Units	2022 Electric Units	2021 Gas Units	2022 Gas Units
Lighting Efficiency	Custom Lighting Project	16	\$6,944	\$24,015	79,287	12.370	0.0	-\$50.38	73%	73%	100%	400	400	0	0
Lighting Efficiency	Lighting Controls	8	\$1	\$10	26	0.004	0.0	-\$0.01	86%	86%	100%	42,910	42,910	0	0
Lighting Efficiency	Midstream Flat	1	\$0	\$0	0	0.000	0.0	\$0.00	100%	100%	100%	0	0	0	0
Lighting Efficiency	Midstream High Bay	10	\$61	\$118	798	0.139	0.0	-\$0.09	78%	78%	100%	775	775	0	0
Lighting Efficiency	Midstream Screw In	4	\$5	\$12	150	0.026	0.0	-\$0.02	78%	78%	100%	99,362	99,362	0	0
Lighting Efficiency	Midstream Troffer	19	\$28	\$120	255	0.045	0.0	-\$0.03	78%	78%	100%	14,000	14,000	0	0
Lighting Efficiency	Midstream Tube	- 11	\$3	\$13	120	0.021	0.0	-\$0.01	78%	78%	100%	227,285	227,085	0	0
Lighting Efficiency	Network Lighting Controls	15	\$19	\$75	90	0.013	0.0	-\$0.02	100%	100%	100%	17,854	17,854	0	0
Lighting Efficiency	Retrofit Exterior	20	\$46	\$448	1,537	0.000	0.0	\$0.00	73%	73%	100%	8,093	8,093	0	0
Lighting Efficiency	Retrofit Flat	20	\$52	\$176	507	0.062	0.0	-\$0.03	73%	73%	100%	2,087	2,087	0	0
Lighting Efficiency	Retrofit High Bay	20	\$67	\$266	573	0.096	0.0	-\$0.06	73%	73%	100%	18,080	18,183	0	0
Lighting Efficiency	Retrofit Refrigerator	20	\$45	\$164	343	0.056	0.0	\$0.00	73%	73%	100%	70	70	0	0
Lighting Efficiency	Retrofit Troffer	20	\$29	\$136	245	0.046	0.0	-\$0.05	73%	73%	100%	54,389	55,335	0	0