

**ELECTRIC TARIFF**

**RULES, REGULATIONS AND CONDITIONS OF SERVICE**

**5. CHARACTER OF SERVICE**

Electric service furnished shall be of the character known as 60 hertz alternating current. Voltage supplied and the choice of single or three-phase service shall be by mutual agreement between the Customer and the Company.


The standard nominal voltages to be supplied are:

- 120/240 Volts single-phase
- 120 Volts single-phase
- 480 Volts single-phase
- 120/208 Volts three-phase
- 120/240 Volts three-phase
- 277/480 Volts three-phase
- 480 Volts three-phase
- 2400 Volts three-phase
- 2400/4160 Volts three-phase
- 6930/12,000 Volts three-phase
- 7200/12,470 Volts three-phase
- 7620/13,200 Volts three-phase
- 13,200/22,860 Volts three-phase
- 34,500 Volts three-phase
- 19,900/34,500 Volts three-phase

PUBLIC UTILITY COMMISSION OF TEXAS  
APPROVED

JUL 27 '07 DOCKET 32766

CONTROL # \_\_\_\_\_



PRESIDENT AND CEO,  
SOUTHWESTERN PUBLIC SERVICE COMPANY