

BEFORE THE NEW MEXICO PUBLIC REGULATION COMMISSION

IN THE MATTER OF SOUTHWESTERN)	
PUBLIC SERVICE COMPANY'S)	
APPLICATION FOR: (1) REVISION OF)	
ITS RETAIL RATES UNDER ADVICE)	
NOTICE NO. 282; (2) AUTHORIZATION)	CASE NO. 19-00170-UT
AND APPROVAL TO SHORTEN THE)	
SERVICE LIFE OF AND ABANDON ITS)	
TOLK GENERATING STATION UNITS;)	
AND (3) OTHER RELATED RELIEF,)	
)	
SOUTHWESTERN PUBLIC SERVICE)	
COMPANY,)	
)	
APPLICANT.)	

DIRECT TESTIMONY

of

DAVID A. LOW

on behalf of

SOUTHWESTERN PUBLIC SERVICE COMPANY

TABLE OF CONTENTS

GLOSSARY OF ACRONYMS AND DEFINED TERMS.....	iii
LIST OF ATTACHMENTS	v
I. WITNESS IDENTIFICATION AND QUALIFICATIONS	1
II. ASSIGNMENT AND SUMMARY OF TESTIMONY AND RECOMMENDATIONS.....	4
III. GENERATING FACILITIES	8
IV. ENERGY SUPPLY O&M EXPENDITURES	10
V. HALE WIND PROJECT O&M EXPENDITURES.....	14
VI. SPS POWER PLANT O&M PROGRAMS	21
A. SCHEDULED MAINTENANCE PRACTICES	21
B. PREDICTIVE MAINTENANCE PRACTICES	25
C. PERFORMANCE ASSURANCE PROGRAMS.....	31
D. TRAINING OF PLANT OPERATORS AND MAINTENANCE PERSONNEL.....	41
VII. RESULTS OF SPS'S O&M PRACTICES.....	44
VIII. POWER PLANT MAINTENANCE AND OUTAGES	53
VERIFICATION.....	57

GLOSSARY OF ACRONYMS AND DEFINED TERMS

<u>Acronym/Defined Term</u>	<u>Meaning</u>
Base Period	April 1, 2018 through March 31, 2019
Btu	British thermal unit
Commission	New Mexico Public Regulation Commission
EAF	Equivalent Availability Factor
FERC	Federal Energy Regulatory Commission
FOR	Forced Outage Rates
IM	Integrated Marketplace
kWh	kilowatt hour
LP	Low Pressure
M&D	Monitoring and Diagnostic
MW	megawatt
MWh	megawatt hour
NERC	North American Electric Reliability Corporation
GADS	Generating Availability Data System
OEM	Original Equipment Manufacturer
O&M	Operation and maintenance
RFP	Rate Filing Package

<u>Acronym/Defined Term</u>	<u>Meaning</u>
SMWA	Service Maintenance and Warranty Agreement
SPP	Southwest Power Pool, Inc.
SPS	Southwestern Public Service Company, a New Mexico corporation
Test Year	Historical Test Year Period consisting of the Base Period and further incorporating all proper adjustments and capital additions
Vestas	Vestas-American Wind Technology, Inc.
Xcel Energy	Xcel Energy Inc.
XES	Xcel Energy Services Inc.

LIST OF ATTACHMENTS

<u>Attachment</u>	<u>Description</u>
DAL-1	Test Year Energy Supply O&M Expenses (<i>Filename:</i> DAL-1.xlsx)
DAL-2	Tolk Station Annual Equivalent Availability Factors (<i>Filename:</i> DAL-2.xls)
DAL-3	Harrington Station Annual Equivalent Availability Factors (<i>Filename:</i> DAL-3.xls)
DAL-4	Gas Units (200-299 MW) Annual Equivalent Availability Factors (<i>Filename:</i> DAL-4.xls)
DAL-5	Tolk Station Annual Forced Outage Rates (<i>Filename:</i> DAL-5.xls)
DAL-6	Harrington Station Annual Forced Outage Rates (<i>Filename:</i> DAL-6.xls)
DAL-7	Gas Units (200-299 MW) Forced Outage Rates (<i>Filename:</i> DAL-7.xls)

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **I. WITNESS IDENTIFICATION AND QUALIFICATIONS**

2 **Q. Please state your name and business address.**

3 A. My name is David A. Low. My business address is 790 S. Buchanan Street,
4 Amarillo, Texas 79101.

5 **Q. On whose behalf are you testifying in this proceeding?**

6 A. I am filing testimony on behalf of Southwestern Public Service Company, a New
7 Mexico corporation (“SPS”) and wholly-owned electric utility subsidiary of Xcel
8 Energy Inc. (“Xcel Energy”).

9 **Q. By whom are you employed and in what position?**

10 A. I am employed by SPS, as General Manager, SPS Generation.

11 **Q. Please briefly outline your responsibilities as General Manager, SPS**
12 **Generation.**

13 A. I am responsible for providing management for the SPS Generation business area
14 within the Energy Supply organization, which provides leadership, strategic
15 direction, and management of the power generation group within the SPS area of
16 Xcel Energy.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Please describe your educational background.**

2 A. I received a Bachelor of Science in Mechanical Engineering Technology from
3 Texas Tech University in 1983. I also completed course work toward an MBA at
4 West Texas A&M University from 1998 to 2001.

5 **Q. Please describe your professional experience.**

6 A. I began my career with SPS in 1983 as a Plant Engineer at Tolk Station. I was
7 promoted to Supervisory Plant/Project Engineer at Tolk Station in 1987. In 1992,
8 I was promoted to Senior Project Engineer at Tolk Station. Then in 1995, I
9 became the Maintenance Manager for SPS's Harrington Station. In 2003, I was
10 promoted to Plant Director for Public Service Company of Colorado's Pawnee
11 Station. In 2007, I was promoted to Plant Director of SPS's Tolk and Plant X
12 Complex. Finally, in 2011, I was promoted to my current position as General
13 Manager, SPS Generation.

14 **Q. Have you attended or taken any special courses or seminars relating to**
15 **public utilities?**

16 A. Yes. Over my career, I have taken various courses and seminars related
17 specifically to the public utility industry.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Have you testified before any regulatory authorities?**

2 A. Yes. I have filed testimony and testified before the New Mexico Public
3 Regulation Commission (“Commission”). I have also filed testimony at the
4 Public Utility Commission of Texas. My testimony has addressed the topics of
5 SPS’s generation and its power plant operation, maintenance, expenses, and cost
6 control practices.

II. ASSIGNMENT AND SUMMARY OF TESTIMONY AND
RECOMMENDATIONS

4 A. My testimony supports the Test Year¹ Operation and Maintenance (“O&M”)
5 expenses for the Energy Supply business area and demonstrates how those
6 expenses are reasonable and necessary to support the electric service SPS
7 provides to its New Mexico retail customers and representative of future costs. I
8 also discuss SPS’s generation by operating plant and unit, and its power plant
9 operation, maintenance, and cost control practices during the Test Year. In
10 addition, I sponsor Schedule P-7 in SPS’s Rate Filing Package (“RFP”).

A. I recommend that the Commission approve SPS's requested Energy Supply business area O&M expenses. SPS's Test Year Energy Supply business area O&M expenses are reasonable and necessary to support the electric service SPS provides to its New Mexico retail customers and are representative of SPS's future costs. SPS operates its units in a prudent and efficient manner that ensures

4

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 the safe and reliable operations of its units, with continued environmental
2 compliance:

- 3 • SPS's approach to O&M for the Hale Wind Project leverages Xcel
4 Energy's experience with other wind projects and efficiently uses
5 experienced contractors and internal personnel.
- 6 • SPS uses tools such as PLEXOS software to schedule maintenance or
7 overhauls on a component basis (instead of complete or major unit
8 overhauls), which helps stabilize maintenance costs from year to year
9 and ensures the efficient and reliable operation of SPS's units.
- 10 • SPS uses a proactive predictive maintenance program that helps
11 minimize costs, while maintaining unit reliability.
- 12 • SPS maintains a robust performance assurance program, which
13 includes ongoing monitoring of power plant performance, to improve
14 unit efficiency and find cost-effective ways to reduce fuel costs:
 - 15 ○ SPS's coal units performed well during the Base Period, with most
16 operating within 3% of their Adjusted Design Net Heat Rate; and
 - 17 ○ During the Base Period, SPS conducted a Steam Path Analysis on
18 Tolk Unit 1, Jones Unit 2, and Harrington Unit 1 turbines, which
19 resulted in greater fuel savings and improvements in heat rates for
20 those units.
- 21 • SPS requires and provides training of plant operators and maintenance
22 personnel to ensure the safe and reliable operation of its units.
- 23 • Although SPS continues operating in an efficient manner, the changes
24 to the Southwest Power Pool, Inc.'s ("SPP") market has increased unit
25 starts and shortened unit service hours, which has increased O&M
26 expense and will likely do so in the future.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 In comparison to other utilities, SPS's O&M programs for generation facilities are
2 highly effective:

- 3 • The overall Equivalent Availability Factor ("EAF") for SPS's coal and
4 gas units compare favorably with the national average for 2017, the
5 most recent North American Electric Reliability Corporation
6 ("NERC") publication of these metrics.
- 7 • The overall Forced Outage Rates ("FOR") of SPS's coal and gas units
8 also compare favorably to the national average in 2017.
- 9 • Although SPS had several unplanned outages during the Base Period,
10 SPS took all reasonable steps to avoid unplanned outages and to
11 quickly make repairs and bring plants back on line when needed.

12 SPS's practices also include efforts to minimize related O&M expenses.

13 **Q. Was Attachment DAL-1 prepared by you or under your direct supervision**
14 **and control?**

15 A. Attachment DAL-1 was prepared under the supervision of SPS witness Arthur P.
16 Freitas and represents a portion of the jurisdictional cost of service provided in
17 Mr. Freitas's direct testimony (Attachment APF-6). I have reviewed Attachment
18 DAL-1 and believe it to be accurate.

19 **Q. Were Attachments DAL-2 through DAL-7 prepared by you or under your**
20 **direct supervision and control?**

21 A. Yes.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Was RFP Schedule P-7, which you sponsor, prepared by you or under your**
2 **direct supervision and control?**

3 A. Yes.

4 **Q. Do you incorporate RFP Schedule P-7 that you sponsor into your testimony?**

5 A. Yes.

6 **Q. How were New Mexico retail jurisdictional amounts in your testimony and**
7 **attachments calculated?**

8 A. Throughout my testimony, I quantify the expense and asset amounts on a New
9 Mexico retail basis based upon the jurisdictional allocation percentages Mr.
10 Freitas uses to develop the New Mexico retail revenue requirement in his
11 Attachment APF-6. Mr. Freitas is responsible for calculating jurisdictional
12 allocation percentages that apply to the various costs components in the cost of
13 service. My staff and I conferred with Mr. Freitas and his staff to determine these
14 New Mexico retail jurisdictional amounts presented in my testimony and
15 attachments. If the percentages used to allocate amounts to the New Mexico retail
16 jurisdiction change, those new allocation percentages will need to be applied to
17 the total SPS numbers to derive updated New Mexico retail amounts.

2

3

- Cunningham Unit 3
- Cunningham Unit 4
- Jones Unit 3
- Jones Unit 4
- Maddox Unit 2

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

- Maddox Unit 3
- Quay County Unit 1

1 SPS's natural gas-fueled plants consist of 12 steam turbine units and
2 7 combustion turbines. SPS's coal-fueled power plants consist of 5 steam units.
3 SPS's Carlsbad Generating Station was retired on December 31, 2017, and it has
4 been dismantled. A major addition in the SPS generation fleet is the Hale Wind
5 Project. The Hale Wind Project began commercial operation in June 2019. In
6 addition to these SPS-owned facilities, SPS also makes use of four solar
7 generation facilities located in New Mexico.

8 **Q. Are any units dedicated for peaking service?**

9 A. Yes. The combustion turbines at Jones Units 3 and 4, Cunningham Units 3 and 4,
10 and Maddox Unit 2 are considered peaking units.

11 **Q. Are any units used primarily for emergency situations?**

12 A. Yes. Quay County and Maddox Unit 3 are designated primarily for emergency
13 use.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **IV. ENERGY SUPPLY O&M EXPENDITURES**

2 **Q. What are the types of O&M services associated with SPS's Energy Supply**
3 **business area?**

4 A. SPS's Energy Supply business area is responsible for the oversight, planning,
5 siting, design, construction, operation, and maintenance of SPS's generation
6 facilities. The services Energy Supply provides include activities such as capital
7 project oversight and management, plant engineering and technical support,
8 performance testing and analysis, reliability maintenance services, safety
9 programs, NERC reliability standards compliance, and environmental compliance
10 (e.g., continued compliance with environmental rules and regulations, obtaining
11 permits for new and existing facilities).

12 **Q. Are the services and associated costs related to the Energy Supply business**
13 **area necessary for SPS's operations?**

14 A. Yes. The services and associated costs are necessary to ensure that SPS's
15 generation fleet, which is essential to providing electric service to SPS's
16 customers, is safely and reliably operated and maintained. For example, these
17 services are necessary to ensure that SPS's generation facilities remain in
18 compliance with environmental regulations and receive sufficient technical
19 support. The Energy Supply business area provides services that are required by

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 all utilities and without which SPS would not be able to provide electric service to
2 its customers.

3 **Q. Do SPS's New Mexico retail customers benefit from the services that are**
4 **provided by the Energy Supply business area?**

5 A. Yes. The services of the Energy Supply business area benefit SPS's New Mexico
6 retail customers by supporting the safe and reliable production of generation
7 capacity needed to serve the electric needs of those customers.

8 **Q. Please describe the costs associated with the O&M services provided by**
9 **Energy Supply business area.**

10 A. The costs for these services are made up of both native costs and affiliate charges.
11 Native SPS costs are those costs incurred directly by SPS to provide electric
12 service to customers. For example, the salaries and benefits of SPS employees are
13 native costs. Affiliate costs are those associated with services provided by Xcel
14 Energy Services Inc. ("XES")² or other affiliates to SPS. These services are in
15 addition to, and not duplicative of, the services that SPS employees provide.
16 Charges for affiliate services are provided "at cost," or without profit.

² XES is a centralized service company.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 The costs for these services are related to labor, overheads, pension and benefits
2 costs, materials, and supplies. SPS witness Michael T. Knoll provides testimony
3 explaining that SPS's labor costs are reasonable. SPS witness Richard R.
4 Schrubbe provides testimony explaining that SPS's pension and related benefits
5 costs are reasonable. SPS witness Melissa L. Schmidt provides testimony
6 explaining that the methodology of billings for labor and labor-related overheads
7 and affiliate costs is reasonable.

8 **Q. Do you provide an attachment that lists the total Energy Supply business**
9 **area O&M expense by Federal Energy Regulatory Commission ("FERC")**
10 **account?**

11 A. Yes. Attachment DAL-1 provides the total Test Year Energy Supply-related
12 O&M expenses broken down by FERC account.

13 **Q. During the fiscal year, does the Energy Supply business area monitor its**
14 **actual expenditures versus its budget?**

15 A. Yes. Actual versus expected expenditures are monitored on a monthly basis by
16 management within each department of the Energy Supply business area.
17 Deviations are evaluated each month to ensure that costs are appropriate. In
18 addition, action plans are developed to mitigate variations in actual to budgeted

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 expenditures. These mitigation plans may either reduce or delay other
2 expenditures so that overall spending complies with the authorized budget.

3 **Q. Are employees within the Energy Supply business area held accountable for**
4 **deviations from the budget?**

5 A. Yes. All management employees in the Energy Supply business area have
6 specific budgetary targets that are measured on a monthly basis to ensure
7 adherence to the targets and provide for action plan development to address
8 variances.

9 **Q. Is the Test Year level of O&M costs associated with the Energy Supply**
10 **business area reasonable and representative of the costs apt to prevail in the**
11 **future?**

12 A. Yes. The Test Year level of Energy Supply business area O&M expenses are
13 reasonable and representative of the costs SPS will experience in the future. As I
14 discussed earlier, SPS provides Energy Supply business area services as
15 efficiently as possible, making all reasonable efforts to manage costs and stay
16 within an O&M budget.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **V. HALE WIND PROJECT O&M EXPENDITURES**

2 **Q. Is SPS proposing any adjustments to its Base Period O&M?**

3 A. Yes. The Base Period O&M does not reflect the operation and maintenance
4 expenses for the Hale Wind Project, which began commercial operation in June
5 2019. The adjustment requested for O&M expenditures for the Hale Wind
6 Project is \$7,686,240 (\$2,205,028 New Mexico Retail). The O&M expense is
7 shown in Attachment APF-6 presented by Mr. Freitas. For the reasons explained
8 below, that amount is reasonable, necessary, and representative of the ongoing
9 costs to support the O&M of the Hale Wind Project.

10 **Q. How was the amount included in the cost of service for the Hale Wind**
11 **Project O&M developed?**

12 A. The Hale O&M costs in the cost of service reflect the cost of the Service,
13 Maintenance and Warranty Agreement (“SMWA”) with Vestas-American Wind
14 Technology, Inc. (“Vestas”) for the year during the period that rates will be in
15 effect. Based on the terms of the contract, that amount is known with certainty.

16 **Q. Will there be O&M costs for Hale that are not reflected in the cost of**
17 **service?**

18 A. Yes. There will likely be additional O&M costs outside of the SMWA that SPS
19 intends to request in future cases.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Please provide a description of the Hale Wind Project.**

2 A. The Hale Wind Project is a 478 megawatt (“MW”) facility located in Hale
3 County, Texas. To develop the Hale Wind Project, SPS has installed 239 turbines
4 through a combination of Vestas model 2.0 MW V110 and 2.0 MW V116 wind
5 turbines. Site infrastructure includes access roads, foundations, electrical cable
6 collection systems, and collection system substations. The generation output ties
7 into the SPP transmission system through a generation tie line from the Hale
8 Wind Project collector station to the interconnection tie breaker at the TUCO
9 substation (i.e., the SPP transmission grid point).

10 **Q. What is involved in the O&M of a wind project?**

11 A. O&M activities associated with a wind project generally involve two categories of
12 maintenance: (1) scheduled; and (2) unscheduled. Scheduled maintenance
13 includes general preventative maintenance. Unscheduled maintenance stems
14 from the identification of operational issues from monitoring the wind turbines
15 and the subsequent repair of identified issues.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Please provide an overview of SPS’s plan for operating and maintaining the**
2 **Hale Wind Project.**

3 A. SPS is using a combination of services provided by the Original Equipment
4 Manufacturer (“OEM”) and internal personnel assigned to the Hale Wind Project
5 site. SPS has executed a SMWA with Vestas, the OEM.

6 **Q. Why did SPS enter into an SMWA with Vestas?**

7 A. Vestas is the OEM of the turbines used in building the Hale Wind Project. Xcel
8 Energy has found that using the OEM to perform O&M services offers several
9 benefits, including: (i) lowering the risk of claims of inadequate maintenance
10 during the warranty period; (ii) allowing Xcel Energy to readily obtain controls
11 and software updates that help maintain reliability; and (iii) allowing Xcel
12 Energy’s teams to gain greater knowledge of technological advances by working
13 closely with the OEM, which leads to improved O&M on the turbines over their
14 useful lives. Vestas often provides O&M services to other wind projects,
15 providing SPS additional assurance that Vestas is highly qualified to do the O&M
16 work.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. What types of services will Vestas provide under the SMWA?**

2 A. The SMWA obligates Vestas to perform warranty work as well as scheduled and
3 unscheduled maintenance. The SMWA will cover warranty work for equipment
4 including wind turbines, towers, and climb assists. Examples of warranty work
5 include replacement of failed parts such as bearings, electronic components, and
6 the labor associated with the replacement.

7 Vestas will also perform all maintenance, diagnostics, repair and
8 replacement services on the serviced equipment, including among other things,
9 performing gearbox borescopes, inspecting wind turbine blades, sampling
10 gearbox and hydraulic unit oil, checking tensioning of tower base section anchor
11 bolts and performing re-tensioning, monitoring and reporting any FAA lighting
12 outages, and repairing and maintaining climb assists at scheduled intervals.
13 Vestas is also required to maintain a suitable inventory of replacement and spare
14 parts for the wind turbines.

15 **Q. Could SPS have provided internally the same services as Vestas is providing**
16 **through the SMWA?**

17 A. No. SPS does not have any employees trained in wind generation O&M, and SPS
18 does not currently have training programs to support such activities.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. How many internal staff will be assigned to work on Hale O&M?**

2 A. There will be four internal staff that will provide plant management, engineering,
3 and administrative services to the Hale Wind Project, in addition to overseeing the
4 SMWA contractors. In addition, XES personnel will provide various support
5 services including providing technical service groups for assistance with
6 engineering issues, material and chemical analysis, grid reliability, equipment
7 analysis, environmental services, safety services, and site security.

8 **Q. How does SPS and Xcel Energy work with the OEM to provide O&M**
9 **activities for a wind generation project?**

10 A. Xcel Energy works with the OEM during all phases of the project construction
11 process and thereafter in the operation of the project. Xcel Energy staff monitors
12 and coordinates with those contractors to perform the O&M needed for the
13 facility. SPS staff coordinates on scheduled maintenance as well as on
14 responding to issues at the site. The contractor bears the responsibility for
15 reporting conditions at the site and any issues, and contractor will inform the
16 internal employees when an operations issue is identified.

17 In an instance where monitoring of SCADA data or other O&M-related
18 monitoring has revealed a potential operations issue, internal staff will direct the
19 external contractors to schedule a technician to go out to the turbine in question.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 Depending upon the nature of the potential problem, the team that goes out to the
2 turbine may include both internal and external personnel. SPS works hand in hand
3 with the contractor to address the cause of the issue and fix it as timely as
4 possible.

5 **Q. What type of plant management technology will the Hale Wind Project use?**

6 A. The Hale Wind Project will use Energy Supply's Monitoring and Diagnostic
7 ("M&D") Center as described in Section VI of my testimony.

8 **Q. How will the Hale Wind Project be monitored?**

9 A. Xcel Energy has staff on site Monday through Friday during normal business
10 hours, so if an issue arises during this time the staff can respond quickly. After
11 normal business hours, the SCADA system continues to be monitored remotely
12 by Vestas and personnel can be dispatched if an issue arises that requires an
13 immediate response. Turbines can also be turned off and restarted remotely if a
14 problem is observed and the turbine needs to be taken offline. Under both
15 emergency and non-emergency situations, however, the O&M response is just
16 like any other power plant: when you get an alarm, you go to the site and address
17 it as soon as practicable given the issue.

18 **Q. Does Xcel Energy have experience with other wind project O&M?**

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 A. Yes. Xcel Energy has wind farm O&M experience through multiple, successful
2 company-owned wind projects at its other Operating Companies.³ In total, by the
3 end of 2019 Xcel Energy expects to be operating 1,127 turbines with a nameplate
4 capacity of 2,200 MW, not including the Hale Wind Project.

5 **Q. Has SPS applied the knowledge and experience that Xcel Energy has gained**
6 **from those wind projects to its plan for operating and maintaining the Hale**
7 **Wind Project?**

8 A. Yes. Xcel Energy and SPS applied the best practices learned from Xcel Energy's
9 experience at those wind farms to SPS's O&M plan for the Hale Wind Project.
10 Based on this experience, SPS believes that its O&M activities and requested
11 amount for the Hale Wind Project are reasonable and necessary.

³ Xcel Energy's operating companies are: Northern States Power Company - Minnesota, Northern States Power Company - Wisconsin, Public Service Company, Public Service Company Colorado and SPS.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **VI. SPS POWER PLANT O&M PROGRAMS**

2 **Q. Please describe SPS's O&M programs that help ensure generation efficiency.**

3 A. SPS employs a number of strategies to control costs and ensure generation
4 efficiency including: (1) scheduled routine maintenance practices; (2) predictive
5 maintenance practices; (3) performance assurance programs; and (4) training of
6 maintenance personnel and plant operators. The objective of these activities is to
7 reduce O&M expenditures while maximizing unit availability. Improved unit
8 availability allows system operations to optimize generation through increased
9 use of the most cost-effective units.

10 **A. Scheduled Maintenance Practices**

11 **Q. Please describe SPS's power plant maintenance program.**

12 A. SPS uses a computerized maintenance information system software program to
13 manage its power plant maintenance activities. This system integrates:
14 (1) maintenance requests submitted by power plant personnel; (2) maintenance
15 progress tracking; (3) man-hour time reporting; (4) parts inventory management;
16 (5) scheduled maintenance; and (6) maintenance history. It also enables operators,
17 maintenance personnel, engineers and other technical staff to identify, prioritize,
18 plan, coordinate, and schedule maintenance activities for power plants. This
19 system allows SPS operators and maintenance personnel to work together as a

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 team toward the common goals of minimizing operating costs, maximizing unit
2 availability, and complying with environmental regulations. Additionally, SPS
3 uses project management software programs such as PLEXOS, Microsoft Project,
4 and Primavera P6 to ensure efficient maintenance scheduling.

5 **Q. Please describe SPS's scheduled maintenance practice.**

6 A. SPS uses an equivalent, nine-year cycle on its major component inspections
7 unless specific circumstances warrant more or less frequent inspections. Under
8 this practice, all components in a turbine are inspected within a nine-year cycle of
9 equivalent operating time. Actual durations vary and inspections may occur more
10 or less often if component history, industry information, component assessment,
11 projected retirements, and unit operations warrant an extension or reduction in the
12 duration.

13 Maintenance on SPS's turbine generators is done on a component basis.
14 Instead of a less frequent complete unit major overhaul (which involves
15 disassembly, inspection, and repair of all major components of the turbine-
16 generator at once), individual sub-components of the turbine generator are
17 overhauled on a more frequent basis. This practice allows for more stable
18 maintenance costs from year to year, and provides a higher average level of unit

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 availability. Additionally, boilers are inspected and overhauled on a three-year
2 cycle. When a unit must be shut down for boiler maintenance, SPS may take
3 advantage of that outage to do component turbine or generator maintenance as
4 well.

5 **Q. Is the overhaul frequency the same for all units?**

6 A. No. Generally, both steam and combustion turbines follow manufacturer
7 recommendations. But some units are scheduled for maintenance on a more
8 frequent basis due to operational concerns or the nature of the unit design
9 specifications. SPS has a combustion turbine maintenance system that tracks the
10 hours of operation and number of starts and trips and correlates that with total
11 hours of operation. When a unit reaches the OEM recommended hours of
12 operation, maintenance inspection and repairs are performed. SPS uses a similar
13 method of tracking maintenance requirements for steam turbines. Additional
14 hours of operation are added to the total hours when the units are cycled.

15 One example of a change to SPS's overhaul frequency due to the nature of
16 a unit's design specifications occurred with respect to Tolk Unit 2's nozzle block
17 during the February 2017 overhaul. The OEM recommended inspecting the
18 nozzle block bolting every 50,000 hours of operation. With this recommendation

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 the inspection frequency would be every 5.7 years and none of the other
2 components would be required to be inspected during this time. However, during
3 SPS's February 2017 overhaul of Tolk Unit 2, SPS installed a new nozzle block
4 design that would not require bolting inspections. With the new slide-in nozzle
5 block installation, all the hold down bolts were eliminated. The new design has
6 an equivalent operating cycle extended to a nine-year inspection interval, which
7 matches the inspection recommendations for the high pressure/intermediate
8 pressure turbine.

9 Another recent example of an OEM recommendation occurred at the
10 Cunningham 3 and 4 units. The original generator cooling fan design had limited
11 life and can fail without warning. The new Siemens design has a two-stage set of
12 blades and is currently being installed in Cunningham 3. Cunningham 4 will
13 receive the upgrade during the generator rewind scheduled in 2020. The new
14 blade design will extend the life of the cooling fan without concern of sudden
15 failure.

16 An example of overhaul frequency being influenced by operational
17 concerns is that coal-fired units, which may experience boiler slagging, usually
18 require more frequent maintenance than gas-fired plants. Slagging is the

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 formation of molten or partially fused deposits on the furnace walls or surfaces
2 and forms when ash deposits are exposed to the radiant heat of the coal flames.
3 These deposits are removed to recover the efficiency of the unit.

4 **Q. How does SPS's scheduled maintenance practice affect system operations?**

5 A. Scheduling outages on a component basis rather than incurring a complete unit
6 outage results in higher availability because problems that occur due to normal
7 degradation can be identified and corrected much sooner and with less disruption
8 to the plant as a whole. Also, the manpower needs for a component outage are
9 less than for a major outage. This reduces the need for outside contractors or
10 higher internal staffing levels for scheduled outages. The ability to minimize the
11 scheduled outage time of units provides more options to minimize costs to SPS's
12 customers by increasing efficiency and maintaining the availability of these units.
13 Minimizing outage times also provides SPS with more options to meet load and
14 increases system reliability.

15 **B. Predictive Maintenance Practices**

16 **Q. What is predictive maintenance?**

17 A. Predictive maintenance is the process of analyzing equipment operations for
18 degradation and performing maintenance at a cost effective time, prior to failures
19 that could be more costly. If maintenance is performed too frequently, reliability

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 remains very high, but maintenance costs can be higher than required for that
2 level of reliability. If maintenance is performed too infrequently, then problems
3 can go undetected and unaddressed – resulting in decreased reliability and
4 increased repair costs once the problem emerges. SPS is a strong proponent of
5 taking a proactive approach with our predictive maintenance programs rather than
6 being in a position where we are simply reacting to failures.

7 **Q. Please describe the tools SPS uses in its predictive maintenance program.**

8 A. SPS uses several tools to help identify problems before forced outages occur. A
9 performance assurance program is employed in which the steam turbine and the
10 parameters of the steam turbine cycle are evaluated for problems that may require
11 maintenance. Performance testing, as a predictive maintenance tool, is used to
12 prevent problems that may result in a forced outage. This program allows the
13 maintenance department to gather data from the performance test and act on that
14 data by, for example, ordering parts and materials so that they can be prepared for
15 an anticipated outage.

16 As part of the performance assurance program, a Valve Wide Open Test is
17 performed with the unit on-line. The information obtained from this test allows
18 the Performance Monitoring organization or power plant personnel to quantify the
19 amount of degradation that has occurred since previous tests. If the level of

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 degradation is large, then plant personnel can spend the needed time during the
2 outage to identify and resolve any problems. Heat balance tests are scheduled
3 every two to three years depending on the outage schedules for the major units
4 (>200 MW). This ensures that the units that have the greatest effect on fuel costs
5 are tested frequently. Minor units that have high capacity factors are scheduled for
6 testing approximately every five years depending on need and resource
7 availability. Peaking and low capacity factor units are not routinely tested as their
8 use is based on need for capacity and not on economical generation.

9 Steam-path analysis is another tool SPS uses for predictive maintenance
10 purposes. During a scheduled turbine outage, the steam-path areas of the turbine
11 are thoroughly inspected. By taking precise measurements and conducting a
12 detailed inspection, components are evaluated for wear, deposit buildup, foreign
13 object damage, and steam leakage. A steam-path analysis will identify
14 components that should be replaced to prevent a forced outage or improve the
15 efficiency of the unit.

16 Vibration monitoring is another predictive maintenance tool utilized by
17 SPS. Because vibration is recognized as an early indicator of problems in rotating
18 machinery, SPS has installed continuous vibration detection and protection on
19 critical equipment, such as large turbine generators, large boiler feed pumps and

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 cooling tower fans. SPS collects computerized periodic vibration data. This data
2 can be used to monitor and trend vibration problems.

3 SPS has invested in nondestructive examination capabilities by training
4 and qualifying personnel in magnetic particle nondestructive examination. This
5 enables SPS to determine the condition of components in a power plant without
6 damage to the component being inspected. SPS has the capability to use several
7 qualified nondestructive examination techniques, such as magnetic particle, dye
8 penetrant, ultrasonic, eddy current, and x-ray. Each technique has a special
9 application to identify components that could cause failure.

10 Generator tagging is another useful predictive tool that can provide early
11 information of localized overheating in the generator. Used on the gas-cooled
12 generators at Jones, Tolk, and Harrington, generator tagging involves painting or
13 tagging different locations in the generator with various tagging compounds. If
14 localized overheating occurs while the unit is on-line, a device called a generator
15 condition monitor senses the condition and gives an alarm to the operator. A gas
16 sample from the generator containing molecules of the burned tagging compound
17 can be taken from the generator and the location of the overheating can be
18 determined before entering the generator. This advanced warning system not only
19 minimizes generator damage in the event of overheating, but also assists

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 maintenance personnel in determining the location of the overheating and the
2 steps to correct the overheating before disassembly of the generator.

3 Dissolved gas and oil testing, a predictive maintenance tool used for
4 transformer condition assessment, enables SPS to identify localized overheating
5 and insulation defects in oil-cooled transformers at the incipient stage so that
6 repairs can be planned in conjunction with a scheduled outage of the unit. Early
7 awareness of potential localized burning in the transformer can help prevent
8 catastrophic forced outages of generating units. This testing involves taking oil
9 samples from the transformer for evaluation by SPS's analytical chemistry lab for
10 the presence of several gases, as well as degradation of insulation materials.
11 Knowledge of how the different gaseous compounds are formed and trending
12 analyses are used to interpret the data and detect problems before failure.

13 In addition to testing transformer oil, lubrication oils for the plants are
14 sampled and tested. Lubrication oils are tested once per year for indication of oil
15 degradation and unusual machine wear. Analyses include measuring oxidation
16 resistance and the presence of wear metals. In addition to yearly testing, major
17 rotating equipment is tested at least every six months at all facilities for indication
18 of corrosion or contamination.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 With regard to plant water chemistry, water samples are used to predict
2 areas for corrective action. Automatic analyzers constantly measure the quality of
3 the boiler feedwater, boiler water, and steam. Small amounts of impurities can be
4 detected, which when immediately addressed, prevent costly long-term damage to
5 the boiler and turbine equipment. Water samples are taken from every water
6 source in each plant for indication of operational and maintenance problems as
7 well as unusual corrosion conditions.

8 Another predictive maintenance tool SPS uses is insulation resistance
9 testing of motors. An insulation resistance test is performed by applying a high
10 voltage (at least twice the rated voltage) direct current to the motor windings. The
11 test is conducted on motors during a scheduled outage, and the data obtained
12 provides three alternative courses of action. If the data shows the insulation to be
13 in good condition, then no action is necessary and repeat testing can be done at
14 the next scheduled outage. If the data shows marginal results, the motor is
15 disassembled, cleaned, and retested. Lastly, if the data indicates an imminent
16 failure, the motor is repaired or replaced. The advantage of this predictive tool is
17 that repairs can be done during a scheduled outage, and a forced outage can be
18 avoided.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

C. Performance Assurance Programs

Q. Please explain SPS's performance assurance programs.

A. Performance assurance programs are all activities undertaken to achieve optimum operating efficiency of SPS's power generating facilities.

Q. Please summarize SPS's policy relating to efficient operation of its plants.

A. SPS maintains an ongoing policy of monitoring its power plant performance, improving unit efficiency, and determining cost-effective ways to save on fuel and base rate costs for its customers. The Performance Monitoring department monitors, maintains, and recommends changes to enhance the operational performance of SPS's power plants. This group constantly evaluates unit operational conditions and identifies opportunities to improve availability and reduce process emissions based upon design and/or best achievable conditions. Over the years, SPS has developed performance assurance practices to maximize efficiencies by studying and evaluating the latest technologies in plant maintenance and/or operations. These technologies are then adapted to the unique power plant designs in SPS's system if technically and economically feasible.

The application of performance assurance practices to optimize power plant efficiency, availability, and reliability is not new to SPS. Since the early

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 1950s, SPS has had performance assurance practices in place to ensure that
2 reliable electricity is generated at the lowest reasonable cost. These practices
3 have resulted in an increasingly sophisticated testing program to monitor and
4 improve power plant efficiency. The following is a list of the various testing and
5 analytical services that SPS's performance testing staff currently provides:

- 6 • Power Plant Thermal Performance – Unit Cycle Testing;
- 7 • Development of Dispatch Performance Curves;
- 8 • Component Testing;
- 9 • Environmental Emissions Testing; and
- 10 • Independent Power Producing Facilities Capacity Testing.

11 **Q. What indicators are available to monitor plant equipment and process**
12 **performance?**

13 A. Heat rates, unit availability, and process emissions are the primary indicators of
14 unit performance. SPS uses these indicators in assessing the performance of its
15 generation fleet.

16 **Q. What other technology does SPS use to monitor generating fleet**
17 **performance?**

18 A. Energy Supply's M&D Center was established in 2014 to monitor the
19 performance and health of SPS's generating fleet. Monitoring and diagnostic

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 technology is used to help detect plant abnormalities before they result in
2 equipment failures and lost generation. The M&D Center offers the potential to
3 improve plant reliability, optimize performance, and minimize repair costs. Tolk
4 Station and Harrington Station have been monitored by the M&D Center since
5 January 2014. Jones Station Unit 1 and Unit 2 have been monitored by the M&D
6 Center since September 2016.

7 The M&D Center is in the process of developing the needed models for
8 monitoring the new wind turbines for the Hale Wind Project. The M&D Center
9 expects the diagnostic services to the facility to be operational by February 2020.
10 Once the system is operational there will be around 200 points of data for each
11 turbine monitored that will alert operations of any operational issues.

12 **Q. Please compare SPS's largest units' actual versus design heat rates.**

13 A. The following definitions will be helpful to understanding this comparison:

14 *Average Net Heat Rate* is defined by SPS as: The fuel consumption in British
15 thermal units ("Btu") divided by the net generation in kilowatt hours ("kWh").
16 Both the fuel consumption and the net generation are totals for the applicable time
17 period. This heat rate is sometimes referred to as the operating or accounting heat
18 rate.

Adjusted Design Net Heat Rate is defined by SPS as: The design net heat rate is estimated at the average load and adjusted for major equipment performance degradation and/or deviation from the manufacturers' design when the equipment was placed in service. This value approximates a unit's best achievable heat rate at the present time. The average net heat rates for SPS's largest units during the Base Period are provided below and have been compared to their adjusted design net heat rates.

89

0 **Q. How did SPS calculate the adjusted design net heat rate?**

1 A. Monthly average loads were determined for each unit and then compared against

2 original design heat rate curves for the units. In previous years, SPS calculated

3 the design net heat rate using the average load for the entire base period. The

4 monthly calculation method should produce a more representative result of

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 adjusted design heat rate when compared to calculating one design heat rate value
2 for the entire base period. Then, adjustments were applied to correct for
3 degradations to boiler and turbine efficiencies. The degradation factors are time-
4 based factors related to unit age and time between overhauls.

5 Adjusted design fuel usage was calculated on a monthly basis and then
6 totaled for all months. The total adjusted design fuel usage was then used along
7 with the total MWh to calculate the overall adjusted design heat rate values for the
8 Base Period.

9 **Q. Please explain the results shown in Table DAL-1.**

10 A. As can be noted from Table DAL-1, the operating heat rates (i.e., Average Net
11 Heat Rate) for SPS's largest units during the Base Period were within
12 approximately 3% of the best achievable target or the adjusted design net heat
13 rates. Tolk Unit 1's heat rate has always been higher than Tolk Unit 2's because
14 the shared systems between both units are applied to Unit 1.

15 The Average Net Unit Heat rate is affected by several factors such as unit
16 loading, measured generation, measured fuel consumption, measured fuel heating
17 value, and overall process degradation. Heat rate determination is subject to
18 measurement errors due to several factors including: type of instruments used,

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 number of test points collected, and condition of the equipment being tested. SPS
2 works to minimize uncertainties associated with power and fuel measurement
3 through frequent calibration of measurement devices and installation of more
4 accurate measurement devices.

5 Economic dispatching of SPS's units results in unit operation that varies
6 from minimum load to full load. It is difficult to account for these variations in
7 load when considering a design heat rate. Design heat rates are typically
8 associated with a particular load point. Generally, operation at less than full load
9 results in higher heat rates than under full load operation. Caution is advised
10 when comparing a heat rate at any specific load point with an average heat rate,
11 which includes start-up fuel consumption, low load operation, and station power.
12 Heat rate is greatly affected, usually negatively, by variations in unit loading.

13 **Q. Does the heat rate of a generating unit deteriorate over time?**

14 A. Yes.

15 **Q. Why does that deterioration occur?**

16 A. Heat rate is a measure of the efficiency of a unit. There are many factors that
17 cause the efficiency of a generating unit to deteriorate. The following are some
18 major reasons that plant performance becomes less optimal over time:

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

- 1 • Deposits, erosion, and foreign object damage to turbine rotating and
2 stationary blading;
- 3 • Excessive seal clearances on the turbine blading, which allow steam to
4 bypass the blading;
- 5 • Buildup of deposits on and between boiler tubing, which reduces heat
6 transfer and increases fan horsepower requirements;
- 7 • Oxidation inside boiler tubes, which also reduces heat transfer through
8 the tubes;
- 9 • Plugging and oxidation of air preheaters, which reduce heat transfer
10 from flue gas to incoming air and also increase required fan
11 horsepower;
- 12 • Oxidation and deposits on (and/or in) feedwater heater tubes, which
13 reduce heat transfer from the extraction steam to the feedwater;
- 14 • Erosion or holes, or both, on the partition plates in feedwater heaters,
15 which allows feedwater to bypass the heaters;
- 16 • Pump performance degradation due to increased seal clearances and/or
17 impeller erosion;
- 18 • Corrosion of inner surfaces of piping, which increases friction loss;
- 19 • Steam or high-energy water leaking through valves and/or steam traps,
20 which develop leaks over time;
- 21 • Oxidation and deposit buildups on condenser tubes, which reduce heat
22 transfer through the tubes; and
- 23 • Deterioration of cooling tower due to ice damage, algae growth, and
24 other issues, which reduces heat transfer between air and water.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 The efficiency of a generating unit decreases over time, but some tasks
2 can be performed to regain most of the lost efficiency. For example, boiler tubes
3 can be cleaned, turbine blade damage can be repaired, new turbine seals can be
4 installed, and leaking valves and steam traps can be repaired or replaced. SPS
5 currently has programs specifically designed to implement these tasks. Moreover,
6 as described in this section, SPS works to maintain and improve the efficiency of
7 its generating units.

8 **Q. Are there any other programs SPS uses for performance assurance?**

9 A. Yes. SPS uses a turbine steam-path analysis program and other performance test
10 methods in its performance assurance program.

11 **Q. Please describe the turbine steam-path analysis program.**

12 A. The purpose of this ongoing program is to economically optimize the
13 performance of steam turbines through sound maintenance practices. The
14 analysis consists of two phases: (1) pre-inspection test data is collected and
15 analyzed for indications of turbine performance degradation; and (2) during the
16 overhaul, numerous measurements and observations are made to further evaluate
17 the condition of the turbine. After appropriate engineering and economic analyses
18 are completed, repairs are made, if economically justified.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 During the pre-inspection analysis, performance test data is analyzed for
2 the following steam-path problems: solid particle erosion, foreign object damage,
3 deposits, and steam-path leakage. As problems are identified, the extent of the
4 damage and the probability of the component's failure are evaluated. The
5 projected effect of these problems on fuel costs is also determined. With this
6 knowledge, a determination is made as to which components may need to be
7 replaced and the repair procedures needed. The pre-inspection information is then
8 furnished to the plant maintenance department for scheduling repairs, ordering
9 parts, and preparing repair procedures. During planned overhauls further
10 inspections such as steam-path audits are made to determine the extent of damage
11 and repairs required to bring the equipment back to design condition.

12 When the turbine is disassembled for inspection, the following evaluations
13 are performed:

- 14 • Turbine nozzle and blade erosion and damage are assessed.
15 Measurements are taken for throat and pitch dimension. The effect of
16 these problems on heat rate is established;
- 17 • Measurements are made to determine deposit thickness and the degree
18 of coverage on nozzles and blades. The result of excessive deposits on
19 heat rate is calculated;
- 20 • Steam seal and steam packing clearances are measured, and the
21 alignment of rotating and stationary components is evaluated. Their
22 effect on heat rate is calculated; and

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

- The measurements and calculated values are used to cost justify the repair and/or the replacement of worn or damaged components.

Q. What are the costs of implementation and the estimated financial benefits resulting from the steam-path analysis program?

A. The steam-path analyses were conducted by SPS performance engineers. Steam path audits were conducted on Tolk Unit 1 in September 2018 for the Low Pressure (“LP”) turbines, Jones 2 in January 2019 for the LP turbine and Harrington Unit 1 in February 2019 for the LP turbine. Table DAL-2 below displays potential fuel savings identified as a result of this inspection.

Table DAL-2
Potential Improvements from Steam Path Audits

	Potential Annual Fuel Savings (Total Company)	Potential Annual Fuel Savings (NM retail) ⁴	Capacity Recoverable (kilowatt)	Heat Rate Improvement (Btu/net-kWh)
Tolk 1 LP Turbine Audit	\$244,045	\$70,012	4,674	81.9
Jones 2 LP Turbine Audit	\$37,588	\$10,783	740	29
Harrington 1 LP Turbine Audit	\$136,901	\$39,274	1,775	46

⁴ NM retail amounts are derived by applying ENERGY allocator. Fuel impacts flow through SPS’s fuel factor with no effect on base rates.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Please describe the other performance test methods SPS uses in its**
2 **performance assurance program.**

3 A. SPS also uses the following test methods in its performance assurance program:

- 4 • The Unit Heat Rate Test. SPS currently uses two different test methods to
5 determine the net unit heat rates for its units. The two methods are the
6 input-output method and the heat balance method. As indicated
7 previously, heat rate is a measure of unit efficiency.
- 8 • The Variable Throttle Pressure Operation Test. This test determines the
9 operational mode that results in the optimum heat rate throughout the load
10 range. This testing helps define how boiler pressure can be reduced at
11 lower loads to improve unit heat rate. Heat rate improves because:
12 (i) there is less pressure drop across the turbine steam admission valves;
13 and (ii) less power is required to pump the feedwater into the boiler drum.
- 14 • The Unit Equipment Condition and Efficiency Test. These tests measure
15 energy in and energy out. The results are compared with previous test
16 results and/or design efficiency. For major plant equipment within the
17 steam cycle, efficiency tests are periodically conducted to determine if
18 there has been any degradation in the performance of the components,
19 such as a boiler feed pump, condensate pump compressor, cycle heat
20 exchanger, or cooling tower. From the results of this test, the cost benefit
21 for replacing or reconditioning equipment parts can be evaluated, which
22 enables SPS to make informed decisions.

23 **D. Training of Plant Operators and Maintenance Personnel**

24 **Q. Do SPS plant operators receive training in efficient operating practices?**

25 A. Yes. Every plant operator receives training to operate the plant equipment
26 reliably, efficiently, and safely. No operator is allowed to perform operating
27 duties or is promoted to a higher level until successfully completing the required

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 training and passing the appropriate tests. Each test consists of a written and
2 demonstration portion.

3 **Q. Briefly describe SPS's power plant training programs.**

4 A. Power plant personnel are required to complete a three- to four-year apprentice
5 program depending on the individual's progress. Training includes classroom,
6 computer-based, programmed text, video, and on the job training.
7 Apprenticeships are available in the areas of Operations, Maintenance, Electrical,
8 Instrument, Technician, and Chemist Technician programs. Following apprentice
9 training, power plant personnel are continually provided training in their area of
10 operations. SPS provides operator refresher and scenario training on an on-going
11 basis. Operator refresher training reviews all of the major systems and cycles
12 every three to four years. Scenario training is conducted about once a month with
13 a simulator to go through "what if" scenarios in the plant.

14 The Power Plant Engineer training program is designed to guide the new
15 engineer through a six-year development plan with a goal to have a well-rounded
16 power plant engineer ready to be considered for the full performance level
17 Engineer "C" role by the end of the six-year period. The program is designed to
18 take a relatively inexperienced engineer and expose them to all facets of power
19 plant operations. It includes role-specific formal power plant training classes such

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 as Power Plant Fundamentals, Heat Rate Analysis, Predictive Maintenance, and
2 Equipment and Plant Balancing. This is followed by numerous training modules
3 specific to the systems in their assigned power plant. Also incorporated are
4 formalized rotational on-the-job training assignments in Operations, Maintenance,
5 Environmental, and Chemistry. In addition, rotations outside the department,
6 including at other power plants, and other engineering departments are required.
7 To maximize the engineer's ability to work within the Xcel Energy accounting
8 and budgeting environment, the training also covers the use of financial software
9 systems. Other topics include numerous safety-related modules, time
10 management, and project management. For professional development, the
11 program includes a completion requirement of an Engineer-in-Training program.
12 As components of the program are completed, participants become eligible for
13 promotional consideration to Engineer "B" and "C" positions in the Plant
14 Engineering and Technical Support organization. To assist in identifying and
15 coordinating training, SPS has formed a Regional Training Activity Committee
16 that includes at least one member from each power plant and from each of the
17 following disciplines: Safety, Environmental, Engineering, Management, and
18 Human Resources. This committee meets quarterly to discuss the training needs
19 for each SPS plant.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

VII. RESULTS OF SPS'S O&M PRACTICES

Q. Are there indications that SPS's O&M practices are effective?

A. Yes. Several comparisons indicate that SPS's practices are highly effective. First, Attachments DAL-2, DAL-3, and DAL-4 graphically display the EAF of SPS's coal-fueled plants, Tolk and Harrington Stations, and its larger gas-fueled units compared with the national average from the North American Electric Reliability Corporation/Generating Availability Data System ("NERC/GADS") for historical periods. EAF is the ratio of the time a unit was available for full-load operation (or at full capacity) over the time a unit was planned to be available for such operation expressed as a percentage. A higher EAF indicates higher unit availability. These attachments demonstrate that SPS's coal-fueled units have historically had a higher availability than the national average for comparably-sized units. SPS's gas-fired units generally track the national average for comparably sized units.

Second, Attachments DAL-5, DAL-6, and DAL-7 display the FORs of SPS's coal-fueled units and larger gas-fueled units compared to NERC/GADS data. The FOR indicates how much time SPS's units were off-line because of an unscheduled outage; the smaller the FOR, the better. SPS's coal units have a

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

much better FOR than the national average. Generally, SPS's gas units have had a better FOR than the national average.

Q. Please describe Tolk's historical EAF and FOR.

A. Tolk's EAF and FOR were better than the NERC average for units of similar size in 2016 and 2017. In comparison to NERC/GADS averages, Tolk achieved the following performance during 2016 and 2017:

Table DAL-3
Tolk Operational Statistics Comparison

	NERC 2016	Tolk 2016	NERC 2017	Tolk 2017
EAF	79.52%	90.05%	77.24%	86.41%
FOR	6.56%	5.16%	9.8%	1.97%

Tolk's performance from prior years is reflected in Attachments DAL-2 (EAF) and DAL-5 (FOR).

Q. Please describe Harrington's historical EAF and FOR.

A. Harrington's EAF and FOR were better than the NERC average for units of similar size in 2017. In comparison to NERC/GADS averages, Harrington achieved the following performance during 2016 and 2017:

Table DAL-4
Harrington Operational Statistics Comparison

	NERC 2016	Harrington 2016	NERC 2017	Harrington 2017
EAF	76.79%	86.80%	78.91%	91.95%
FOR	9.72%	3.04%	6.44%	1.47%

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 Harrington's performance from prior years is reflected in Attachments DAL-3
2 (EAF) and DAL-6 (FOR).

3 **Q. Please describe the historical EAF and FOR of SPS's gas-fueled units.**

4 A. SPS's gas-fueled units have had an EAF better than, or comparable to, the
5 NERC/GADS averages, with the exception of Jones 2 in 2016, when the unit was
6 taken off line to rebuild the cooling tower due to a high wind event. Attachment
7 DAL-4 shows that SPS's gas-fueled units have generally outperformed the
8 NERC/GADS averages since 2007. SPS's larger gas-fueled units have generally
9 performed better than the NERC/GADS FOR averages, even though some of the
10 gas units have been used for peaking and cycling service, which causes greater
11 wear and tear on the unit than other operating regimes. Attachment DAL-7 shows
12 that SPS's gas-fueled units have generally had a much lower FOR than the
13 NERC/GADS averages since 2007.

14 **Q. Are EAF and FOR indicators of efficient operation and maintenance**
15 **practices?**

16 A. Yes. Both EAF and FOR are indicators of efficient operation and maintenance
17 practices because they relate to the percentage of time that the units were
18 available and ready for dispatch to full load. Better unit availability helps ensure
19 utilization of the lowest cost dispatchable energy.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Please describe how SPS operates its units in the SPP Integrated**
2 **Marketplace (“IM”).**

3 A. The SPP operates a two-settlement, locational marginal price energy market
4 model. SPS operates its units in accordance with the SPP market optimization
5 models. This market structure has had the effect of increasing unit starts and
6 decreasing plant operating service hours.

7 Unit starts is the process of preparing the unit to come back on-line either
8 from reserve shut down or outage. For example, with respect to a steam unit, the
9 unit start process begins with placing the unit’s equipment back into service and
10 firing the boiler to establish the proper steam temperature and pressure. Once
11 achieved, the turbine is rolled to predetermined speeds to warm the casing and
12 rotor prior to synchronization speed (3,600 rpm). Once this is established, the
13 generator is synchronized to the electrical system.

14 During all unit startups, there are periods when fuel is consumed before
15 the unit generates power. These fuel costs are referred to as startup costs. Startup
16 costs are highest whenever a unit is cold at the beginning of the startup sequence.
17 Startup costs are less when a unit is warm, and startup costs are lowest when a
18 unit is hot. Whether a unit is hot, warm, or cold is defined by the number of hours

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 a particular unit has been offline. Each unit has a specific number of hours that
2 define a hot, warm, and cold start, which is determined by a number of factors,
3 including unit size.

4 **Q. Are there any other factors affecting the number of unit starts?**


5 A. Yes. The increase in wind generation on the system has also caused the unit loads
6 to swing and increased the cyclic effect on the system. Lower gas prices have also
7 changed how the units have been dispatched over the last year. The region has
8 experienced record low gas pricing due to the limits of the basin's available
9 takeaway capacity. Additional gas pipelines should be in service in the fall of
10 2019 that will return the gas pricing back to normal.

11 **Q. Will you please show the relationship between unit starts and operating**
12 **hours?**

13 A. Table DAL-5 reflects the relationship between unit starts and operating service
14 hours from 2009 to 2018 including the Base Period. As noted above, in general,
15 the SPP IM has had the effect of increasing unit starts and decreasing operating
16 service hours.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

Table DAL-5
SPS Unit Starts and Operating Hours 2009 - 2018



Q. How have the increases in unit starts affected the unit equipment?

A. Since the increase in starts began, the units have experienced an increase in boiler, motor, and other equipment failures. The increase in failures has resulted in increased maintenance and repair cost. For example, Maddox Unit 1, Jones Unit 2, and Plant X Units 1, 2, 3, and 4 have experienced boiler casing tears and boiler tube leaks from cycle fatigue. Motor failures occurred at Maddox Unit 2, Nichols

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 Unit 1, and Harrington Unit 3. A generator cooling fan blade failure at
2 Cunningham Unit 4 and hardware failure at Cunningham Unit 3 required a
3 compressor rebuild.

4 **Q. What effect will the increased cycling of the units have on SPS's O&M costs**
5 **going forward?**

6 A. While SPS has experienced fuel cost savings due to the IM, SPS has also
7 experienced an increase in O&M costs associated with the increase in starts and
8 continued cycling of the units, in addition to increases in expenses due to the
9 advanced age of several units.

10 Prior to the IM, units were brought on line and stayed on line for long
11 periods. The equipment stayed in a steady state of temperature and the load was
12 raised and lowered as needed. Motors ran continually, and were not shut down
13 and started again as frequently as they are in today's market. With frequent
14 cycling of the units, an increase in boiler tube failures, boilers casing failures and
15 motor failures have increased. These failures can reduce the reliable operation of
16 the units and increase repair costs (some equipment replacements can be
17 capitalized). Table DAL-6 below summarizes the maintenance cost of SPP
18 cycling for the SPS region. The repair cost reflects cycling failures to equipment.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1
2

Table DAL-6
Summary of Maintenance Cost of SPP Cycling for the SPS Region⁵

Facility	2017 Cost Total Company	2017 Cost NM Retail	2018 Cost Total Company	2018 Cost NM Retail
Cunningham	\$ 59,137	\$ 16,370	\$ 153,869	\$ 42,593
Maddox	-	-	18,108	5,013
Jones	230,000	63,667	56,983	15,774
Tolk	199,166	55,132	-	-
Plant X	56,004	15,503	32,950	9,121
Harrington	-	-	248,680	68,838
Nichols	210,000	58,131	50,244	13,908
Total Cost	\$ 754,307	\$ 208,802	\$ 560,834	\$ 155,246

- 3 **Q. How is cycling of the units determined?**
- 4 A. Cycling of the units is based on modeling software that includes pricing
- 5 information, unit heat rates, fuel cost, etc. In general, units are shut down when
- 6 the SPP market optimization model has determined that the unit will not be
- 7 needed the following day. There should be an economic benefit (fuel savings)
- 8 when a unit is shut down for economic purposes. Unit startups are normally
- 9 triggered when the SPP model determines that a unit is an economic choice to run
- 10 or if there is a system reliability improvement gained by starting up a unit.

⁵ NM retail amounts are derived by applying 12CP-PROD allocator.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **Q. Does the IM provide a net benefit to SPS's retail customers?**

2 A. Yes. The IM is providing a net benefit to SPS's customers. The SPP modeling
3 software should lead to fuel cost savings when a unit is shut down for economic
4 purposes. As stated previously, there should be a fuel cost savings each time a
5 unit is started for economic purposes.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

1 **VIII. POWER PLANT MAINTENANCE AND OUTAGES**

2 **Q. Has SPS provided power plant maintenance information?**

3 A. Yes. In RFP Schedule P-7, SPS provides the following information: total
4 maintenance by operating unit for four years prior to the Test Year; scheduled
5 maintenance for the Test Year; and projected scheduled maintenance for five
6 years beyond the Test Year.

7 **Q. What does SPS do to bring a unit back on-line after an unplanned outage?**

8 A. As I discussed earlier, SPS has a thorough inspection program, as well as
9 scheduled and predictive maintenance programs for its units. SPS takes all
10 reasonable steps to avoid unplanned outages, but occasionally events occur that
11 are unavoidable.

12 When unplanned outages occur, SPS has processes and procedures in
13 place to react quickly to get units back on-line in an efficient and safe manner.
14 Once a unit experiences an outage, plant engineers and technical staff quickly
15 evaluate the unit to determine what caused the outage. SPS then immediately
16 takes steps to make any necessary repairs, considering any safety issues that may
17 be implicated. In evaluating the problem, engineers and technical staff assess
18 whether it is reasonable and prudent to have additional repairs or upgrades
19 performed while the unit must remain down for repair of the initial problem.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

XES's Commercial Operations group assists in evaluating the cost of working overtime versus normal working hours. Depending on the unit that is out, the market pricing of the generating resources available in the IM, and various other factors, it may be more cost effective to conduct work only during normal business hours.

Q. Were there significant operational events during the Base Period that affected the availability of SPS's generating units?

A. Yes. Of the five largest events that caused a forced outage and large loss in equivalent megawatt hours ("MWh") during the Base Period: four occurred in 2018 and the other one occurred in 2019. These outages are summarized below in Table DAL-7.

Table DAL-7
Largest Forced Outages by MWh
April 1, 2018 to March 31, 2019

Date	Unit	Net Dep. Cap. (MW)	Type	Fuel Source	Description	Equivalent MWh
4/1/18	Tolk 1	532	Steam	Coal	Main Power Transformer Failure	716,899*
8/1/18	Cunningham 3	106	Combustion Turbine	Gas	Compressor Damage	615,758*

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

Date	Unit	Net Dep. Cap. (MW)	Type	Fuel Source	Description	Equivalent MWh
9/21/18	Maddox 1	112	Steam	Gas	Hot Reheat header seal box skin leak and boiler tube leaks	247,031
1/15/19	Plant X2	90	Steam	Gas	Generator Rotor collector brushes	162,450*
10/24/18	Cunningham 4	103	Combustion Turbine	Gas	Generator cooling fan blade failure	119,510

1 *** Hours extend outside the April 1, 2018 to March 31, 2019 dates**

2 The most common events that have otherwise affected availability of
3 SPS's units were outages caused by boiler tube leaks. During the Base Period,
4 twenty-five boiler tube leaks contributed to a combined total loss of 805,182
5 equivalent MWh during multiple forced outages.

6 When reasonably feasible, SPS undertakes minor upgrades and repairs to
7 non-affected equipment during unplanned outages in order to best utilize the
8 downtime. Typically, these minor upgrades and repairs are those that would
9 otherwise be performed during a scheduled outage. Any work performed that is
10 unrelated to the unplanned outage work is made with an emphasis on returning
11 the unit to service in the most cost-effective way possible.

Case No. 19-00170-UT
Direct Testimony
of
David A. Low

- 1 **Q.** **Does this conclude your pre-filed direct testimony?**
- 2 **A.** **Yes.**

VERIFICATION


STATE OF TEXAS)

) SS.


COUNTY OF POTTER)


DAVID A. LOW, first being sworn on his oath, states:

I am the witness identified in the preceding direct testimony. I have read the direct testimony and the accompanying attachment(s) and am familiar with their contents. Based upon my personal knowledge, the facts stated in the testimony are true. In addition, in my judgment and based upon my professional experience, the opinions and conclusions stated in the testimony are true, valid, and accurate.


DAVID A. LOW

SUBSCRIBED AND SWORN TO before me this 24th day of June, 2019 by DAVID A. LOW.




Notary Public of the State of Texas
My Commission Expires: 06-08-2020

Southwestern Public Service Company

Total Company SPS Operation and Maintenance Expenses

Line No.	FERC Acct	Account Description	SPS Total Company O&M Expense - Adjusted Test Year Period	SPS NM Retail O&M Expense - Adjusted Test Year Period
Production				
1	500.0	Operation Supervision and Engineering	\$ 2,268,554	\$ 627,965
2	501.35	Coal Non-Mine; Non-Freight	36,822,078	10,563,515
3	507.7	Coal Ash Sales	(638,126)	(183,066)
5	502.0	Steam Expenses	10,999,173	3,044,713
6	505.0	Electric Expenses	9,804,750	2,714,081
7	506.0	Miscellaneous Steam Power Expenses	12,308,638	3,407,190
8	507.0	Rents	6,346,153	1,756,697
9	509.0	Steam Operation SO2 Allowance Expense	159,720	69,444
12	510.0	Maintenance Supervision and Engineering	1,487,576	411,780
13	511.0	Maintenance of Structures	5,165,862	1,429,977
14	512.0	Maintenance of Boiler Plant	17,498,911	5,020,086
15	513.0	Maintenance of Electric Plant	12,292,355	3,526,430
16	514.0	Maintenance of Miscellaneous Steam Plant	11,085,594	3,068,636
17	546.0	Operation Supervision and Engineering	20,803	5,759
18	548.0	Generation Expenses	607,534	168,173
19	549.0	Misc Other Power Generation Expenses	4,229,813	1,209,556
20	550.0	Rents	509,638	141,074
21	551.0	Maintenance Supervision and Engineering	215,299	59,598
22	552.0	Maintenance of Structures	396,710	109,815
23	553.0	Maintenance of Generating and Electric Equipment	5,156,506	1,466,076
24	554.0	Maintenance of Misc Other Power Generation Plant	303,609	84,043
25	556.00	System Control and Load Dispatching	1,086,063	300,636
26	557.0	Purchased Power Other	1,649,520	476,935
27	Total Production O&M Expense		\$ 139,776,736	\$ 39,479,115

Southwestern Public Service Company

Total Company SPS Operation and Maintenance Expenses

Line No.	FERC Acct	Account Description	SPS Total Company O&M Expense - Adjusted Test Year Period	SPS NM Retail O&M Expense - Adjusted Test Year Period
Transmission				
28	560	Operation Supervision and Engineering	\$ 9,782,898	\$ 2,049,023
29	561	Load Dispatch - Reliability	231,641	47,369
30	561	Load Dispatch - Monitor and Operate Trans. System	3,248,302	664,252
31	561	Scheduling, System Control and Dispatching Services	4,043,263	989,084
32	562	Reliability, Planning and Standards Development	31	6
33	562	Transmission Service Studies	66,498	13,598
34	562	Generation Interconnection Studies	(55,916)	(11,434)
35	562	Reliability Planning and Standards Development Services	3,190,183	875,170
36	562	Station Expenses	1,936,338	405,565
37	563	Overhead Line Expenses	834,686	174,825
38	564	Underground Line Expenses	-	-
	565	Wheeling Lamar DC Tie	(420)	(116)
41	565	Wheeling Meter Charges	912,309	-
42	565	Wheeling Miscellaneous	31,117	6,363
46	565	Wheeling Schedule 12	1,833,497	588,980
47	565	Wheeling Schedule 12 - Wholesale	493,218	-
48	565	Wheeling Schedule 1 - Wholesale	762,783	-
49	565	Wheeling Schedule 2	4,678	1,503
50	565	W-Wheeling Schedule 2 - Wholesale	1,115	-
51	565	Wheeling Schedule 7&8	-	-
52	565	Wheeling Schedule 9	6,062,371	1,239,706
53	565	Wheeling Schedule 9 - Wholesale	25,175,406	-
54	565	565000S11T-Wheeling Schedule 11 - Total	135,171,319	33,009,456
55	565	565Z2DAUC - Z2 Direct Assigned Upgrade Charge	81,490	26,180
56	565	565Z2DAUCW - Z2 Direct Assigned Upgrade Charge - Wholesale	16,962	-
57	565	565Z2Sch11 - Z2 Schedule 11 Charges	(182,512)	(58,629)
58	565	565Z2Sch11W - Z2 Schedule 11 Charges - Wholesale	(4,093)	-
59	566	Misc Transmission Expenses	3,050,286	638,881
60	567	Rents	1,966,505	411,884
61	568	Maintenance Supervision and Engineering	8,520	1,784
62	570	Maintenance of Station Equipment	1,742,671	365,002
63	571	Maintenance of Overhead Lines	1,288,468	269,869
66	Sub-Total Total Transmission O&M Expenses		\$ 201,693,613	\$ 41,708,320
Regional Market Expenses				
67	575	Operation Supervision	\$ 158,137	\$ 45,366
68	575	Day-Ahead and Real-Time Market Administration	306,568	87,948
69	576	Ancillary Services Market Administration	24,516	7,033
70	576	Market Monitoring and Compliance	41,429	11,885
71	576	Market Admin, Monitoring, and Compliance Services	8,199,872	2,005,954
	576	Regional Market Rents	51,609	14,806
73	Total Regional Market Expenses		\$ 8,782,132	\$ 2,172,993
74	Total Transmission O&M Expenses		\$ 210,475,744	\$ 43,881,313

Southwestern Public Service Company

Total Company SPS Operation and Maintenance Expenses


Line No.	FERC Acct	Account Description	SPS Total Company O&M Expense - Adjusted Test Year Period	SPS NM Retail O&M Expense - Adjusted Test Year Period
Distribution				
75	580	Operation Supervision and Engineering	\$ 3,163,274	\$ 1,111,790
76	581	Load Dispatching	313,310	111,864
77	582	Station Expenses	1,595,635	569,703
78	583	Overhead Line Expenses	3,666,655	1,454,447
79	584	Underground Line Expenses	145,869	50,477
80	585	Street Lighting and Signal Systems Expenses	154,975	55,332
81	586	Meter Expenses	3,381,132	1,205,442
82	587	Customer Installations Expenses	918,200	327,833
83	588	Misc Distribution Expense	13,631,759	3,709,454
84	589	Rents	2,595,221	799,926
85	590	Maintenance Supervision and Engineering	19,407	6,929
86	591	Maintenance of Structures	4,271	(2,928)
87	592	Maintenance of Station Equipment	789,883	282,019
88	593	Maintenance of Overhead Lines	7,027,707	2,463,915
89	594	Maintenance of Underground Lines	407,483	130,209
90	595	Maintenance of Line Transformers	346	346
91	596	Maintenance of Street Lighting and Signal Systems	637,197	242,783
92	597	Maintenance of Meters	13,267	4,737
93	598	Maintenance of Misc Distribution Plant	(240,996)	(158,415)
94	Total Distribution O&M Expenses		\$ 38,224,594	\$ 12,365,862
Customer Accounts				
95	901	Supervision	\$ 29,486	\$ 9,165
96	902	Meter Reading Expenses	4,784,352	1,487,047
97	903	Customer Records and Collection Expenses	6,947,307	2,159,325
98	904	Uncollectible Expenses	4,380,461	1,361,536
99	904	Uncollectible Expenses Misc	1,058,042	328,861
100	905	Customer Acct - Misc	-	-
101	DEPINT	Customer Deposit Interest Expense	151,110	34,508
102	Total Customer Accounts Expense		\$ 17,350,759	\$ 5,380,441
Customer Service				
103	908.00	Customer Asst Expense	\$ 2,113,147	\$ 656,797
104	908.00	Historical EE Amortization	388,237	-
107	908.04	SaversSwitch	855,119	-
109	909.00	Informational and Instructional Advertising Expense	600,478	186,641
	910.00	Miscellaneous Customer Service Expense	17,088	5,311
115	Total Customer Service Expense		\$ 3,974,069	\$ 848,749

Southwestern Public Service Company

Total Company SPS Operation and Maintenance Expenses

Line No.	FERC Acct	Account Description	SPS Total Company O&M Expense - Adjusted Test Year Period	SPS NM Retail O&M Expense - Adjusted Test Year Period
Sales				
116	912.00	Demonstration and Selling Expense-Economic Development	\$ 260,978	\$ 81,116
117	Total Sales Expense		\$ 260,978	\$ 81,116
Administrative and General Expenses				
118	920	Administrative and General Salaries	\$ 28,862,730	\$ 8,012,705
119	921	Office Supplies and Expenses	19,880,024	5,518,978
120	922	Administrative Expenses Transferred-Credit	(17,541,474)	(4,869,763)
121	923	Outside Services Employed	10,024,264	2,782,878
122	924	Property Insurance	3,263,374	866,236
123	925	Injuries and Damages	6,582,771	1,827,471
124	926.00	Employee Pensions and Benefits	34,553,810	9,592,630
126	926.03	Deferred Pension Expense	(2,798,525)	-
128	928.01	Regulatory Commission Expense - NM	6,452,462	6,452,462
130	928.04	Regulatory Commission Expense - Misc	5,528,868	30,507
131	929.00	Duplicate Charges-Credit	(1,390,153)	(367,516)
135	930.20	Misc General Expenses	1,192,983	315,390
136	931	A&G Rents	12,941,448	3,752,019
138	935	Maintenance of General Plant	185,735	51,677
139		Recoverable Contributions, Dues, and Donations	228,213	228,213
140	Total Administrative and General Expenses		\$ 107,966,529	\$ 34,193,886
141	Total Operations and Maintenance Expense		\$ 518,029,409	\$ 136,230,481

Southwestern Public Service Company
Tolk Station Annual Equivalent Availability Factors




	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
NERC AVERAGE	80.66	82.72	80.88	81.33	84.35	82.64	83.25	81.43	79.99	79.52	77.24
Tolk	83.88	88.14	87.01	91.54	87.52	86.57	95.37	82.37	86.04	90.05	86.41

NERC Average data taken from Generating Availability Data System (GADS) Reports - Generating Unit Statistical Brochure - All Units Reporting
<http://www.nerc.com>
Unit data taken from Meridian

Harrington Station Annual Equivalent Availability Factors

COAL UNITS 300 - 399 MW




	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
NERC AVERAGE	83.9	83.6	84.4	83.8	83.4	82	83.9	81.09	80.03	76.79	78.91
HARRINGTON	89.1	91	93	84.1	75	79.9	82.87	86.92	86.80	91.95	

NERC Average data taken from Generating Availability Data System (GADS) Reports - Generating Unit Statistical Brochure - All Units Reporting
<http://www.nerc.com>

Unit data taken from Meridian

Southwestern Public Service Company

Gas Units (200-299 MW) Annual Equivalent Availability Factors



	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
NERC AVERAGE	84.86	86.74	84.9	79.13	83.6	79.48	84.25	75.47	77.79	79.76	83.75
NICHOLS 3	90.51	93.15	82.45	82.99	96.68	95.01	87.1	95.24	71.11	81.35	94.68
JONES 1	91.19	97.83	94.98	84.74	97.17	98.1	76.29	88.04	99.03	75.58	76.44
JONES 2	95.64	81.37	96.7	96.36	96.85	69.6	86.17	95.40	76.58	56.74	80.37
CUNNINGHAM 2	75.22	99.22	70.16	67.14	89.4	77.71	93.14	95.36	75.48	96.56	81.74
PLANT X 4	68.84	93.05	94.25	79.9	90.7	97.38	84.43	96.00	87.82	97.11	93.83

NERC Average data taken from Generating Availability Data System (GADS) Reports - Generating Unit Statistical Brochure - All Units Reporting (NERC Data - Gas Primary 200-299 MW range)


<http://www.nerc.com>

Unit data taken from Meridian

Southwestern Public Service Company

Tolk Station Annual Forced Outage Rates


COAL UNITS 400 - 599 MW



	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
NERC AVERAGE	5.52	5.83	6.44	5.58	4.84	5.36	5.41	5.09	6.26	6.56	9.8
TOLK	1.40	2.73	2.75	3.79	1.27	1.33	0.59	3.64	2.11	5.16	1.97

NERC Average data taken from Generating Availability Data System (GADS) Reports - Generating Unit Statistical Brochure - All Units Reporting
<http://www.nerc.com>
 Unit data taken from Meridian

Southwestern Public Service Company
Harrington Station Annual Forced Outage Rates




	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
NERC AVERAGE	4.92	4.83	3.73	5.09	6.24	5.47	5.30	5.30	6.14	9.72	6.44
HARRINGTON	1.44	1.70	2.24	7.23	18.87	6.40	5.70	5.70	2.77	3.04	1.47

NERC Average data taken from Generating Availability Data System (GADS) Reports - Generating Unit Statistical Brochure - All Units Reporting
<http://www.nerc.com>
Unit data taken from Meridian.

Southwestern Public Service Company

Gas Units (200-299 MW)

Forced Outage Rates (FOR)



	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017
NERC AVERAGE	4.06	7.06	6.58	11.78	12.74	10.33	4.43	16.45	14.50	9.69	8.99
NICHOLS 3	0.01	1.36	2.91	0.85	0.67	0.39	0.94	2.96	0.05	0.07	2.3
JONES 1	1.41	2.11	1.09	1.23	0.02	0.54	0.95	0.74	0.04	7.08	3.46
JONES 2	0.65	1.97	1.81	2.22	2.29	2.84	10.25	0.07	3.59	4.00	0.39
CUNNINGHAM 2	1.36	0.33	2.71	0.04	2.71	0.37	0.00	3.53	6.06	3.24	11.40
PLANT X 4	0.69	0.64	2.18	2.19	6.43	1.33	1.55	2.81	2.49	1.74	5.25

NERC Average data taken from Generating Availability Data System (GADS) Reports - Generating Unit Statistical Brochure - All Units Reporting
(NERC Data - Gas Primary 200-299 MW range)

<http://www.nerc.com>

Unit data taken from Meridian