

SECOND REVISED RULE NO. 13
CANCELING FIRST REVISED RULE NO. 13

2014 MAR 31 PM 4 26
X
X
X

RULES AND REGULATIONS - ELECTRIC

13. CUSTOMER'S INSTALLATION

Customer's Responsibility: Customer shall assume all responsibility on Customer's side of Point of Delivery for service supplied or taken, as well as for the electrical installation, appliances and apparatus used in connection therewith, except for injury or damage to persons or property occasioned by negligence on the part of the Company. X
X

Customer's Facilities: Customer's facilities shall comply with specifications at least equal to those prescribed by the National Electric Safety Code of the United States Bureau of Standards, any other legally applicable codes, and the rules of the Company. Customer shall operate said facilities and other electrical equipment in such a manner as not to interfere with the service of Company to other Customers. X
X
X

The service entrance shall be so located that one set of attachments will provide the necessary support for the Service Connection.

Customer's service terminals are to be located at a point readily accessible to Company's service lines, such point to be determined by Company. X
X

When construction or remodeling of a building preclude the use of Company's standard service attachment, Customer shall install a suitable attachment for the overhead service wires to the building. The location of such attachment shall be determined by Company, and at the cost of Customer. X
X


Company shall be responsible for any and all damages to persons or property resulting from insecure or weak or inadequate attachments on or to Customer's property only when such damages are the result of negligence on the part of the Company. X
X
X

EFFECTIVE

APR - 5 2014

REPLACED BY NMPRC

Final Order Case No. 12-00350-UT

Revised 245	X
Advice Notice No.	
	
REGIONAL VICE PRESIDENT RATES AND REGULATORY AFFAIRS	

SOUTHWESTERN PUBLIC SERVICE COMPANY

SECOND REVISED RULE NO. 13
CANCELING FIRST REVISED RULE NO. 13

X
X

RULES AND REGULATIONS - ELECTRIC

X

13. CUSTOMER'S INSTALLATION

Power Factor: Customer shall furnish, install and maintain, at his own expense, any and all corrective apparatus necessary to maintain a power factor of not less than 90% lagging on installations of any nature whatsoever.

X

Changes in Customer's Installation: As Company's service connections, transformers, meters and other facilities used in supplying service to Customer have a definite limited capacity, Customer shall give notice to Company, and obtain Company's consent, before making any material changes or increases in Customer's installation. After receipt of such notice Company will, as promptly as practicable, give its approval to the proposed change or increase, or will advise Customer upon what conditions service can be supplied for such change or increase.

X
X
X
X
X
X

In the event of damage to Company's facilities resulting from Customer's negligence in reporting changes or increases in Customer's installation, Customer shall be liable to Company for all expenses incurred in repairing such damages and restoring service.

X
X
X

Inspection by Company: Company retains the right, but does not assume the duty, to inspect Customer's installation at any reasonable time, and from time to time, and to refuse to commence or to continue service whenever it considers such installation to be defective, hazardous or for any other reason not in good operating condition.

X
X

Company reserves the right to check Customer's connected load and service requirements from time to time and to apply the proper rate schedule and basis of billing to conform to the findings of such investigations of connected load and service requirements.

X

EFFECTIVE

APR - 5 2014


REPLACED BY NMPRC

BY Final Order Case No. 12-00350-UT

Revised 245

X

Advice Notice No.



REGIONAL VICE PRESIDENT RATES AND
REGULATORY AFFAIRS