

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

**Product: Commercial Refrigeration**

**Description:**

Prescriptive rebates will be offered for the installation of reach-in cases with doors, night curtains on refrigerator and freezer cases, EC Motors for Refrigeration Evaporators (retrofit only), Anti-Sweat Heater Controls (retrofit only) and/or replacement of standard refrigeration case doors with No Heat Case Doors, Retrofit of open multi-deck refrigerated cases with no heat doors, and replacement lighting equipment. Prescriptive rebates will also be offered for retrofitting open multideck coolers or freezers with solid glass doors.

**Program References:**

|   |   |
|---|---|
| Measure "LED Refrigerated Case Lighting"            | Refer to Program "CO - Lighting Efficiency" to find formulas for (Customer kW, Customer kWh, Customer PckW, etc.) for the "LED Refrigerated Case Lighting" measure.                         |
| Measure "LED Ref and Frz Screw In Fixture Retrofit" | Refer to Program "CO - Lighting Efficiency - Small Business" to find formulas for (Customer kW, Customer kWh, Customer PckW, etc.), in which the "LED Interior Lamp" measure is referenced. |

**Equations:**

|  |  |
|--|--|
| <b>Direct Install</b>                        |  |
| <del>Coil Cleaning Tune-Up</del>             |  |
| <del>F_GEN_Deem_Eq_kW (Customer_kW)</del>    | <del>= I_Qty_Prop_Equip * Eq_kW_Savings</del>  |
| <del>F_Gen_kWh_Hrs2 (Customer_kWh)</del>     | <del>= Customer_kW * Eq_Hours</del>  |
| <del>F_GEN_PCKW (PC_kW_Customer)</del>       | <del>= Customer_kW * Eq_Coincidence_Factor</del>   |
| <del>CHW Aerator</del>                       |  |
| F RFR kW (Customer_kW)                       | = Customer_kWh/Eq.Hours  |
| F RFR Energy Elec (Customer_kWh)             | = Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_electric / Eq.Conversion_Factor_Electric * I_Qty_Prop_Equip |
| F RFR PCKW (PC_kW_Customer)                  | = Customer_kW * Eq.Coincidence_Factor  |
| Incram_O_M_Savings                           | = F_RFR_WtrSave * Eq.Incremental_Cost_per_Gal * I_Qty_Prop_Equip   |
| F RFR Energy Gas (Customer_Dth)              | = Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_gas / Eq.Conversion_Factor_gas * I_Qty_Prop_Equip           |
| F_RFR_WtrSave                                | = ( Eq.Baseline_GPM - Eq.Proposed_GPM ) * Eq.Runtime_Hours * P_RFR_Hours * 60  |
| Eq.Water_Heater_Delta_T                      | = Tset - Tcold   |
| <del>CHW Pre-Rinse</del>                     |  |
| F RFR kW (Customer_kW)                       | = Customer_kWh/Eq.Hours  |
| F RFR Energy Elec (Customer_kWh)             | = Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_electric / Eq.Conversion_Factor_Electric * I_Qty_Prop_Equip |
| F RFR PCKW (PC_kW_Customer)                  | = Customer_kW * Eq.Coincidence_Factor  |
| Incram_O_M_Savings                           | = F_RFR_WtrSave * Eq.Incremental_Cost_per_Gal * I_Qty_Prop_Equip   |
| Customer_Dth                                 | = Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_gas / Eq.Conversion_Factor_gas * I_Qty_Prop_Equip           |
| F_RFR_WtrSave                                | = ( Eq.Baseline_GPM - Eq.Proposed_GPM ) * Eq.Runtime_Hours * P_RFR_Hours * 60  |
| Eq.Water_Heater_Delta_T                      | = Tset - Tcold   |
| <b>Prescriptive</b>                          |  |
| <del>Anti-Sweat Heater Controls</del>        |  |
| F Cool AntiSweat kW (Customer_kW)            | = Eq_kW_Door * ( 1 + ( Eq.Door_Heat / Eq.COP ) ) * Eq.PAF * I_Doors_Controlled   |
| F Cool AntiSweat kWh (Customer_kWh)          | = Customer_kW * Eq.Hours   |
| F Cool Anti Sweat PCKW (PC_kW_Customer)      | = Customer_kW * Eq.Coincidence_Factor  |
| <del>Open to Closed Refrigerated Cases</del> |  |
| Customer kW                                  | = Customer kWh / Eq.Hours  |
| Customer kWh                                 | = (kWh_open - kWh_closed) x Linear Feet  |
| PC_kW_Customer                               | = Customer_kW * Eq.Coincidence_Factor  |
| kWh_open                                     | = (Baseline_Load * Infil_open) x (Eq.Load_Factor * 1 / 3412 * Eq.Hours x 1 / COP_Min) - HVAC_kWh_Open  |
| kWh_closed                                   | =(Baseline_Load * Infil_closed) x (Eq.Load_Factor * 1 / 3412 * Eq.Hours x 1 / COP_Min) - HVAC_kWh_Closed   |

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

|  |  |
|--|--|
| HVAC_kWh_Open                            | = (Eq.Baseline_Load * Eq.Infil_Open) * 1 / Eq.COP x 1 / 3412 * Eq.clg_duty_cyc * P_Clg_Hrs   |
| HVAC_kWh_Closed                          | = (Eq.Baseline_Load * Eq.Infil_Closed) * 1 / Eq.COP x 1 / 3412 * Eq.clg_duty_cyc * P_Clg_Hrs<br>73 kW/ft for closed freezer cases. |
| Close_The_Case_Customer_Dth              | = Eq.Baseline_Load * (Eq.Infil_open - * Eq.Infil_closed) * P_Htg_Hours * 1/1000000 * 1/Eq.Max_Efficiency                           |
| Kitchen Demand Controlled Ventilation    |  |
| F_DCV_kW (Customer_kW)                   | = i_qty_MC * i_hp_mc01 * P_kW_Factor   |
| F_DCV_kWh (Customer_kWh)                 | = Customer_kW * P_DCV_hours  |
| F_DCV_PC_kW (PC_kW_Customer)             | = Customer_kW * P_DCV_CF   |
| F_DCV_therms (Customer_Therms)           | = i_qty_MC * i_hp_mc01 * P_DCV_therms_per_hp   |
| Dishwashers                              |  |
| F_KC_kW (Customer_kW)                    | = Eq.kW_Savings * I_Qty_Prop_Equip   |
| F_KC_kWh (Customer_kWh)                  | = Eq.kW_Savings * Eq.Hours * I_Qty_Prop_Equip  |
| F_KC_PCKW (PC_kW_Customer)               | = Eq.kW_Savings * I_Qty_Prop_Equip * Eq.Coincidence_Factor   |
| F_HP_Tstat_Setback_Thm (Customer_Therms) | = Eq.Therms_Savings * I_Qty_Prop_Equip   |
| Increm_O_M_Savings                       | = Eq.Incremental_OM_Savings * I_Qty_Prop_Equip   |
| Electronically Commutated Motors         |  |
| F_Motors_EC_Motors_kW (Customer_kW)      | = ( Eq.kW_Baseline - Eq.Proposed_kW ) * I_Qty_Prop_Equip * ( 1 + 1/ Eq.COP )   |
| F_Motors_EC_Motors_kWh (Customer_kWh)    | = Customer_kW * Eq.Hours   |
| F_Motors_EC_Motors_PCKW (PC_kW_Customer) | = Customer_kW * Eq.Coincidence_Factor  |
| Medium Temperature Reach-In Cases        |  |
| F_RCaNc_kW (Customer_kW)                 | = Eq.kW_Savings_Factor * ( ( Eq.Baseline_Load - Eq.Proposed_Load ) * Eq.Load_Factor * ( 1 / Eq.COP ) ) / 3412 * I_Linear_Ft        |
| F_RCaNc_kWh (Customer_kWh)               | = Customer_kW * Eq.Hours   |
| F_RCaNc_PCKW (PC_kW_Customer)            | = Customer_kW * Eq.Coincidence_Factor  |
| No Heat Case Doors                       |  |
| F_NHDaFC_kW (Customer_kW)                | = ( Eq.kW_Baseline - Eq.kW ) * ( 1 + ( Eq.Residual_Heat_Fraction / Eq.COP ) ) * I_Qty_Prop_Equip                                   |
| F_NHDaFC_kWh (Customer_kWh)              | = Customer_kW * Eq.Hours   |
| F_NHDaFC_PCKW (PC_kW_Customer)           | = Customer_kW * Eq.Coincidence_Factor  |

| Variable ID                          | Value          | Description   |
|--------------------------------------|----------------|---|
| <b>Common</b>                        |                |   |
| Eq_Conversion_Factor_Electric        | 3,412          | Conversion of BTU to kWh  |
| Eq_Conversion_Factor_Gas             | 1,000,000      | Conversion of BTU to Dth  |
| SpecificHeat                         | 1.0            | Specific Heat of Water in btu / (lb x °F)   |
| Density_water                        | 8.34           | Density of water in lbs/gal   |
| Eq.COP (medium temp)                 | 2.28           | Coefficient of performance of compressor in the medium temperature applications (Reference 1) |
| Eq.COP (low temp)                    | 1.43           | Coefficient of performance of compressor in the low temperature applications (Reference 1)    |
| Eq_Min_Efficiency_electric           | 98%            | Efficiency of electric water heater   |
| Eq_Min_Efficiency_gas                | 80%            | Efficiency of gas water heater (Reference 3)  |
| Eq_Load_Factor (cooler)              | 62%            | Load Factor of refrigeration cooler system (Reference 2)                                      |
| Eq_Load_Factor (freezer)             | 80%            | Load Factor of refrigeration freezer system (Reference 2)                                     |
| <b>Direct Install</b>                |                |   |
| Coil_Cleaning_Tune-Up                |                |   |
| I_Qty_Prop_Equip                     | Customer Input | Quantity of proposed equipment installed  |
| Eq_kW_Savings (Refrigerator)         | 0.031          | Average kW-savings for refrigerators  |
| Eq_kW_Savings (Freezer)              | 0.049          | Average kW-savings for freezers   |
| Eq_Hours (Refrigerator)              | 8,760          | Equivalent full-load hours saved for refrigerators  |
| Eq_Hours (Freezer)                   | 8,760          | Equivalent full-load hours saved for freezers   |
| Lifetime                             | 1              | Measure lifetime  |
| Eq_Incremental_Capital_Cost_Electric | \$15.00-       | Incremental cost per unit   |
| Eq_Coincidence_Factor (Refrigerator) | 100%           | Coincidence Factor for refrigerators  |
| Eq_Coincidence_Factor (Freezer)      | 100%           | Coincidence Factor for freezers   |
| CHW_Aerator                          |                |   |
| I_Qty_Prop_Equip                     | Customer Input | Quantity of proposed equipment installed  |

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

|  |                |   |
|--|----------------|---|
| Tset (restroom)                            | 105            | Hot water setpoint temperature; °F  |
| Tset (kitchen)                             | 125            | Hot water setpoint temperature; °F  |
| Tcold                                      | 51.4           | Average groundwater temperature; °F (Reference 37)  |
| Eq,Baseline_GPM                            | 2.2            | Nameplate flowrate of baseline in gpm   |
| Eq,Proposed_GPM (restroom)                 | 0.6            | Nameplate flowrate of low-flow restroom application in gpm  |
| Eq,Proposed_GPM (kitchen)                  | 1.5            | Nameplate flowrate of low-flow kitchen application in gpm   |
| Eq,Runtime_Hours                           | See Table 2    | Number of hours per day equipment is used (Reference 39)  |
| P_RFR_Hours                                | See Table 2    | Number of days per year the equipment is operated based on building type  |
| Eq,Hours                                   | 8,760          | Available equipment hours per year  |
| Lifetime                                   | 9              | Measure lifetime  |
| Eq,Incremental_Capital_Cost_Electric & Gas | \$8.00         | Incremental Cost per unit (Reference 39)  |
| Eq,Incremental_Cost_per_Gal                | \$0.009010     | Water and sewer cost per gallon   |
| Eq,Coincidence_Factor (restroom)           | 1%             | Equipment coincidence factor  |
| Eq,Coincidence_Factor (kitchen)            | 1%             | Equipment coincidence factor  |
| <b>CHW Pre-Rinse</b>                       |                |   |
| Building Type                              | Customer Input | See Table 2 for list of choices   |
| I_Qty_Prop_Equip                           | Customer Input | Quantity of proposed equipment installed  |
| Tset                                       | 105            | Hot water setpoint temperature; °F  |
| Tcold                                      | 51.4           | Average groundwater temperature; °F (Reference 37)  |
| Eq,Baseline_GPM                            | 1.6            | Nameplate flowrate of baseline in gpm   |
| Eq,Proposed_GPM                            | 1.28           | Nameplate flowrate of low-flow prerinse sprayer in gpm  |
| Eq,Runtime_Hours                           | 1.5            | Number of hours per day equipment is used   |
| P_RFR_Hours                                | See Table 2    | Number of days per year the equipment is operated based on building type  |
| Eq,Hours                                   | 8,760          | Available equipment hours per year  |
| Lifetime                                   | 5              | Measure lifetime  |
| Eq,Incremental_Capital_Cost_Electric & Gas | \$45.00        | Incremental Cost per unit   |
| Eq,Incremental_Cost_per_Gal                | \$0.009010     | Water and sewer cost per gallon   |
| Eq,Coincidence_Factor                      | 6%             | Equipment coincidence factor  |
| <b>Prescriptive</b>                        |                |   |
| <b>Anti-Sweat Heater Controls</b>          |                |   |
| I_Doors_Controlled                         | Customer Input | Number of doors being controlled  |
| Eq,kW_Door                                 | See Table 4    | Average anti-sweat heater kW per door without controls  |
| Eq,kW_Door_Heat                            | 0.35           | Residual Heat fraction; estimated percentage of the heat produced by the heaters that remains in the freezer or cooler case and must be removed by the refrigeration unit. (Reference 24) |
| Eq,PAF                                     | See Table 4    | Percent of time the anti-sweat heaters are turned off by the controller   |
| Eq,Hours                                   | See Table 4    | Hours per year  |
| Measure Life                               | 12             | Lifetime  |
| Eq,Incremental_Cost_per_Ton                | See Table 4    | Incremental cost of efficient measures; See Tables 4  |
| Eq,Coincidence_Factor                      | See Table 4    | Coincidence Factor (Reference 15)   |
| <b>Open to Closed Refrigerated Cases</b>   |                |   |
| I_Linear_Ft                                | Customer Input | Linear feet of equipment installed  |
| Eq,COP_Min (Cooler)                        | 2.28           | Coefficient of performance of compressor in the medium temperature applications (Reference 1)   |
| Eq,COP_Min (Freezer)                       | 1.43           | Coefficient of performance of compressor in the low temperature applications (Reference 1)  |
| Eq,Hours                                   | 8760           | Annual hours of operation of refrigerated case  |
| Eq,Baseline_Load (Cooler)                  | 1500           | Cooler Total Load in BTU/h/ft (Ref 33)  |
| Eq,Baseline_Load (Freezer)                 | 1850           | Freezer Total Load in BTU/h/ft (Ref 33)   |
| Eq,Infil_open (Cooler)                     | 81.77%         | Fraction of Refrigerated Case Load that is infiltration for an open cooler  |
| Eq,Infil_open (Freezer)                    | 82.76%         | Fraction of Refrigerated Case Load that is infiltration for an open freezer   |
| Eq,Infil_clsd (Cooler)                     | 13.77%         | Fraction of Refrigerated Case Load that is infiltration for a closed cooler   |
| Eq,Infil_clsd (Freezer)                    | 14.76%         | Fraction of Refrigerated Case Load that is infiltration for a closed freezer  |
| P_Clg_Hrs                                  | 2908           | Number of hours per year that facility is in cooling mode, based on using a location-specific (Denver) bin hours calculation and an assumed facility balance point of 60 F                |
| Eq,clg_duty_cyc                            | 70%            | Cooling compressor duty cycle   |

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

|  |                 |   |
|--|-----------------|---|
| Eq.COP                                       | 3.2             | Coefficient of Performance for facility HVAC system, from Ref 33. This assumes a DX rooftop unit or similar   |
| P_Htg_Hours                                  | 5155            | Number of hours per year that facility is in heating mode, based on using a location-specific (Denver) bin hours calculation and an assumed facility balance point of 60 F, with a 5 degree economizing dead band before heating starts at 55 F |
| Eq.Max_Efficiency                            | 80%             | Heating System Efficiency   |
| Eq.Coincidence_Factor                        | 100%            | Coincidence Factor, based on 8,760 hour run time per year   |
| Measure Life                                 | 12.00           | Lifetime (Ref 11)   |
| Eq.Incremental_Capital_Cost_Electric         | \$497.82        | Incremental cost of efficient measures per linear foot (Ref 34) The incremental cost is split by avoided revenue requirements between gas and electric cost.  |
| <b>Kitchen Demand Controlled Ventilation</b> |                 |   |
| i_qty_MC                                     | Customer Input  | Quantity of proposed equipment installed  |
| i_hp_mc01                                    | Customer Input  | Horsepower of proposed equipment installed  |
| P_kW_Factor                                  | See Table 10    | kW savings per horsepower of controlled fan   |
| P_DCV_hours                                  | See Table 10    | hours of operation  |
| P_DCV_CF                                     | See Table 10    | Coincidence Factor, based on Zone   |
| P_DCV_therms_per_hp                          | See Table 10    | Therms savings per horsepower of controlled fan   |
| Measure Life                                 | 20              | Lifetime  |
| Eq.Incremental_Cost_per_HP                   | \$2,284.26      | Incremental cost per HP   |
| <b>Dishwashers</b>                           |                 |   |
| I_Qty_Prop_Equip                             | Customer Input  | Quantity of proposed equipment installed  |
| Eq.kW_Savings                                | See Table 9     | kW savings per dishwasher   |
| Eq.Hours                                     | See Table 9     | Annual hours of operation   |
| Eq.Coincidence_Factor                        | See Table 8     | Coincidence Factor  |
| Eq.Therms_Savings                            | See Table 6     | Natural gas savings per dishwasher  |
| Measure Life                                 | See Table 7 & 8 | Lifetime  |
| Eq.Incremental_Cost                          | See Table 7 & 8 | Incremental cost per dishwasher   |
| Eq.Incremental_OM_Savings                    | See Table 7 & 8 | Incremental O&M savings due to decrease in water consumption  |
| <b>Electronically Commutated Motors</b>      |                 |   |
| I_Qty_Prop_Equip                             | Customer Input  | Quantity of proposed equipment installed  |
| Eq.kW_Baseline                               | See Table 3     | Average input power for shaded pole or permanent split capacitor motor (Reference 15)   |
| Eq.Proposed kW                               | See Table 3     | Average input power for efficient motor (Reference 15)  |
| Eq.Hours                                     | See Table 3     | Hours per year (freezer subtracts defrost time) (Reference 15)  |
| Eq.Incremental_Cost_per_Ton                  | See Table 3     | Incremental cost per motor  |
| Eq.Coincidence_Factor                        | See Table 3     | Coincidence Factor  |
| <b>Medium Temperature Reach-In Cases</b>     |                 |   |
| I_Linear_Ft                                  | Customer Input  | Linear feet of equipment installed  |
| Eq.kW_Savings_Factor                         | 100%            | Percent of time the doors are used  |
| TDA  | 5.5             | Total Display area per linear foot. Assumed to be 5.5 square feet based on a 5.5 foot tall glass door.  |

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

|  |                |  |
|--|----------------|--|
| Eq.Baseline_Load                             | 1,652          | Btuh/ft load of the standard efficiency refrigerated case (Reference 38)   |
| Eq.Proposed_Load                             | 262            | Btuh/ft load of the high efficiency refrigerated case. (Reference 5)   |
| Eq.Hours                                     | 8,760          | Equipment hours per year   |
| Lifetime                                     | 15             | Measure lifetime   |
| Eq.Incremental_Cost_per_LF                   | \$686.29       | Incremental cost per linear feet of efficient measure (Reference 21).  |
| Eq.Coincidence_Factor                        | 100%           | Equipment coincidence factor   |
| <b>New Medium Temperature Reach-In Cases</b> |                |  |
| I_Linear_Ft                                  | Customer Input | Linear feet of equipment installed   |
| Eq.kW_Savings_Factor                         | 100%           | Percent of time the doors are used   |
| TDA  | 5.5            | Total Display area per linear foot. Assumed to be 5.5 square feet based on a 5.5 foot tall glass door.   |
| Eq.Baseline_Load                             | 1,652          | Btuh/ft load of the standard efficiency refrigerated case (Reference 38)   |
| Eq.Proposed_Load                             | 262            | Btuh/ft load of the high efficiency refrigerated case. (Reference 5)   |
| Eq.Hours                                     | 8,760          | Equipment hours per year   |
| Lifetime                                     | 15             | Measure lifetime   |
| Eq.Incremental_Cost_per_LF                   | \$337.58       | Incremental cost per linear feet of efficient measure (Reference 21 & 40).   |
| Eq.Coincidence_Factor                        | 100%           | Equipment coincidence factor   |
| <b>No Heat Case Doors</b>                    |                |  |
| I_Qty_Prop_Equip                             | Customer Input | Quantity of proposed equipment installed   |
| Eq.kW_Baseline                               | See Table 5    | Average kW for a standard case door (Reference 23 and 24)  |
| Eq.kW  | See Table 5    | Average kW for a no heat case door (Reference 2)   |
| Eq.Residual_Heat_Fraction                    | 0.35           | Estimated percentage of the heat produced by the heaters that remains in the freezer or cooler case and must be removed by the refrigeration unit. |
| Eq.Hours                                     | See Table 5    | Hours per year for no heat case doors (Reference 2)  |
| Eq.Incremental_Capital_Cost_Electric         | See Table 5    | Incremental cost per door  |
| Eq.Coincidence_Factor                        | See Table 5    | Coincidence Factor   |

| Inputs:  | Verified during M&V: |
|--|----------------------|
| <b>Direct Install</b>                                    |                      |
| Coil Cleaning Tune-Up                                    |                      |
| Type of Unit (freezer or refrigerator)                   | Yes                  |
| Quantity (# of units)                                    | Yes                  |
| <b>CHW-Aerator</b>                                       |                      |
| Gas or electric water heater                             | Yes                  |
| Quantity (# of faucet aerators)                          | Yes                  |
| Building type  | Yes                  |
| <b>CHW Pre-Rinse</b>                                     |                      |
| Gas or electric water heater                             | Yes                  |
| Quantity (# of sprayers)                                 | Yes                  |
| Building type  | Yes                  |
| <b>Prescriptive</b>                                      |                      |
| <b>Anti-Sweat Heater Controls</b>                        |                      |
| Application temperature (medium or low temperature case) | Yes                  |
| Number of doors controlled                               | Yes                  |
| <b>Open to Closed Case Retrofit</b>                      |                      |
| Application temperature (cooler or freezer)              | Yes                  |
| Linear feet installed                                    | Yes                  |
| <b>Kitchen Demand Controlled Ventilation</b>             |                      |
| Quantity (# of motors controlled)                        | Yes                  |
| County/Zone  | Yes                  |
| Horsepower (per motor controlled)                        | Yes                  |
| <b>Electronically Commutated Motors</b>                  |                      |
| Case type (Display Case or Walk-in)                      | Yes                  |
| Application temperature (Medium Temp or Low Temp)        | Yes                  |
| Quantity (# of motors)                                   | Yes                  |

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

|   |     |
|---|-----|
| <b>Medium Temperature Reach-In Cases</b>          |     |
| Application temperature (medium temperature)      | Yes |
| Linear feet installed                             | Yes |
| <b>New Medium Temperature Reach-In Cases</b>      |     |
| Application temperature (medium temperature)      | Yes |
| Linear feet installed                             | Yes |
| <b>For No Heat Doors:</b>                         |     |
| Application temperature (freezer or refrigerator) | Yes |
| Quantity (# of doors)                             | Yes |

**Assumptions:**

Enclosed Reach-In Cases, Open to Closed Case Retrofit  
 Existing case must be either a freezer or cooler multi-deck case.  
 Existing specialty, self-contained, and island cases do not qualify.  
 This measure is for replacement of open cases with new cases that include a case door.  
 Replacement cases must have doors, be tied into a central refrigeration system, and be purchased new.  
 Open to Closed Case retrofits must use "no heat" doors

**EC Motors**  
 Each motor is replaced with the same size on a 1 for 1 basis.  
 Rebates do not apply to rewound or repaired motors.

**References**

1. Energy Savings Potential and R&D Opportunities for Commercial Refrigeration, Final Report; Submitted to: U.S. Department of Energy, Energy Efficiency and Renewable Energy Building Technologies Program; Navigant Consulting, Inc.; September 23, 2009
2. PSC of Wisconsin, Focus on Energy Evaluation, Business Programs: Deemed Savings Manual V1.0
3. NREL/TP-550-46101 "Grocery Store 50% Energy Savings Technical Support Document" September 2009
4. State of Illinois Energy Efficiency Technical Reference Manual, Page 131. July 18, 2012.
5. Average of multiple vendor products
6. IMPACT AND PROCESS EVALUATION FINAL REPORT for CALIFORNIA URBAN WATER CONSERVATION COUNCIL 2004-5 PRE-RINSE SPRAY VALVE INSTALLATION PROGRAM (PHASE 2)
7. US DOE Building America Program. Building America Analysis Spreadsheet, Standard Benchmark DHW Schedules [http://www1.eere.energy.gov/buildings/building\\_america/analysis\\_spreadsheets.html](http://www1.eere.energy.gov/buildings/building_america/analysis_spreadsheets.html)
8. State of Illinois Energy Efficiency Technical Reference Manual, June 1st, 2012. Pages 109-113.
9. Title 10, Code of Federal Regulations, Part 431 - Energy Efficiency Program for Certain Commercial and Industrial Equipment, Subpart O - Commercial Prerinse Spray Valves. January 1, 2010.
10. Technology Data Characterizing Water Heating in Commercial Buildings: Application to End-Use Forecasting, Osman Sezgen and Jonathan G. Koomey, Lawrence Berkeley National Laboratory, December 1995.
11. 2008 Database for Energy-Efficient Resources, EUL/RUL (Effective/Remaining Useful Life) Values. <http://www.deeresources.com/deer2008exante/downloads/DEER%200607%20Measure%20Update%20Report.pdf>. Accessed on 7/31/12.
12. 2008 Database for Energy-Efficient Resources, Cost Values and Summary Documentation (updated 6/2/2008 - NR linear fluorescent labor costs typo) <http://www.deeresources.com/deer2008exante/downloads/DEER%200607%20Measure%20Update%20Report.pdf>. Accessed
13. Franklin Energy Services, LLC Engineering Estimate (10 min) and US Department of Energy. Federal Energy Management Program. Energy Cost Calculator for Faucets and Showerheads. Typical use for commercial aerator = 30min. <http://www1.eere.energy.gov>
14. Efficiency Vermont Technical Reference User Manual, 2/19/2010.
15. Monitored data from Custom Efficiency projects
16. Northwest Regional Technical Forum
17. Comprehensive Process and Impact Evaluation of the (Xcel Energy) Colorado Motor and Drive Efficiency Program, FINAL, March 28, 2011, TetraTech
18. ECM incremental costs are from Southern California Edison Work Paper WPSCNRRN0011: Evaporator Fan Motors
19. New York Standard Approach for Estimating Energy Savings from Energy Efficiency Measures in Commercial and Industrial Programs, Sept 1, 2009.
20. Energy Savings Potential and R&D Opportunities for Commercial Refrigeration, Final Report; Submitted to: U.S. Department of Energy, Energy Efficiency and Renewable Energy Building Technologies Program; Navigant Consulting, Inc.; September 23, 2009
21. [http://www.deeresources.com/files/DEER2016/download/2010-2012\\_WO017\\_Ex\\_Ante\\_Measure\\_Cost\\_Study\\_-\\_Final\\_Report.pdf](http://www.deeresources.com/files/DEER2016/download/2010-2012_WO017_Ex_Ante_Measure_Cost_Study_-_Final_Report.pdf)
22. A Study of Energy Efficient Solutions for Anti-Sweat Heaters. Southern California Edison RTTC. December 1999
23. Pennsylvania PUC Technical Reference Manual, June 2011
24. SCE Workpaper WPSCNRRN0009, Revision 0, Anti-Sweat Heat (ASH) Controls, October 15, 2007
25. Wisconsin Focus on Energy Anti-Sweat Heater Controls Technical Data Sheet, 2004.
26. Energy Use of Doored and Open Vertical Refrigerated Display Cases, Fricke and Becker; Presented at 2010 International Refrigeration and Air Conditioning Conference

## DEEMED SAVINGS TECHNICAL ASSUMPTIONS

27. Infiltration Modeling Guidelines for Commercial Building Energy Analysis, US Department of Energy Sept 2009
28. Arkansas Deemed Savings Quick Start Program Draft Report Commercial Measures Final Report, Nexant. CF and hours
29. HVAC Interactive Factors developed based on the Rundquist Simplified HVAC Interaction Factor method for Minnesota, presented on page 28 of the 11/93 issue of the ASHRAE Journal - "Calculating lighting and HVAC interactions".
30. Technical Reference User Manual No. 2004-31, Efficiency Vermont, 12/31/04. CF and Hours
31. Deemed Savings Database, Minnesota Office of Energy Security, 2008. CF, Hours, kW, Costs, Measure life
32. Net-to-Gross factor from 2008 Xcel Energy Lighting Efficiency Program Evaluation
33. Wisconsin Focus on Energy Technical Reference Manual 2015, pg. 238-241
34. Costs calculated and derived from four open-to-closed refrigerated case custom rebate projects.
35. Work Paper PECIREF\_PGE604 Vertical Refrigerated Case, Medium Temperature: Open to Closed (Retrofit)
36. ENERGY STAR
37. Denver Water's 2006 Treated Water Quality Summary Report; <http://www.denverwater.org/docs/assets/9A12FBC5-BCDF-1B42-D1BC5F0B1CE3B115/TreatedWQSummaryReport20061.pdf>
38. 2015 International Energy Conservation Code (IECC)
39. State of Illinois Energy Efficiency Technical Reference Manual, Pages 60-63 & Pages 90-97. February 8th, 2017.
40. **Custom Project History**

### **Changes from 2017 / 2018 Plan:**

- Updated runtime hours for pre-rinse sprayers.
- Updated coincidence factor and kW savings for coil cleaning tune-up measure.
- Updated incremental costs for medium-temp enclosed reach-in case measure.
- Updated heating efficiency and incremental costs for open to closed refrigerated cases calculations.
- Updated lifetime, incremental costs, and runtime hours for aerators.
- Added annual gallons per faucet values breakdown by end-use as opposed to using same value for all end-uses.
- Added gas savings for open to closed refrigerated cases.