

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

**Product: Commercial Refrigeration**

**Description:**

Prescriptive rebates will be offered for the installation of reach-in cases with doors, night curtains on refrigerator and freezer cases, EC Motors for Refrigeration Evaporators (retrofit only), Anti-Sweat Heater Controls (retrofit only) and/or replacement of standard refrigeration case doors with No Heat Case Doors, Retrofit of open multi-deck refrigerated cases with no heat doors, and replacement lighting equipment. Prescriptive rebates will also be offered for retrofitting open multideck coolers or freezers with solid glass doors.

**Program References:**

Measure "LED Refrigerated Case Lighting"	Refer to Program "CO - Lighting Efficiency" to find formulas for (Customer kW, Customer kWh, Customer PckW, etc.) for the "LED Refrigerated Case Lighting" measure.
Measure "LED Ref and Frz Screw In Fixture Retrofit"	Refer to Program "CO - Lighting Efficiency - Small Business" to find formulas for (Customer kW, Customer kWh, Customer PckW, etc.), in which the "LED Interior Lamp" measure is referenced.
Savings for Direct Install Measure "Energy Star Smart Thermostats"	Refer to Product "Commercial Building Controls" to find equations (Customer kW, Customer kWh, Customer PckW, Customer Dth, etc.) for the "Energy Star certified smart thermostat - AC & GAS", "Energy Star certified smart thermostat - AC ONLY", and the "Energy Star certified smart thermostat - AC & ELEC HEAT" electric measures.

**Equations:**

<b>Direct Install</b>	
CHW Aerator	
F RFR kW (Customer_kW)	= Customer_kWh/Eq.Hours
F RFR Energy Elec (Customer_kWh)	= Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_electric / Eq.Conversion_Factor_Electric * I_Qty_Prop_Equip
F RFR PckW (PC_kW_Customer)	= Customer_kW * Eq.Coincidence_Factor
Increm_O_M_Savings	= F_RFR_WtrSave * Eq.Incremental_Cost_per_Gal * I_Qty_Prop_Equip
F RFR Energy Gas (Customer_Dth)	= Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_gas / Eq.Conversion_Factor_gas * I_Qty_Prop_Equip
F_RFR_WtrSave	= ( Eq.Baseline_GPM - Eq.Proposed_GPM ) * Eq.Runtime_Hours * P_RFR_Hours * 60
Eq.Water_Heater_Delta_T	= Tset - Tcold
<b>CHW Pre-Rinse</b>	
F RFR kW (Customer_kW)	= Customer_kWh/Eq.Hours
F RFR Energy Elec (Customer_kWh)	= Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_electric / Eq.Conversion_Factor_Electric * I_Qty_Prop_Equip
F RFR PckW (PC_kW_Customer)	= Customer_kW * Eq.Coincidence_Factor
Increm_O_M_Savings	= F_RFR_WtrSave * Eq.Incremental_Cost_per_Gal * I_Qty_Prop_Equip
Customer_Dth	= Density_Water * SpecificHeat * F_RFR_WtrSave * Eq.Water_Heater_Delta_T / Eq.Min_Efficiency_gas / Eq.Conversion_Factor_gas * I_Qty_Prop_Equip
F_RFR_WtrSave	= ( Eq.Baseline_GPM - Eq.Proposed_GPM ) * Eq.Runtime_Hours * P_RFR_Hours * 60
Eq.Water_Heater_Delta_T	= Tset - Tcold
<b>Prescriptive</b>	
<b>Anti-Sweat Heater Controls</b>	
F Cool AntiSweat kW (Customer_kW)	= Eq.kW_Door * ( 1 + ( Eq.Door_Heat / Eq.COP ) ) * Eq.PAF * I_Doors_Controlled
F Cool AntiSweat kWh (Customer_kWh)	= Customer_kW * Eq.Hours
F Cool Anti Sweat PckW (PC_kW_Customer)	= Customer_kW * Eq.Coincidence_Factor
<b>Open to Closed Refrigerated Cases</b>	
Customer kW	= Customer kWh / Eq.Hours
Customer kWh	= (kWh_open - kWh_closed) x Linear_Feet
PC_kW_Customer	= Customer_kW * Eq.Coincidence_Factor
kWh_open	= (Baseline_Load * Infil_open) x (Eq.Load_Factor * 1 / 3412 * Eq.Hours x 1 / COP_Min) - HVAC_kWh_Open
kWh_closed	= (Baseline_Load * Infil_closed) x (Eq.Load_Factor * 1 / 3412 * Eq.Hours x 1 / COP_Min) - HVAC_kWh_Closed
HVAC_kWh_Open	= (Eq.Baseline_Load * Eq.Infil_Open) * 1 / Eq.COP x 1 / 3412 * Eq.clg_duty_cyc * P_Clg_Hrs

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

HVAC_kWh_Closed	= (Eq.Baseline_Load * Eq.Infil_Closed) * 1 / Eq.COP x 1 / 3412 * Eq.clg_duty_cyc * P_Clg_Hrs 73 kW/ft for closed freezer cases.
Close_The_Case_Customer_Dth	= Eq.Baseline_Load * (Eq.Infil_open - * Eq.Infil_closed) * P_Htg_Hours * 1/1000000 * 1/Eq.Max_Efficiency
Kitchen Demand Controlled Ventilation	
F_DCV_kW (Customer_kW)	= i_qty_MC * i_hp_mc01 * P_kW_Factor
F_DCV_kWh (Customer_kWh)	= Customer_kW * P_DCV_hours
F_DCV_PC_kW (PC_kW_Customer)	= Customer_kW * P_DCV_CF
F_DCV_therms (Customer_Therms)	= i_qty_MC * i_hp_mc01 * P_DCV_therms_per_hp
Dishwashers	
F_KC_kW (Customer_kW)	= Eq.kW_Savings * I_Qty_Prop_Equip
F_KC_kWh (Customer_kWh)	= Eq.kW_Savings * Eq.Hours * I_Qty_Prop_Equip
F_KC_PCKW (PC_kW_Customer)	= Eq.kW_Savings * I_Qty_Prop_Equip * Eq.Coincidence_Factor
F_HP_Tstat_Setback_Thm (Customer_Therms)	= Eq.Therms_Savings * I_Qty_Prop_Equip
Increm_O_M_Savings	= Eq.Incremental_OM_Savings * I_Qty_Prop_Equip
Electronically Commutated Motors	
F_Motors_EC_Motors_kW (Customer_kW)	= ( Eq.kW_Baseline - Eq.Proposed_kW ) * I_Qty_Prop_Equip * ( 1 + 1/ Eq.COP )
F_Motors_EC_Motors_kWh (Customer_kWh)	= Customer_kW * Eq.Hours
F_Motors_EC_Motors_PCKW (PC_kW_Customer)	= Customer_kW * Eq.Coincidence_Factor
Medium Temperature Reach-In Cases	
F_RCnC_kW (Customer_kW)	= Eq.kW_Savings_Factor * ( ( Eq.Baseline_Load - Eq.Proposed_Load ) * Eq.Load_Factor * ( 1 / Eq.COP ) ) / 3412 * I_Linear_Ft
F_RCnC_kWh (Customer_kWh)	= Customer_kW * Eq.Hours
F_RCnC_PCKW (PC_kW_Customer)	= Customer_kW * Eq.Coincidence_Factor
No Heat Case Doors	
F_NHDaFC_kW (Customer_kW)	= ( Eq.kW_Baseline - Eq.kW ) * ( 1 + ( Eq.Residual_Heat_Fraction / Eq.COP ) ) * I_Qty_Prop_Equip
F_NHDaFC_kWh (Customer_kWh)	= Customer_kW * Eq.Hours
F_NHDaFC_PCKW (PC_kW_Customer)	= Customer_kW * Eq.Coincidence_Factor

Variable ID	Value	Description
<b>Common</b>		
Eq.Conversion_Factor_Electric	3,412	Conversion of BTU to kWh
Eq.Conversion_Factor_Gas	1,000,000	Conversion of BTU to Dth
SpecificHeat	1.0	Specific Heat of Water in btu / (lb x °F)
Density_water	8.34	Density of water in lbs/gal
Eq.COP (medium temp)	2.28	Coefficient of performance of compressor in the medium temperature applications (Reference
Eq.COP (low temp)	1.43	Coefficient of performance of compressor in the low temperature applications (Reference 1)
Eq.Min_Efficiency_electric	98%	Efficiency of electric water heater
Eq.Min_Efficiency_gas	80%	Efficiency of gas water heater (Reference 3)
Eq.Load_Factor (cooler)	62%	Load Factor of refrigeration cooler system (Reference 2)
Eq.Load_Factor (freezer)	80%	Load Factor of refrigeration freezer system (Reference 2)
<b>Direct Install</b>		
CHW Aerator		
I_Qty_Prop_Equip	Customer Input	Quantity of proposed equipment installed
Tset (restroom)	105	Hot water setpoint temperature; °F
Tset (kitchen)	125	Hot water setpoint temperature; °F
Tcold	51.4	Average groundwater temperature; °F (Reference 37)
Eq.Baseline_GPM	2.2	Nameplate flowrate of baseline in gpm
Eq.Proposed_GPM (restroom)	0.6	Nameplate flowrate of low-flow restroom application in gpm
Eq.Proposed_GPM (kitchen)	1.5	Nameplate flowrate of low-flow kitchen application in gpm
Eq.Runtime_Hours	See Table 2	Number of hours per day equipment is used (Reference 39)
P_RFR_Hours	See Table 2	Number of days per year the equipment is operated based on building type
Eq.Hours	8,760	Available equipment hours per year
Lifetime	9	Measure lifetime
Eq.Incremental_Capital_Cost_Electric & Gas	\$8.00	Incremental Cost per unit (Reference 39)

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

Eq.Incremental_Cost_per_Gal	\$0.009010	Water and sewer cost per gallon
Eq.Coincidence_Factor (restroom)	1%	Equipment coincidence factor
Eq.Coincidence_Factor (kitchen)	1%	Equipment coincidence factor
CHW Pre-Rinse		
Building Type	Customer Input	See Table 2 for list of choices
I_Qty_Prop_Equip	Customer Input	Quantity of proposed equipment installed
Tset	105	Hot water setpoint temperature; °F
Tcold	51.4	Average groundwater temperature; °F (Reference 37)
Eq.Baseline_GPM	1.6	Nameplate flowrate of baseline in gpm
Eq.Proposed_GPM	1.28	Nameplate flowrate of low-flow prerinse sprayer in gpm
Eq.Runtime_Hours	1.5	Number of hours per day equipment is used
P_RFR_Hours	See Table 2	Number of days per year the equipment is operated based on building type
Eq.Hours	8,760	Available equipment hours per year
Lifetime	5	Measure lifetime
Eq.Incremental_Capital_Cost_Electric & Gas	\$45.00	Incremental Cost per unit
Eq.Incremental_Cost_per_Gal	\$0.009010	Water and sewer cost per gallon
Eq.Coincidence_Factor	6%	Equipment coincidence factor
<b>Energy Star Smart Thermostats</b>		
<b>Incremental Cost</b>	<b>\$175.00</b>	<b>Cost of the High Efficiency technology from implementer. *Costs are re-evaluated throughout the year and updated to account for the rapidly evolving market. The incremental cost to install the thermostats is split between the demand response and energy efficiency programs.</b>
<b>Prescriptive</b>		
Anti-Sweat Heater Controls		
I_Doors_Controlled	Customer Input	Number of doors being controlled
Eq.kW_Door	See Table 4	Average anti-sweat heater kW per door without controls
Eq.kW_Door_Heat	0.35	Residual Heat fraction; estimated percentage of the heat produced by the heaters that remains in the freezer or cooler case and must be removed by the refrigeration unit. (Reference 24)
Eq.PAF	See Table 4	Percent of time the anti-sweat heaters are turned off by the controller
Eq.Hours	See Table 4	Hours per year
Measure Life	12	Lifetime
Eq.Incremental_Cost_per_Ton	See Table 4	Incremental cost of efficient measures; See Tables 4
Eq.Coincidence_Factor	See Table 4	Coincidence Factor (Reference 15)
<b>Open to Closed Refrigerated Cases</b>		
I_Linear_Ft	Customer Input	Linear feet of equipment installed
Eq.COP_Min (Cooler)	2.28	Coefficient of performance of compressor in the medium temperature applications (Reference 1)
Eq.COP_Min (Freezer)	1.43	Coefficient of performance of compressor in the low temperature applications (Reference 1)
Eq.Hours	8760	Annual hours of operation of refrigerated case
Eq.Baseline_Load (Cooler)	1500	Cooler Total Load in BTU/h/ft (Ref 33)
Eq.Baseline_Load (Freezer)	1850	Freezer Total Load in BTU/h/ft (Ref 33)
Eq.Infil_open (Cooler)	81.77%	Fraction of Refrigerated Case Load that is infiltration for an open cooler
Eq.Infil_open (Freezer)	82.76%	Fraction of Refrigerated Case Load that is infiltration for an open freezer
Eq.Infil_clsd (Cooler)	13.77%	Fraction of Refrigerated Case Load that is infiltration for a closed cooler
Eq.Infil_clsd (Freezer)	14.76%	Fraction of Refrigerated Case Load that is infiltration for a closed freezer
P_Clg_Hrs	2908	Number of hours per year that facility is in cooling mode, based on using a location-specific (Denver) bin hours calculation and an assumed facility balance point of 60 F
Eq.clg_duty_cyc	70%	Cooling compressor duty cycle
Eq.COP	3.2	Coefficient of Performance for facility HVAC system, from Ref 33. This assumes a DX rooftop unit or similar
P_Htg_Hours	5155	Number of hours per year that facility is in heating mode, based on using a location-specific (Denver) bin hours calculation and an assumed facility balance point of 60 F, with a 5 degree economizing dead band before heating starts at 55 F

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

Eq.Max_Efficiency	80%	Heating System Efficiency
Eq.Coincidence_Factor	100%	Coincidence Factor, based on 8,760 hour run time per year
Measure Life	12.00	Lifetime (Ref 11)
Eq.Incremental_Capital_Cost_Electric	\$497.82	Incremental cost of efficient measures per linear foot (Ref 34) The incremental cost is split by avoided revenue requirements between gas and electric cost.
<b>Kitchen Demand Controlled Ventilation</b>		
i_qty_MC	Customer Input	Quantity of proposed equipment installed
i_hp_mc01	Customer Input	Horsepower of proposed equipment installed
P_kW_Factor	See Table 10	kW savings per horsepower of controlled fan
P_DCV_hours	See Table 10	hours of operation
P_DCV_CF	See Table 10	Coincidence Factor, based on Zone
P_DCV_therms_per_hp	See Table 10	Therms savings per horsepower of controlled fan
Measure Life	20	Lifetime
Eq.Incremental_Cost_per_HP	\$2,284.26	Incremental cost per HP
<b>Dishwashers</b>		
I_Qty_Prop_Equip	Customer Input	Quantity of proposed equipment installed
Eq.kW_Savings	See Table 9	kW savings per dishwasher
Eq.Hours	See Table 9	Annual hours of operation
Eq.Coincidence_Factor	See Table 8	Coincidence Factor
Eq.Therms_Savings	See Table 6	Natural gas savings per dishwasher
Measure Life	See Table 7 & 8	Lifetime
Eq.Incremental_Cost	See Table 7 & 8	Incremental cost per dishwasher
Eq.Incremental_OM_Savings	See Table 7 & 8	Incremental O&M savings due to decrease in water consumption
<b>Electronically Commutated Motors</b>		
I_Qty_Prop_Equip	Customer Input	Quantity of proposed equipment installed
Eq.kW_Baseline	See Table 3	Average input power for shaded pole or permanent split capacitor motor (Reference 15)
Eq.Proposed_kW	See Table 3	Average input power for efficient motor (Reference 15)
Eq.Hours	See Table 3	Hours per year (freezer subtracts defrost time) (Reference 15)
Eq.Incremental_Cost_per_Ton	See Table 3	Incremental cost per motor
Eq.Coincidence_Factor	See Table 3	Coincidence Factor
<b>New Medium Temperature Reach-In Cases</b>		
I_Linear_Ft	Customer Input	Linear feet of equipment installed
Eq.kW_Savings_Factor	100%	Percent of time the doors are used
TDA	5.5	Total Display area per linear foot. Assumed to be 5.5 square feet based on a 5.5 foot tall glass door.
Eq.Baseline_Load	1,652	Btuh/ft load of the standard efficiency refrigerated case (Reference 38)
Eq.Proposed_Load	262	Btuh/ft load of the high efficiency refrigerated case. (Reference 5)
Eq.Hours	8,760	Equipment hours per year
Lifetime	15	Measure lifetime
Eq.Incremental_Cost_per_LF	\$337.58	Incremental cost per linear feet of efficient measure (Reference 21 & 40).
Eq.Coincidence_Factor	100%	Equipment coincidence factor
<b>No Heat Case Doors</b>		
I_Qty_Prop_Equip	Customer Input	Quantity of proposed equipment installed
Eq.kW_Baseline	See Table 5	Average kW for a standard case door (Reference 23 and 24)
Eq.kW	See Table 5	Average kW for a no heat case door (Reference 2)
Eq.Residual_Heat_Fraction	0.35	Estimated percentage of the heat produced by the heaters that remains in the freezer or cooler case and must be removed by the refrigeration unit.
Eq.Hours	See Table 5	Hours per year for no heat case doors (Reference 2)
Eq.Incremental_Capital_Cost_Electric	See Table 5	Incremental cost per door
Eq.Coincidence_Factor	See Table 5	Coincidence Factor

<b>Inputs:</b>	<b>Verified during M&amp;V:</b>
Direct Install	
CHW-Aerator	
Gas or electric water heater	Yes

DEEMED SAVINGS TECHNICAL ASSUMPTIONS

Quantity (# of faucet aerators)	Yes
Building type	Yes
CHW Pre-Rinse	
Gas or electric water heater	Yes
Quantity (# of sprayers)	Yes
Building type	Yes
Smart Thermostats	
Quantity (# of smart thermostats)	Yes
Building type	Yes
Prescriptive	
Anti-Sweat Heater Controls	
Application temperature (medium or low temperature case)	Yes
Number of doors controlled	Yes
Open to Closed Case Retrofit	
Application temperature (cooler or freezer)	Yes
Linear feet installed	Yes
Kitchen Demand Controlled Ventilation	
Quantity (# of motors controlled)	Yes
County/Zone	Yes
Horsepower (per motor controlled)	Yes
Electronically Commutated Motors	
Case type (Display Case or Walk-in)	Yes
Application temperature (Medium Temp or Low Temp)	Yes
Quantity (# of motors)	Yes
New Medium Temperature Reach-In Cases	
Application temperature (medium temperature)	Yes
Linear feet installed	Yes
For No Heat Doors:	
Application temperature (freezer or refrigerator)	Yes
Quantity (# of doors)	Yes

**Assumptions:**

Enclosed Reach-In Cases, Open to Closed Case Retrofit  
 Existing case must be either a freezer or cooler multi-deck case.  
 Existing specialty, self-contained, and island cases do not qualify.  
 This measure is for replacement of open cases with new cases that include a case door.  
 Replacement cases must have doors, be tied into a central refrigeration system, and be purchased new.  
 Open to Closed Case retrofits must use "no heat" doors

EC Motors  
 Each motor is replaced with the same size on a 1 for 1 basis.  
 Rebates do not apply to rewound or repaired motors.

**References**

1. Energy Savings Potential and R&D Opportunities for Commercial Refrigeration, Final Report; Submitted to: U.S. Department of Energy, Energy Efficiency and Renewable Energy Building Technologies Program; Navigant Consulting, Inc.; September 23, 2009
2. PSC of Wisconsin, Focus on Energy Evaluation, Business Programs: Deemed Savings Manual V1.0
3. NREL/TP-550-46101 "Grocery Store 50% Energy Savings Technical Support Document" September 2009
4. State of Illinois Energy Efficiency Technical Reference Manual, Page 131. July 18, 2012.
5. Average of multiple vendor products
6. IMPACT AND PROCESS EVALUATION FINAL REPORT for CALIFORNIA URBAN WATER CONSERVATION COUNCIL 2004-5 PRE-RINSE SPRAY VALVE INSTALLATION PROGRAM (PHASE 2)
7. US DOE Building America Program. Building America Analysis Spreadsheet, Standard Benchmark DHW Schedules [http://www1.eere.energy.gov/buildings/building\\_america/analysis\\_spreadsheets.html](http://www1.eere.energy.gov/buildings/building_america/analysis_spreadsheets.html)
8. State of Illinois Energy Efficiency Technical Reference Manual, June 1st, 2012. Pages 109-113.
9. Title 10, Code of Federal Regulations, Part 431 - Energy Efficiency Program for Certain Commercial and Industrial Equipment, Subpart O - Commercial Prerinse Spray Valves. January 1, 2010.

## DEEMED SAVINGS TECHNICAL ASSUMPTIONS

10. Technology Data Characterizing Water Heating in Commercial Buildings: Application to End-Use Forecasting, Osman Sezgen and Jonathan G. Koomey, Lawrence Berkeley National Laboratory, December 1995.
11. 2008 Database for Energy-Efficient Resources, EUL/RUL (Effective/Remaining Useful Life) Values.  
<http://www.deeresources.com/deer2008exante/downloads/DEER%200607%20Measure%20Update%20Report.pdf>. Accessed on 7/31/12.
12. 2008 Database for Energy-Efficient Resources, Cost Values and Summary Documentation (updated 6/2/2008 - NR linear fluorescent labor costs typo)  
<http://www.deeresources.com/deer2008exante/downloads/DEER%200607%20Measure%20Update%20Report.pdf>. Accessed
13. Franklin Energy Services, LLC Engineering Estimate (10 min) and US Department of Energy. Federal Energy Management Program. Energy Cost Calculator for Faucets and Showerheads. Typical use for commercial aerator = 30min. <http://www1.eere.energy.gov>
14. Efficiency Vermont Technical Reference User Manual, 2/19/2010.
15. Monitored data from Custom Efficiency projects
16. Northwest Regional Technical Forum
17. Comprehensive Process and Impact Evaluation of the (Xcel Energy) Colorado Motor and Drive Efficiency Program, FINAL, March 28, 2011, TetraTech
18. ECM incremental costs are from Southern California Edison Work Paper WPSCNRRN0011: Evaporator Fan Motors
19. New York Standard Approach for Estimating Energy Savings from Energy Efficiency Measures in Commercial and Industrial Programs, Sept 1, 2009.
20. Energy Savings Potential and R&D Opportunities for Commercial Refrigeration, Final Report; Submitted to: U.S. Department of Energy, Energy Efficiency and Renewable Energy Building Technologies Program; Navigant Consulting, Inc.; September 23, 2009
21. [http://www.deeresources.com/files/DEER2016/download/2010-2012\\_WO017\\_Ex\\_Ante\\_Measure\\_Cost\\_Study\\_-\\_Final\\_Report.pdf](http://www.deeresources.com/files/DEER2016/download/2010-2012_WO017_Ex_Ante_Measure_Cost_Study_-_Final_Report.pdf)
22. A Study of Energy Efficient Solutions for Anti-Sweat Heaters. Southern California Edison RTTC. December 1999
23. Pennsylvania PUC Technical Reference Manual, June 2011
24. SCE Workpaper WPSCNRRN0009, Revision 0, Anti-Sweat Heat (ASH) Controls, October 15, 2007
25. Wisconsin Focus on Energy Anti-Sweat Heater Controls Technical Data Sheet, 2004.
26. Energy Use of Doored and Open Vertical Refrigerated Display Cases, Fricke and Becker; Presented at 2010 International Refrigeration and Air Conditioning Conference
27. Infiltration Modeling Guidelines for Commercial Building Energy Analysis, US Department of Energy Sept 2009
28. Arkansas Deemed Savings Quick Start Program Draft Report Commercial Measures Final Report, Nexant. CF and hours
29. HVAC Interactive Factors developed based on the Rundquist Simplified HVAC Interaction Factor method for Minnesota, presented on page 28 of the 11/93 issue of the ASHRAE Journal - "Calculating lighting and HVAC interactions".
30. Technical Reference User Manual No. 2004-31, Efficiency Vermont, 12/31/04. CF and Hours
31. Deemed Savings Database, Minnesota Office of Energy Security, 2008. CF, Hours, kW, Costs, Measure life
32. Net-to-Gross factor from 2008 Xcel Energy Lighting Efficiency Program Evaluation
33. Wisconsin Focus on Energy Technical Reference Manual 2015, pg. 238-241
34. Costs calculated and derived from four open-to-closed refrigerated case custom rebate projects.
35. Work Paper PECIREF\_PGE604 Vertical Refrigerated Case, Medium Temperature: Open to Closed (Retrofit)
36. ENERGY STAR
37. Denver Water's 2006 Treated Water Quality Summary Report; <http://www.denverwater.org/docs/assets/9A12FBC5-BCDF-1B42-D1BC5F0B1CE3B115/TreatedWQSummaryReport20061.pdf>
38. 2015 International Energy Conservation Code (IECC)
39. State of Illinois Energy Efficiency Technical Reference Manual, Pages 60-63 & Pages 90-97. February 8th, 2017.
40. Custom Project History

### Changes from 2017 / 2018 Plan:

Updated runtime hours for pre-rinse sprayers.  
Updated coincidence factor and kW savings for coil cleaning tune-up measure.  
Updated incremental costs for medium-temp enclosed reach-in case measure.  
Updated heating efficiency and incremental costs for open to closed refrigerated cases calculations.  
Updated lifetime, incremental costs, and runtime hours for aerators.  
Added annual gallons per faucet values breakdown by end-use as opposed to using same value for all end-uses.  
Added gas savings for open to closed refrigerated cases.