

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF COLORADO**

* * * * *

**IN THE MATTER OF THE APPLICATION)
OF PUBLIC SERVICE COMPANY OF)
COLORADO FOR APPROVAL OF ITS) PROCEEDING NO. 21A-____E
2021 ELECTRIC RESOURCE PLAN AND)
CLEAN ENERGY PLAN)**

DIRECT TESTIMONY AND ATTACHMENTS OF KEVIN D. CARDEN

ON

BEHALF OF

PUBLIC SERVICE COMPANY OF COLORADO

March 31, 2021

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF COLORADO**

* * * * *

IN THE MATTER OF THE APPLICATION)
OF PUBLIC SERVICE COMPANY OF)
COLORADO FOR APPROVAL OF ITS) PROCEEDING NO. 21A-____E
2021 ELECTRIC RESOURCE PLAN AND)
CLEAN ENERGY PLAN)

DIRECT TESTIMONY AND ATTACHMENTS OF KEVIN D. CARDEN

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
I. INTRODUCTION, QUALIFICATIONS, AND PURPOSE OF TESTIMONY	6
II. PLANNING RESERVE MARGIN & RESOURCE ADEQUACY STUDY OVERVIEW	12

LIST OF ATTACHMENTS

Attachment KDC-1	Planning Reserve Margin and Resource Adequacy Study, Final Report, prepared for Public Service Company of Colorado by Astrapé Consulting
Attachment KDC-2	Reserve Margin References Table
Attachment KDC-3	Curriculum Vitae of Kevin D. Carden

GLOSSARY OF ACRONYMS AND DEFINED TERMS

<u>Acronym/Defined Term</u>	<u>Meaning</u>
2021 ERP & CEP	2021 Electric Resource Plan and Clean Energy Plan
AESO	Alberta Electric System Operator
Astrapé	Astrapé Consulting
BHEC	Black Hills Energy Corporation
Commission	Colorado Public Utilities Commission
CSU	Colorado Springs Utilities
ELCC	Effective Load Carrying Capability
ERCOT	Electric Reliability Council of Texas
FERC	Federal Energy Regulatory Commission
IEEE	Institute of Electrical and Electronics Engineers
JDA	Joint Dispatch Agreement
LOLE	Loss of Load Expectation
LOLH	Loss of Load Hours
MISO	Midwest Independent System Operator
MW	Megawatt
NERC	North American Electric Reliability Council
NYISO	New York Independent System Operator
PACE	PacifiCorp East
PRPA	Platte River Power Authority
Public Service or Company	Public Service Company of Colorado

<u>Acronym/Defined Term</u>	<u>Meaning</u>
SCS	Southern Company Services
SERVM	Strategic Energy and Risk Valuation Model
SPP	Southwest Power Pool
The Study	Planning Reserve Margin and Resource Adequacy Study
TVA	Tennessee Valley Authority

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF COLORADO**

* * * * *

**IN THE MATTER OF THE APPLICATION)
OF PUBLIC SERVICE COMPANY OF)
COLORADO FOR APPROVAL OF ITS) PROCEEDING NO. 21A-____E
2021 ELECTRIC RESOURCE PLAN AND)
CLEAN ENERGY PLAN)**

DIRECT TESTIMONY AND ATTACHMENTS OF KEVIN D. CARDEN

1 **I. INTRODUCTION, QUALIFICATIONS, AND PURPOSE OF TESTIMONY**

2 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

3 A. My name is Kevin D. Carden. My business address is 3000 Riverchase Galleria,
4 Suite 575, Hoover, Alabama 35244.

5 **Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?**

6 A. I am the Director of Astrapé Consulting (“Astrapé”).

7 **Q. ON WHOSE BEHALF ARE YOU TESTIFYING IN THE PROCEEDING?**

8 A. I am testifying on behalf of Public Service Company of Colorado (“Public Service”
9 or the “Company”).

10 **Q. WHAT IS THE PURPOSE OF YOUR DIRECT TESTIMONY?**

11 A. The purpose of my Direct Testimony is to introduce and summarize the Planning
12 Reserve Margin and Resource Adequacy Study that Astrapé conducted on behalf
13 of Public Service. More specifically, I discuss the input assumptions, study
14 methodology, and results of the study. I also provide an overview of how the study
15 results compare to similar planning reserve margin and resource adequacy

1 assessments on an industry-wide basis. The Planning Reserve Margin and
2 Resource Adequacy Study (“the Study”) is provided as Attachment KDC-1 to my
3 Direct Testimony.

4 **Q. WHAT IS ASTRAPÉ AND WHAT WORK DO THEY DO IN THE UTILITY**
5 **INDUSTRY?**

6 A. Astrapé is a Resource Planning Consulting firm that specializes in generation
7 resource adequacy planning. We were founded in 2005 and have since been
8 providing consulting services using our Strategic Energy and Risk Valuation Model
9 (“SERVM”) for utilities, independent system operators, and regulators around the
10 world. We also license SERVM to planning entities. Studies using SERVM have
11 been vetted through public regulatory processes for over 30 years.

12 **Q. WHAT IS YOUR EDUCATIONAL BACKGROUND AND WORK EXPERIENCE?**

13 A. I hold a Bachelor of Science Degree in Industrial Engineering from the University
14 of Alabama. Prior to starting Astrapé in 2005, I was employed by Southern
15 Company Services, Inc. (“SCS”) as a reliability engineer, where I performed
16 resource adequacy studies for Alabama Power Company, Georgia Power
17 Company, Mississippi Power Company, and Gulf Power Company. I am an active
18 participant in several industry groups concerned with resource adequacy and
19 reliability, including the North American Electric Reliability Council (“NERC”)
20 Probabilistic Assessment Working Group and Institute of Electrical and Electronics
21 Engineers (“IEEE”) Loss of Load Expectation Working Group.

1 **Q. WHAT ARE YOUR JOB DUTIES AND RESPONSIBILITIES AT ASTRAPÉ?**

2 A. As the Director of Astrapé Consulting, I primarily manage the SERVVM software for
3 Astrapé and perform reliability studies, capacity valuation studies, and renewable
4 integration studies using SERVVM for clients across North America and
5 internationally. SERVVM was originally developed by SCS in the 1980s to assist
6 with system reliability planning needs. Astrapé took over maintenance of the
7 model in 2005 and began marketing the software to other entities across the
8 country. In addition to providing resource adequacy analyses for many of the
9 largest utilities in the nation, Astrapé has performed resource adequacy analyses
10 for many of the organized markets in North America, including Midwest
11 Independent System Operator (“MISO”), Southwest Power Pool (“SPP”), Electric
12 Reliability Council of Texas (“ERCOT”), PJM, and Alberta Electric System
13 Operator (“AESO”). Most of these entities rely on SERVVM simulations for their
14 resource adequacy assessments. I have also performed studies for the Federal
15 Energy Regulatory Commission (“FERC”) and the United States Department of
16 Energy on the implications of market structure on electric system reliability. My
17 curriculum vitae is provided as Attachment KDC-D-3.

18 **Q. WHAT WORK WAS ASTRAPÉ ASKED TO PERFORM REGARDING PUBLIC**
19 **SERVICE’S 2021 ELECTRIC RESOURCE PLAN?**

20 A. For the Company’s 2021 Electric Resource Plan and Clean Energy Plan (“2021
21 ERP & CEP”), Astrapé was asked to develop data inputs to be used in a planning
22 reserve margin and resource adequacy study, construct a model of the Public
23 Service system, and identify a planning reserve margin to be applied to the

1 forecasted Public Service peak load to maintain system reliability at industry
2 standards. The development of the data inputs included creating historical
3 weather-based representations of load, wind, and solar hourly profiles, historical
4 performance-based generation unit outages, non-firm gas supply outages, and
5 transmission availability outages. The resulting model was to capture generation,
6 transmission, and load topology, generation resource characteristics, energy-
7 limited resource characteristics, ancillary service requirements, reserve sharing
8 group requirements and response, and market reliance limits of the Public Service
9 system.

10 **Q. PLEASE DESCRIBE THE WORK YOU PERFORMED FOR PUBLIC SERVICE**
11 **THAT IS THE SUBJECT OF YOUR TESTIMONY AS IT RELATES TO THE**
12 **PLANNING RESERVE MARGIN AND RESOURCE ADEQUACY STUDY.**

13 A. Astrapé developed the data inputs for the SERVVM model outlined in the request
14 for proposal issued by Public Service that sought proposals for performing a
15 planning reserve margin and resource adequacy study. This includes
16 development of hourly load, wind, and solar profiles, generator outages,
17 transmission constraints and system resources for Public Service and its
18 neighboring systems. The SERVVM model was then used to identify the planning
19 reserve margin for Public Service that will result in a system LOLE of one day in
20 ten years for the planning years of 2021, 2023, 2026 and, 2030. Astrapé also
21 performed multiple sensitivity analyses to examine the reserve margin impact of
22 varying assumptions.

1 **Q. HAVE YOU PERFORMED SIMILAR WORK FOR OTHER UTILITIES?**

2 A. Yes. Astrapé has performed resource adequacy studies for other utilities including
3 Duke Energy Corporation, Tennessee Valley Authority (“TVA”), Southern
4 Company, Cleco, Louisville Gas and Electric, Santee Cooper, North Carolina
5 Electric Membership Corporation, Georgia System Operations Corporation, and
6 Public Service Company of New Mexico. As noted above, Astrapé has also
7 performed related resource adequacy studies for large independent operators
8 such as ERCOT, SPP, MISO, and AESO.

9 **Q. ARE YOU SPONSORING ANY ATTACHMENTS AS PART OF YOUR DIRECT**
10 **TESTIMONY?**

11 A. Yes. I am sponsoring the following three attachments:

- 12 • Attachment KDC-1 is the Planning Reserve Margin and Resource Adequacy
13 Study, prepared for Public Service by Astrapé;
- 14 • Attachment KDC-2 is a summary table of planning reserve margin references
15 across multiple entities; and
- 16 • Attachment KDC-3 is a copy of my curriculum vitae.

17 **Q. BEFORE DISCUSSING THE DETAILS OF THE STUDY, WHAT IS PUBLIC**
18 **SERVICE’S CURRENT RESERVE MARGIN AND WHAT IS THE**
19 **RECOMMENDED TARGET RESERVE MARGIN BASED ON ASTRAPÉ’S**
20 **ANALYSIS?**

21 A. Public Service’s current planning reserve margin is 16.3 percent. This planning
22 reserve margin has been used for ERP and resource adequacy purposes since
23 2008. As a result of the Study, Astrapé recommends a target reserve margin range
24 of 18 to 20 percent to adequately ensure compliance with a 0.1 Loss of Load

1 Expectation (“LOLE”) standard. Table KDC-D-1 below is a reproduction of Table
2 ES1. 0.1 LOLE Results from the Study.

3 **Table KDC-D-1: LOLE Results**

Year	2021	2023	2026	2030
0.1 LOLE Reserve Margin	17.4%	19.3%	19.1%	18.0%

4

1 **Q. PLEASE EXPLAIN RESERVE MARGIN AND HOW IT IS DEFINED FOR**
2 **PURPOSES OF THE STUDY.**

3 A. Reserve margin represents the megawatt (“MW”) amount of generation capacity
4 that a utility maintains on its system above its forecast of peak load, in order to
5 accommodate for example, events such as unexpected outages of generating
6 units or higher than expected customer load due to extreme weather. Reserve
7 margin on a percent basis is defined by the formula:

8
$$\text{reserve margin} = (\text{resources} - \text{firm peak demand}) / (\text{firm peak demand}).$$

9 The resources component of the formula represents the capacity in MW of
10 generation resources available on-peak. The nameplate MW rating of energy
11 limited or non-dispatchable resources such as renewables is not used when
12 calculating the reserve margin since their output is highly variable. Rather, an
13 accounting mechanism such as effective load carrying capability (“ELCC”) must
14 be employed to those resources that gives credit for their expected contributions
15 to reliability. Accurate quantification of a resource’s reliability contribution will
16 result in a relatively stable reserve margin over time that meets reliability
17 standards. Firm peak demand in the reserve margin formula represents the
18 median annual peak demand forecast. Half of all weather scenarios would be
19 expected to produce an annual peak lower than the forecast and half would be
20 expected to produce an annual peak higher than the forecast.

1 **Q. WHY IS IT IMPORTANT THAT UTILITIES ESTABLISH AN ADEQUATE**
2 **RESERVE MARGIN?**

3 A. It is important to establish an adequate reserve margin because firm load
4 customers expect to have electricity at all times of the year, especially during
5 extreme weather conditions like hot summer days when there can be increased
6 resource adequacy risk for Public Service. To avoid firm load shed events and
7 ensure reliability during these peak periods, Public Service should maintain an
8 adequate reserve margin to manage variable conditions like extreme weather, load
9 growth, and forced outages of generating units. It is particularly important to
10 ensure adequate reserve margin is available to maintain reliability as Public
11 Service retires conventional fossil fuel resources and adds increasing levels of
12 intermittent and energy limited resources. It is important to note, however, that an
13 adequate reserve margin does not imply zero firm load shed events. Constructing
14 a system with zero probability of firm load shed would be prohibitively expensive.

15 **Q. HOW IS RESOURCE ADEQUACY RISK GENERALLY ADDRESSED IN THE**
16 **RESOURCE PLANNING PROCESS?**

17 A. Most entities perform simulations which incorporate distributions of weather
18 uncertainty, load forecast uncertainty, and generation performance uncertainty
19 and identify the frequency with which load plus ancillary service requirements are
20 greater than the available generating capacity. The frequency of shortfalls (i.e.,
21 firm load shed events) is measured in LOLE. Simulations are performed at varying
22 reserve margin levels. The reserve margin which produces LOLE equal to the
23 industry standard is set as the target reserve margin.

1 **Q. WHAT IS THE INDUSTRY STANDARD FOR RESOURCE ADEQUACY**
2 **PLANNING?**

3 A. The standard for resource adequacy planning in the United States is to procure
4 sufficient resources to expect to shed firm load less than one day every 10 years
5 (0.1 LOLE).

6 **Q. IS THE TARGET RESERVE MARGIN RECOMMENDATION FROM THE STUDY**
7 **PREPARED BY ASTRAPÉ BASED ON THE SAME INDUSTRY STANDARD AS**
8 **PUBLIC SERVICE'S MOST RECENT RESERVE MARGIN STUDY**
9 **PERFORMED IN 2008?**

10 A. No. In Public Service's most recent reserve margin study performed in 2008, the
11 target reserve margin of 16.3 percent was based on an alternate interpretation of
12 the one day in 10-year loss of load reliability standard. Namely, the prior Public
13 Service study planned to 24 hours of load shed in 10 years which could have
14 occurred over multiple days. The 0.1 LOLE interpretation is defined as a single day
15 with one or more hours of firm load shed in 10 years. The planning target of 24
16 hours of load loss in 10 years is commonly referred to as 2.4 Loss of Load Hours
17 ("LOLH"). The updated Study prepared by Astrapé is based on the interpretation
18 that the one day in 10-year standard is properly represented by 0.1 LOLE.

1 **Q. WHY DOES ASTRAPÉ RECOMMEND CHANGING THE BASIS OF THE**
2 **TARGET RESERVE MARGIN TO THE INDUSTRY STANDARD 0.1 LOLE FROM**
3 **THE 2.4 LOLH THAT WAS USED IN THE COMPANY’S PRIOR PLANNING**
4 **RESERVE MARGIN STUDY?**

5 A. While the industry standard reliability metric in North America of one day of firm
6 load shed in 10 years has very high adoption, some latitude has been taken on its
7 interpretation. The two primary interpretations have been 0.1 LOLE and 2.4 LOLH.
8 The 0.1 LOLE interpretation results in a higher reserve margin and produces a
9 significantly higher level of reliability than those associated with the 2.4 LOLH
10 interpretation. In most systems, firm load shed events have a duration of 2-3 hours
11 which would correspond to 0.2 to 0.3 LOLH per year when using the 0.1 LOLE
12 interpretation. This means 2.4 LOLH interpretation corresponds to an order of
13 magnitude higher frequency of expected firm load shed – shedding firm load every
14 year rather than once in 10 years. Given the reduced reliability associated with
15 the 2.4 LOLH interpretation, we do not believe it to be consistent with the intent of
16 the original one day in 10-year reliability standard. The origins of the 1-in-10
17 standard were from the 1940s and 1950s when probabilistic analysis only
18 considered reliability in the peak hour.¹ Shedding load in the peak hour on one
19 day in 10 years simply cannot be equated with shedding firm load 24 hours in 10
20 years. To further support the utilization of 0.1 LOLE, a partial list of entities that

¹ Source: Calabrese, Giuseppe, "Generating Reserve Capacity Determined by the Probability Method," American Institute of Electrical Engineers, Transactions of the IEEE, vol.66, no.1, pp.1439-1450, Jan. 1947

1 use that interpretation is included in Table KDC-D-2. Attachment KDC-2 to my
2 Direct Testimony includes a table of planning reserve margin references across
3 multiple entities.

4 **Table KDC-D-2: Entities Utilizing 0.1 LOLE**

New York Independent System Operator ("NYISO")	Florida Power and Light
ISO-New England	MISO
PJM	Louisville Gas and Electric
SPP	Southern Company
Duke Energy Carolinas	TVA
Duke Energy Progress	Public Service Company of New Mexico
Duke Energy Florida	California Public Utilities Commission

5 **Q. HOW DID ASTRAPÉ CALCULATE PHYSICAL RELIABILITY FOR A RANGE**
6 **OF TARGET RESERVE MARGINS FOR THE PUBLIC SERVICE SYSTEM?**

7 A. To calculate the necessary reserve margin for the Public Service system, Astrapé
8 utilized its reliability model, SERVM, to perform over 9,500 yearly simulations with
9 one-hour granularity at various reserve margin levels. With each simulation,
10 SERVM calculates multiple physical reliability metrics in order to provide a holistic
11 perspective on the reliability of the Public Service system. Each of the 9,500 yearly
12 simulations was developed through stochastic modeling of the uncertainty of load,
13 renewable generation, economic growth, unit availability, and transmission
14 availability. In addition to the Base Case analysis of study years 2021, 2023, 2026,

1 and 2030, sensitivity analyses were performed to understand the importance of
2 varying assumptions.

3 **Q. PLEASE EXPLAIN THE ELECTRIC MARKET REPRESENTATION OF THE**
4 **STUDY.**

5 A. The Study includes all neighboring utilities that are one transmission connection
6 away from Public Service and have historically delivered power to Public Service
7 during normal operations. This includes the current Joint Dispatch Agreement
8 (“JDA”) neighbors and other neighbors inside and outside the Public Service
9 Balancing Authority Area. The reliability benefits provided by the electrically
10 interconnected neighboring systems were captured in the Study. The market was
11 calibrated in SERVM using historical data to reflect a reasonable representation of
12 the reliability benefits from neighbors due to weather and generator outage
13 diversity.

14 **Q. PLEASE SUMMARIZE THE RECOMMENDED TARGET RESERVE MARGIN**
15 **BASED ON ASTRAPÉ’S ANALYSIS IN THE STUDY.**

16 A. Astrapé recommends a target reserve margin range of 18 percent to 20 percent to
17 adequately ensure compliance with a 0.1 LOLE standard. As initially referenced
18 above in Section I of my Direct Testimony, Table KDC-D-1 is a reproduction of
19 Table ES1. 0.1 LOLE Results from the Study.

1

Table KDC-D-1: LOLE Results

Year	2021	2023	2026	2030
0.1 LOLE Reserve Margin	17.4%	19.3%	19.1%	18.0%

2 **Q. PLEASE EXPLAIN WHY ASTRAPÉ HAS RECOMMENDED A TARGET**
3 **RESERVE MARGIN RANGE FOR YEARS 2021, 2023, 2026, AND 2030.**

4 A. Absent changes to the Public Service load shape and conventional portfolio outage
5 rate, the reserve margin that meets the 0.1 LOLE standard could remain static
6 even as the renewable profile changes. However, given the uncertainties in
7 reliability contributions of renewable resources and in the reliability contributions
8 of neighboring systems, the target reserve margin that achieves 0.1 LOLE cannot
9 be known with precision. Rather than make conservative assumptions and set the
10 target reserve margin at the high end of the range, Astrapé recognizes the
11 reliability outcomes are only marginally different within the range of 18-20 percent
12 and portfolios that achieve reserve margins in this range can be considered
13 compliant with industry standard reliability targets.

14 **Q. WHY ARE THE 2023-2030 TARGET RESERVE MARGINS HIGHER THAN THE**
15 **TARGET RESERVE MARGIN IN 2021?**

16 A. The reason that 2023 through 2030 are higher than 2021 is that on an incremental
17 portfolio basis, the Company's capacity credit (i.e., ELCC) for certain resources is
18 slightly higher than the reliability contributions for those same resources reflected
19 within SERVM. The most significant change in the reserve margin percentage
20 occurs in 2023, when within the Study, one of the Comanche coal units is retired

1 and approximately 1,000 MW of utility scale solar and 300 MW of battery storage
2 are added in the modeling. Between 2023 and 2030, the differences between
3 SERVM's reliability contribution and the Company's ELCC values become smaller
4 and the 0.1 LOLE compliant reserve margin moves closer to the 2021 result.
5 Astrapé reviewed the ELCC analysis performed by Public Service and found the
6 technical approach to be sound. Small differences in renewable profiles and
7 utilization assumptions of energy limited resources contribute to the minor
8 differences in reliability contributions within SERVM simulations, but Astrapé
9 believes both the Public Service analysis and SERVM analysis to be equally
10 plausible outcomes. This means that the reserve margin that meets 0.1 LOLE
11 varies between 17.4-19.3 percent.

12 **Q. DO YOU KNOW HOW PUBLIC SERVICE PLANS TO IMPLEMENT THE**
13 **TARGET RESERVE MARGIN RANGE AND DOES IT MEET THE 0.1 LOLE**
14 **RELIABILITY STANDARD?**

15 A. Public Service has indicated that it intends to acquire long-term generation
16 resources for years 2023-2030 to meet an 18 percent reserve margin through the
17 ERP process. Company witness Mr. James F. Hill discusses the long-term
18 planning reserve margin and Company witness Mr. Jon T. Landrum discusses how
19 the 18 percent long-term planning reserve modeling has been incorporated into
20 the modeling in this proceeding.

21 To the extent additional capacity is needed in years 2023 through 2026
22 above any capacity resources acquired and brought online through the ERP
23 process to meet the 19.3 percent and 19.1 percent levels, for those years, my

1 understanding is Public Service intends to procure that capacity through normal
2 course of business short-term market purchases. Company witness Mr. John T.
3 Welch discusses these short-term reserve margin considerations in more detail in
4 his Direct Testimony.

5 **Q. WHAT ARE THE KEY DRIVERS OF ASTRAPÉ'S RECOMMENDED TARGET**
6 **RESERVE MARGIN?**

7 A. The key drivers of Astrapé's recommended target reserve margin include weather-
8 related load uncertainty, generator outages, operating reserve requirements,
9 market purchase availability, economic load forecast uncertainty, energy limited
10 resource performance uncertainty, and non-dispatchable resource reliability
11 contribution uncertainty.

12 **Q. DOES THE RISK OF BEING UNABLE TO SERVE FIRM LOAD CUSTOMERS**
13 **EXIST ONLY DURING SUMMER PEAK LOAD PERIODS?**

14 A. No. While seasonal peak load forecasts are higher for the summer than winter,
15 load variability is higher in winter, solar and wind capacity provides less reliability
16 value in the winter, and generator performance for these resources is more volatile
17 in the winter. Thus, as the penetration of renewable resources increases, the
18 proportion of modeled winter reliability events rises.

19 **Q. IN ADDITION TO THE BASE CASE, WERE OTHER CASES OR SCENARIOS**
20 **MODELED IN THE STUDY?**

21 A. Yes.

1 **Q. PLEASE DESCRIBE THE SENSITIVITIES THAT WERE SIMULATED IN THE**
2 **STUDY.**

3 A. In addition to the base case scenarios which simulated expected conditions for
4 2021, 2023, 2026, and 2030, sensitivities were run to examine the reserve margin
5 impact of various modeling assumptions. This included a 2021 island sensitivity
6 where Public Service was modeled with no access to external assistance from its
7 neighbors, a 2030 “No Economic Load Forecast Error” sensitivity where the
8 economic load forecast error distribution was removed, a 2030 “No SPP Import”
9 sensitivity where the SPP import across the Lamar DC tie was removed, a 2030
10 “No Four Corners Transmission Import Path” sensitivity where the Four Corners
11 transmission path was removed, a 2030 “Increased Transmission” sensitivity
12 where the Public Service and PacifiCorp East (“PACE”) transmission capability
13 was increased bi-directionally by 200 MW, a second 2030 “Increased
14 Transmission” sensitivity where the Public Service and PACE transmission
15 capability was increased bi-directionally by a further 200 MW to 400 MW, a 2030
16 “Non-Firm Fuel Supply” sensitivity where Plains End I and Plains End II were
17 modeled on forced outage when the temperature was -5°F or below due to an
18 assumed lack of natural gas supply, a 2030 “JDA Market Reliance” sensitivity
19 where Black Hills Energy Corporation (“BHEC”), Colorado Springs Utilities
20 (“CSU”), and Platte River Power Authority (“PRPA”) were removed, and a 2023
21 “Firm Energy Purchase” sensitivity where 250 MW of the JDA assistance was
22 modeled as a firm purchase as opposed to a non-firm purchase. A summary of
23 the impact on the target reserve margin is shown in Table KDC-D-3.

1 **Table KDC-D-3: Sensitivity Impact on Target Reserve Margin**

Sensitivity	Reserve Margin Impact
Island	+9.0%
Remove Economic Forecast Error	-0.5%
Remove Access to SPP Market	+1.6%
Remove Access to Four Corners Market	+1.3%
Plus 200 MW Transmission	-2.5%
Plus 400 MW Transmission	-4.0%
Reduce Firm Fuel Supply	+0.5%
Remove JDA Assistance	+1.3%
Add 250 MW Firm Market Purchase	+4-6%

2 **Q. IS IT INSTRUCTIVE TO COMPARE THE TARGET RESERVE MARGIN RANGE**
3 **RECOMMENDED BY ASTRAPÈ TO RESERVE MARGINS CURRENTLY USED**
4 **IN OTHER REGIONS ACROSS THE INDUSTRY?**

5 A. No. There are several reasons why one must be cautious when attempting to
6 compare reserve margin targets across different regions. Comparing reserve
7 margin targets alone often does not provide significant insight into the expected
8 reliability differences among various regions. The benefits of participating in a
9 market vary significantly. Some regions face reliability risks in different seasons
10 with different load variability implications. Entities have varying forced outage
11 rates. There is also variation in the methods used to calculate reserve margin.
12 The capacity accounting of non-dispatchable resources varies drastically. Some
13 entities include expected non-firm purchases as a resource. Some include
14 emergency actions such as voltage reduction as resources. Some utilize a load
15 forecast that does not represent median peak load conditions. Some back out

1 non-firm loads from loads and resources. Notwithstanding all those caveats, the
2 reserve margin target recommendation by Astrapé is comparable to the reserve
3 margin targets in other regions in North America. For example, Florida utilities
4 utilize a 20 percent reserve margin target;² Southern Company utilities utilize a 25
5 percent reserve margin target;³ TVA uses an 18 percent summer and 25 percent
6 winter reserve margin target;⁴ California is in the process of moving to a 20 percent
7 reserve margin target;⁵ and NYISO (“NYISO”) uses a 20.7 percent reserve margin
8 target.⁶

9 **Q. IN YOUR OPINION, WAS THE STUDY PERFORMED ACCORDING TO**
10 **INDUSTRY BEST PRACTICES?**

11 A. Yes. The Study was performed according to industry best practices. By adopting
12 the recommendations of the Study including determining the reserve margin target
13 using 0.1 LOLE, Public Service’s approach to resource adequacy is in line with
14 industry best practices. The Study performed by Astrapé includes rigorous
15 consideration of the drivers of reliability typically considered in resource adequacy
16 studies including weather-related load uncertainty, economic-related load

²Source: *Duke Energy Florida, LLC Ten-Year Site Plan*, Pages 92-93
<http://www.psc.state.fl.us/Files/PDF/Utilities/Electricgas/TenYearSitePlans/2020/Duke%20Energy%20Florida.pdf>

³ Source: *Alabama Power 2019 Integrated Resource Plan Summary Report Public Version*, Page 3
<https://www.alabamapower.com/content/dam/alabamapower/Our%20Company/How%20We%20Operate/Regulations/Integrated%20Resource%20Plan/IRP.pdf>

⁴Source: *TVA 2019 Integrated Resource Plan Volume I-Final Resource Plan*, Page 36
https://tva-azr-eastus-cdn-ep-tvawcm-prd.azureedge.net/cdn-tvawcma/docs/default-source/default-document-library/site-content/environmental-stewardship/irp/2019-documents/tva-2019-integrated-resource-plan-volume-i-final-resource-plan.pdf?sfvrsn=44251e0a_4

⁵ Source: *Comments of the California Independent System Operator Corporation on Order Instituting Rulemaking Emergency Reliability*, Page 6
<https://docs.cpuc.ca.gov/PublishedDocs/Efile/G000/M353/K226/353226841.PDF>

⁶Source: *New York Control Area Installed Capacity Requirement*, Page 4
<http://www.nysrc.org/PDF/Reports/2021%20IRM%20Study%20Report%20Body%20Final.pdf>

1 uncertainty, planned and forced generator outages, market assistance, operating

2 reserve requirements, and renewable output uncertainty.

3 **Q. DOES THIS CONCLUDE YOUR TESTIMONY?**

4 **A. Yes, it does.**