



**Sodium Sulfur Battery Energy Storage
And Its Potential To Enable Further Integration of Wind
(Wind-to-Battery Project)**

**Xcel Energy Renewable Development Fund
Contract # RD3-12**

J. Himelic, F. Novachek
Xcel Energy

**Final Report
(Milestone 6)**

December 2011

Public Version

*Project funding provided by customers of Xcel Energy through a grant from the
Renewable Development Fund.*

Contacts and Acknowledgements

This report was prepared primarily by the Strategic Technologies Department and the Portfolio Strategy and Business Development Department at Xcel Energy. General questions concerning the report can be directed to:

Frank Novachek, Project Director

303-294-2410
1800 Larimer Street
Denver, CO 80202

Jim Himelic, Project Analyst

303-571-7508
1800 Larimer St.
Denver, CO 80202

Additional persons and organizations that contributed significantly to the report include:

- ☐ Nancy Pellowski, Xcel Energy
- ☐ Liam Noailles, Xcel Energy
- ☐ Dave Porter, S&C Electric
- ☐ Abe Hiroyuki, NGK Insulators
- ☐ Jeremy Davis, GridPoint
- ☐ Mike Gregerson and Rolf Nordstrom, Great Plains Institute
- ☐ Brad Lutz, National Renewable Energy Laboratory

LEGAL NOTICE

THIS REPORT WAS PREPARED AS A RESULT OF WORK SPONSORED BY PROJECT FUNDING PROVIDED BY CUSTOMERS OF XCEL ENERGY THROUGH A GRANT FROM THE 100% RATEPAYER FINANCED RENEWABLE DEVELOPMENT FUND ADMINISTERED THROUGH THE NORTHERN STATES POWER COMPANY, A MINNESOTA CORPORATION.

Note: Information that is protected by the Confidentiality Agreements with NGK and S&C Electric is blacked out in the public version.

Table of Contents

Executive Summary	5
Project Overview	10
Project Description	10
Project Objectives	11
Modes of Operation	11
Analysis of Data By Mode of Operation	12
Analysis Approach.....	12
Actual and Effective Wind Output	12
Basic Generation-Storage (GS)	13
<i>Introduction.....</i>	<i>13</i>
<i>Theory</i>	<i>13</i>
<i>Performance Data'</i>	<i>15</i>
<i>Conclusions.....</i>	<i>24</i>
Economic Dispatch (ED)	31
<i>Introduction.....</i>	<i>31</i>
<i>Theory</i>	<i>31</i>
<i>Performance Data.....</i>	<i>31</i>
<i>Conclusions.....</i>	<i>36</i>
<i>Supplemental Information for ED Mode.....</i>	<i>38</i>
Frequency Regulation	40
<i>Introduction.....</i>	<i>40</i>
<i>Theory</i>	<i>40</i>
<i>Performance Data.....</i>	<i>41</i>
<i>Conclusions.....</i>	<i>47</i>
Wind Smoothing	48
<i>Introduction.....</i>	<i>48</i>
<i>Theory</i>	<i>48</i>
<i>Performance Data.....</i>	<i>49</i>
<i>Conclusions.....</i>	<i>56</i>
Dispatched Wind Leveling	60
<i>Introduction.....</i>	<i>60</i>
<i>Theory</i>	<i>60</i>
<i>Performance Data.....</i>	<i>61</i>
<i>Conclusions.....</i>	<i>66</i>
DESS Operation Universal to All Modes of Operation.....	67
General Conclusions and Lessons Learned.....	68
Public Policy Considerations	77
Policy Work Group Approach and Process	77
<i>Work Group Objective</i>	<i>77</i>
<i>Key Assumptions For Analysis.....</i>	<i>77</i>
<i>Principles and Guidelines.....</i>	<i>78</i>
<i>Policy Work Group Participants</i>	<i>79</i>
Key Policy Considerations and Recommendations	79
<i>FERC and MISO Policy Areas.....</i>	<i>79</i>
<i>Environmental/Reliability Policy Areas.....</i>	<i>80</i>

<i>Recent Policy Developments</i>	81
<i>Conclusions and Further Research and Investigation</i>	82
Supplemental Information - System and Technology Overview	83
Sodium Sulfur (NaS) Energy Storage Technology.....	83
<i>Introduction</i>	83
<i>Cell Construction and Electrochemistry</i>	84
<i>Module and Unit Construction</i>	86
<i>Thermal Considerations</i>	87
<i>NaS SOC Calculation and Battery Efficiency</i>	90
<i>NaS Battery Durability</i>	90
<i>Project-Specific Battery Details</i>	94
<i>Maintenance Procedures</i>	95
Power conversion system.....	96
<i>Introduction</i>	96
<i>Physical Layout</i>	97
<i>Physical Operating Principles and Electrical Layout</i>	97
<i>PCS Alarms</i>	99
<i>PCS HMI</i>	100
<i>PCS Modes of Operation</i>	100
<i>PCS Server-Client Designation</i>	101
<i>Maintenance and System Lifetime</i>	101
<i>DESS Overall System Efficiency</i>	101
<i>PCS Efficiency</i>	103
DESS System Architecture.....	105
<i>Introduction</i>	105
<i>Functional Requirements</i>	105
<i>Overview</i>	105
<i>GridPoint</i>	107
<i>System Context</i>	108
<i>Basic GS</i>	110
<i>Wind Smoothing</i>	111
<i>Wind Leveling</i>	112
<i>Frequency Regulation</i>	113
<i>Economic Dispatch</i>	114
References	115
List of Acronyms	116
Table of Figures	117
Table of Tables	118
Appendix 1: University of Minnesota Final Project Report	

Executive Summary

As the nation's number one wind power provider and number five solar energy provider, Xcel Energy has demonstrated its renewable energy leadership in the utility industry. Xcel Energy continues to aggressively pursue wind and other types of renewable generation technologies in line with a strategic vision of a clean energy future.

However, as more wind capacity comes online and meets a greater amount of customers' load obligation, system impacts will become consequential and have to be addressed. With a large penetration of wind already in the Xcel Energy balancing footprint and plans to add more in the near future, Xcel Energy is seeking innovative ways to integrate renewable energy. One potential solution is large-scale electrochemical energy storage.

Xcel Energy is conducting the Wind-to-Battery (W2B) Project to evaluate the overall effectiveness of sodium sulfur (NaS) battery technology in regards to its ability to facilitate the integration of wind energy onto the grid. As part of this demonstration project, Xcel Energy is investigating the ability of the technology to provide system benefits, the cost-effectiveness of the storage device, and methods and procedures to evaluate other types of energy storage technologies in the future. Through this small-scale demonstration project, Xcel Energy can evaluate energy storage technology at a modest level of investment and customer impact. By doing so, the company will promote the future deployment of only proven technologies that meet or exceed cost, reliability, and environmental requirements.

This report summarizes the testing phase of the project, which consisted of a technical evaluation of the battery-based Distributed Energy Storage System (DESS) and grid-related performance data under multiple modes of operation. Project analysts have completed initial testing of the DESS for all modes of operation and collected system performance data accordingly. From analyses of the data, Xcel Energy has assessed the effectiveness of the technology for each mode of operation and gained a better understanding of the general operating characteristics of the technology. Overall, the battery met expectations by performing successfully in all modes tested.

This report also contains a discussion of policy issues identified by a work group convened by the Great Plains Institute, including (but not limited to): the potential need for MISO tariffs specific to energy storage resources; the need to create a separate FERC asset class for storage, in addition to the generation and transmission asset classes; and the potential additional value for the very fast response energy storage can provide to system regulation signals. Also included is a comprehensive technology overview for the NaS Battery, the PCS, and the overall DESS System Architecture, which may be useful in understanding the testing process and results.

Project Objectives

Along with external project partners, Xcel Energy conducted its W2B Project to evaluate the ability of utility-grade, large-scale electrochemical storage to provide system benefits specific to wind (from the perspective of both a wind farm owner and a balancing authority) and the bulk electric grid in general.

The objectives for the W2B Project are the following:

- ☐ Evaluate the ability of large-scale battery storage technology to effectively firm wind energy, enabling a shift of wind-generated energy from off-peak to on-peak availability;

- ❑ Evaluate the ability of the DESS system to reduce the need for the utility to compensate for the variability and uncertainty impacts of wind against other grid balancing procedures;
- ❑ Evaluate the potential for battery-storage technology to provide ancillary service support to the grid;
- ❑ Assess the obtainable value of storage in the Midwest ISO (MISO) market for current wind penetration scenarios; and
- ❑ Assess the overall operating characteristics of the DESS system, including impacts on system performance as a function of operational mode and external weather conditions.

Usefulness of the Information Gained

Xcel Energy is grateful to the Renewable Development Fund for supporting our Wind-To-Battery energy storage demonstration. The Company, the utility industry, the wind energy industry, and the energy storage industry (nationally and internationally) have all benefited from the information gained from this project

- ❑ We have proven that this type of storage technology can perform functions that can help us manage the variability of wind energy on our operating system.
- ❑ We have gained significant knowledge & insights into the value of energy storage as wind integration tool for the utility, wind providers, and the grid, including:
 - The potential for reduced baseload cycling costs due to wind variability
 - The capability to use battery for multiple integration functions simultaneously
 - The identification of the key energy storage system functions of value to the grid and its utility customers, ultimately resulting in better service at lower costs
 - Methods for determining how much and where to site energy storage on the grid to maximize its value to the electric system.
- ❑ Our learnings have reached the world. We have shared our learnings with industry, governments, and academia through over 30 speaking engagements, three published reports and countless outside inquiries.
 - We contributed input to the utility and energy storage industries on utility system and customer needs, including functionality and costs.
 - We participated in increased collaboration and sharing between energy storage users, federal and state policy-makers, and the energy storage industry, ultimately enriching the conversations around energy storage and its potential for supporting the integration of large penetrations of renewable resources onto utility grids.
- ❑ We have used the results of this demonstration and testing to identify additional applications for energy storage on utility distribution systems and obtained regulatory support for two additional energy storage projects that will be used to demonstrate its potential for managing the variability & uncertainty of solar PV.

Benefits to Funders

Xcel Energy's funders and customers have benefited from:

- ❑ A better understanding of the ways in which the increased flexibility (because of being both a dispatchable load and a dispatchable generator) energy storage can have, over that of traditional gas peaking resources, may provide overall system cost benefits, once energy storage prices become competitive with traditional peaking resources.
- ❑ The Company gaining an understanding of how to determine in what price range energy storage deployments will be cost beneficial to our customers and using that information to provide input to the energy storage industry as to the costs that will likely be needed to be cost beneficial to utility customers and potentially deployed more widely on a utility grid. Generally speaking, we have found that bulk energy storage assets (with greater than four hours of storage) must be competitive in price to traditional peaking generation on the system.
- ❑ The commercial use of the Wind-To-Battery system providing fast-response, ancillary services to the MISO after testing.
- ❑ The Company's expertise in specifying the essential energy storage system functions of value to the grid and its utility customers, ultimately resulting in better service at lower costs.
- ❑ The use of the Wind-To-Battery system as a means to validate system modeling work currently being done by the MISO.
- ❑ The potential use of energy storage on distribution system to help manage potential grid issues related to system reliability and performance expected with increased penetrations of distributed generation, including the potential for using the same storage resources to integrate both off-peak wind resources and distributed solar PV resources.

The potential for affordable energy storage systems in next five years is real, and because of this demonstration and associated analyses, the Company is in a much better position to know when it's right for our customers.

General Conclusions and Lessons Learned

The following is a list of the general conclusions and lessons learned related to the DESS as a whole, based on the tests conducted and the related testing conditions:

- ❑ The overall efficiency of the DESS, accounting for the auxiliary energy requirements, displayed considerable variation as a function of mode of operation, ranging from 67.6% to 78.9%.
- ❑ The efficiency of the DESS, not accounting for the auxiliary energy requirements, displayed less variation as a function of mode of operation, ranging from 85.1% to 91.6%.
- ❑ The DESS never exceeded more than one discharge cycle in any 24-hour period for any mode of operation.
- ❑ The DESS mileage varied significantly depending on the mode of operation. Based on the mileage metric, the Frequency Regulation mode of operation was the most aggressive mode while the Economic Dispatch mode was the least aggressive.

Key Findings From The Main Testing Modes

Basic Generation Storage (Time Shifting) was tested by scheduling the battery to discharge during defined on-peak periods and charge during defined off-peak periods at a rate that was

proportional and coincident with the power output from the wind farm. Overall, the DESS performed as expected for the majority of scenarios tested for both the wind-only and wind-grid charging variations. Key findings:

- During the 2009/10 testing period, the testing determined that the 1 MW wind farm scenario (for the 1 MW, 7 MWh battery) was incapable of fully charging the battery during the allowed charging window of 8.5 hours, while the 10 MW wind farm scenario generated more wind energy than needed.
- The University of Minnesota investigated this further in 2010/11 and determined that the optimal ratio of storage to wind for the sole purpose of shifting wind-only generation is 200 – 400 kW storage per MW installed wind, under the obligation that storage should be offered as a generating resource for 6 peak load hours everyday.

This information will prove helpful for future energy storage projects when determining the appropriate size of energy storage as a function of the size of the wind system it will support.

Economic Dispatch was tested whereby the DESS followed set-points based on an algorithm that uses forward and spot energy prices in the MISO market along with settings from the user. Although the battery was never officially offered into the MISO market in this mode, project analysts estimated the settlements results. The DESS performed as expected in this mode of operation. Key findings:

- Although the arbitrage potential was limited due to market conditions, project analysts feel that improved results are possible by optimizing the control algorithms. Moreover, project analysts also recommend performing additional testing using different market nodes and pricing information from previous years to better estimate potential financial returns over an extended period of time at various physical locations.
- The University of Minnesota analyzed this further in 2011, using 2010 data, and developed a method for screening nodes in the NSP system. As one might expect, the value of energy storage will vary by location on the system grid. They found that the variance, range and absolute error of MISO's real-time (RT) prices, and the variance of the day-ahead (DA) prices at each point on the grid are good predictors of the total revenue one could expect from an energy storage device with characteristics of the sodium-sulfur battery system tested.

This information will be helpful for designing control systems for energy storage projects where arbitrage operations are the primary focus.

Frequency Regulation was tested whereby the DESS followed a frequency regulation signal derived from changes in the Area Control Error (ACE) for the MISO market. Even with the frequent temporary system alarms, the DESS performed well in this mode. Key findings:

- On a continuous basis, the device followed the rapidly changing set-points issued by the NSP Energy Management System (EMS) in a timely and accurate manner and displayed excellent ramping capabilities. Project analysts recommend additional testing for this mode over time to determine if any long-term damage is incurred by the batteries as a result of the rapid, frequent charging and discharging of the battery.
- The University of Minnesota investigated the economics of the offering the battery in the MISO ancillary services market (ASM) and found that under the current market conditions, for this particular energy storage system, it could be said that offering the battery in MISO

ASM has the potential to make money for the investor and while providing meaningful service to the system.

This information will establish a framework for future energy storage projects to evaluate the value of providing ancillary services to the MISO market.

Wind Smoothing (Ramp Rate Control) was tested by varying the charging and discharging rates of the battery based on the output of the effective wind farm. That is, we scaled the power output signal from the wind farm to simulate different wind farm sizes (or “effective” wind farms) and then varied the charging and discharging rates of the battery system to determine the effectiveness of the battery system in limiting the rate of change of the sum of the power output from “effective” wind farms and the battery system combined to specified levels. The test results were mixed as a result of errors in the PCS source code, and additional testing will be required once fixed. Key findings:

- The tests indicate that the DESS is able to effectively limit the total power output rate of change of the sum of the power output from “effective” wind farms and the battery system combined in the 1 MW wind farm scenario, but the rate of change was too great for the DESS to handle in the 10 MW wind farm scenario.
- The University of Minnesota analyzed this further and determined that the optimal storage to wind ratio for generation shifting (i.e., 200 – 400 kW storage per MW installed wind) would also be suitable for limiting the ramp rate of wind generation. Moreover, these two tasks could be combined for maximum benefit to the system.

Prior to the testing, the assumption was that capturing the value from time-shift and smoothing applications would likely be mutually exclusive. These findings suggest that they could be additive, thereby increasing the value created by an energy storage project in a similar configuration.

Wind Leveling (Steady Output Control) was tested by varying the DESS charging and discharging operations to minimize the difference between the expected and actual power output for the wind facility. Overall, the DESS performed well for the 1 MW and 5 MW scenarios. Key findings:

- For all the scenarios, the DESS performed as expected, responding to changes in the output from the effective wind farm rapidly and accurately.
- Ongoing evaluation of battery system performance under actual wind generation conditions over the years will continue to increase our confidence in understanding the battery system’s capabilities in this regard. This may provide insights enabling Xcel Energy to identify additional synergistic benefits that may be available when integrating wind energy by incorporating new technology into the company’s daily business operations.

Since this mode of operation is effectively the ultimate smoothing function (i.e., zero ramp rate), the significance of these findings are on par with those of the smoothing function. The need for a flat output from a wind farm/energy storage system combined is not likely to be critical in a flexible grid like MISO.

Project Overview

Project Description

A 1 MW, 7.2 MWh NaS battery purchased from NGK Insulators Ltd. (NGK), a Japanese firm involved in the manufacture and sale of power-related equipment, was installed near the 11.5 MW Minwind Energy LLC (MWD) wind facility in Luverne, MN. The battery is located at the newly constructed “W2B Substation” adjacent to both Xcel Energy’s existing Rock County (RCY) Substation and MWD’s substation.



Figure 1: Battery Photo

Next to the battery, S&C Electric (S&C), a Chicago-based company that provides equipment and services for electric power systems, designed, built and installed a stand-alone power conversion system (PCS), which includes a local monitoring, data collection, control, and communication system. Herein, the combined NaS-PCS system is referred to as the Distributed Energy Storage System (DESS). S&C also installed a 175 kW backup generator at the NaS Substation to provide backup power for the battery heaters in the event that grid power was lost at the site.

GridPoint Inc., a firm involved in smart grid technology, provided a remote two-way communications and control system for system integration, remote monitoring and control, and data access. GridPoint’s system enabled the battery to respond to Automatic Generation Control (AGC) and market-driven control set-points.

Project participants selected the NaS technology for multiple reasons. The battery has a high energy storage capacity, can handle a large number of charge-discharge cycles, is capable of dynamic operation, and has demonstrated commercial performance and availability. In addition, the technology is capable of large scale deployment in the future.

Xcel Energy selected the MWD facility for several reasons. First, the company thought it was important to locate the battery next to a wind farm to avoid any potential latency issues when trying to relay output data from the turbines to battery when operating in a “wind-coupled” mode of operation. Furthermore, the company wanted a wind farm with an installed capacity in the range of 10 MW so as not to overwhelm the 1 MW battery. Also, because Xcel Energy owns a substation at the site, the project team was able to minimize land purchase/usage fees. Finally, expressing interest to participate in the project as a partner, MWD offered the use of its

interconnection transformer to the transmission system. By using the MWD transformer, Xcel Energy avoided the need to purchase and register an additional transformer.

Project Objectives

Along with external project partners, Xcel Energy is conducting its W2B Project to evaluate the ability of utility-grade, large-scale electrochemical storage to provide system benefits specific to wind (from the perspective of both a wind farm owner and a balancing authority) and the bulk electric grid in general.

The objectives for the W2B Project are the following:

- ☐ Evaluate the ability of large-scale battery storage technology to effectively firm wind energy, enabling a shift of wind-generated energy from off-peak to on-peak availability;
- ☐ Evaluate the ability of the DESS system to reduce the need for the utility to compensate for the variability and uncertainty impacts of wind against other grid balancing procedures;
- ☐ Evaluate the potential for battery-storage technology to provide ancillary service support to the grid;
- ☐ Assess the obtainable value of storage in the Midwest ISO (MISO) market for current wind penetration scenarios; and
- ☐ Assess the overall operating characteristics of the DESS system, including impacts on system performance as a function of operational mode and external weather conditions.

Modes of Operation

To meet these objectives, the W2B project analysis team evaluated the DESS under multiple modes of operation (see table below) to obtain a thorough understanding of the system's range of capabilities.

Table 1: Modes of Operation

Mode of Operation	Description
Basic Generation Storage (<i>Time Shifting</i>)	The battery discharges during defined on-peak periods and charges during defined off-peak periods at a rate that is proportional and coincident with the power output from the wind farm.
Economic Dispatch	The battery follows a signal based on market prices to capture arbitrage benefits in forward and spot energy markets.
Frequency Regulation	The battery follows a frequency regulation signal both as a load and a generator.
Wind Smoothing (<i>Ramp Rate Control</i>)	The battery is used to reduce the variability of wind power by charging and discharging accordingly to limit the ramping rate of a wind farm.
Wind Leveling (<i>Steady Output Control</i>)	The battery is used to reduce the uncertainty of wind power by charging and discharging accordingly to limit the deviation between scheduled and actual power output from a wind farm.

Analysis of Data By Mode of Operation

Analysis Approach


For the analysis phase of the project, project analysts technically evaluated DESS and grid-related performance data for each mode of operation. Xcel Energy analyzed the data to better understand the general operating characteristics of the technology and to evaluate its effectiveness in meeting the desired functions.

The next and final phase of the project will be to use the data collected to date, as well as any additional tests deemed necessary by the W2B analytics team, to complete the evaluation of the value propositions contained in the project objectives, including an assessment on the ability of the DESS to facilitate the integration of larger penetrations of wind energy on the grid and its cost effectiveness.

Actual and Effective Wind Output

For the W2B Project, Xcel Energy was interested in evaluating different ratios of installed wind capacity to storage capacity to effectively determine the appropriate ratio for each mode of operation. As part of the design of the PCS logic, a user was able to specify a wind scaling factor to specify the amount of wind power the PCS was effectively exposed to. The PCS logic dictated its command decisions based on the amount of effective wind present, which was simply the original power output from the wind farm times the user-specified scaling factor, and could range from 1-100%. For the W2B Project, researchers varied the scaling factor to make the 11.55 MW Minwind facility appear as if it were a 1 MW (scaling factor of 8.7%), 5 MW (scaling factor 43.3%), and 10 MW wind farm (scaling factor of 86.7%).

Figure 2 graphically displays the difference between the actual and effective amount of wind for various scaling factors over the course of a 24 hour period¹. From 00:00 to 7:59, the scaling



factor was 86.7%. From 08:00 to 15:59, the scaling factor was 43.3%. From 16:00 to 23:59, the scaling factor was 8.7%. As expected, the PCS was exposed to less magnitude and variance in power output from the wind farm for smaller scaling factors compared to the output from the full wind farm.

Figure 2: Power Generation from the Actual and Effective Wind Farms

¹ For all figures herein, negative power represents power going from the wind facility / DESS to the grid, whereas positive power represents power going from the grid to the wind facility / DESS.

Basic Generation-Storage (GS)

Introduction

One of the value propositions in the W2B Test Plan is to evaluate the ability of large-scale battery storage technology to time shift a variable generation resource. Project analysts used the Basic GS mode to test this proposition by scheduling the battery to discharge during defined on-peak periods and charge during defined off-peak periods at a rate that was proportional and coincident with the power output from the wind farm. Project analysts tested the battery in this mode over a period of six weeks for varying installed wind capacity scenarios, charging options, and discharge profiles.

Theory

One of the objectives in this mode was to gauge the ability of the battery to discharge during the defined on-peak demand periods using one of NGK's reference duty cycles. For testing purposes, the peak demand hour was based on the hourly averages of 2009 obligation load data for Northern States Power (NSP)².

Table 2 lists the monthly average peak load hour for NSP, and Figure 3 on the next page shows the monthly average daily load profiles.

Table 2: 2009 Monthly Peak Demand Hours

Month	Peak Demand Hour (CST)
January	18:00
February	18:00
March	09:00
April	10:00
May	11:00
June	13:00
July	14:00
August	14:00
September	13:00
October	18:00
November	17:00
December	17:00

To ensure that the discharge profile remains centered on the peak demand hour, regardless of the initial State of Charge (SOC), the PCS modifies the scheduled discharge duration by delaying the start time and expediting the end time accordingly, depending on the amount of energy available for discharge. The PCS adheres to all the operating constraints placed on the battery by the NGK battery controller.

The Basic GS mode has two variations of charging: wind-only charging and wind-grid charging. For both variations, charging is only allowed during the user-defined charging period, which is specified by a start and end time.

² Does not account for obligation load Xcel Energy has in balancing authorities outside of NSP.




Figure 3: 2009 Daily Average NSP Obligation Load Profile

When charging in the wind-only charging option, the DESS begins to charge at a rate that is proportional to the output of the effective wind farm. If the output of the effective wind farm is less than the maximum allowed charge rate, the DESS charges on a one-to-one basis with the amount of wind power available. However, if the output of the effective wind farm exceeds the maximum allowed charge rate, the PCS charges the storage device at its maximum allowed rate (1,100 kW) with the remaining wind power spilling over onto the grid³. Charging terminates either when the end time of the allowed charging window is reached or the battery receives a full charge. A fully-charged battery is determined by the “cut-off voltage”, which is calculated by the NGK battery controller. Because the battery is not able to charge by drawing electricity from the grid, the battery may or may not attain a full recharge before its next discharge period.

Charging under the wind-grid option is similar to the wind-only variation except that the battery is capable of charging at its maximum allowed rate, regardless of the output of the effective wind farm. The battery begins to charge at its maximum allowed rate if the battery has still not reached a SOC of 100% before the time specified by the “Grid Allowed Charging Hour” set-point. The storage device continues to charge at its maximum allowed charge rate until it either reaches a full charge state or the allowed charging window expires. Depending on the value entered for the Grid Allowed Charging Hour set-point and the duration of the allowed charging window, the battery may or may not attain a full recharge before its next discharge period.

³ Project analysts acknowledge that it is not physically possible to designate electrons from a particular generation facility for a given load. However, this report makes the assumption that when the charging rate is identical to the output of the scaled farm, the battery is charging on wind energy. Conversely, when the charge rate is greater than the output of the scaled farm, the battery is charging on grid energy.

For both variations of the Basic GS charging options, the NGK battery controller gradually reduces the maximum allowed charge rate for the battery as it approaches a full SOC. NGK implements this charging constraint to reduce the risk of damaging any of the battery modules by overcharging them. Table 3 below lists the approximate SOC thresholds and the respective maximum allowed charging rates. Before the battery can charge again after achieving a full charge state, the SOC must first drop below 93%. The PCS still honors all charging and discharge constraints for the storage device while in this mode.

Table 3: Maximum Allowed Charge Rates

State of Charge (%)	Maximum Allowed Charge Rate (kW)
$x < \sim 92.5$	1,100
$\sim 92.5 \leq x < \sim 93.5$	962
$\sim 93.5 \leq x < \sim 94.7$	825
$\sim 94.7 \leq x < \sim 95.4$	687
$\sim 95.4 \leq x < \sim 97.1$	550
$\sim 97.1 \leq x < \sim 97.6$	275
$\sim 97.6 \leq x < \sim 99.9$	137
$x > \sim 99.9$	0

Performance Data^{4,5}

Project analysts tested the battery in the Basic GS mode of operation over a period of six weeks while collecting data at a resolution of one minute. Researchers tested the wind-only charge mode and wind-grid charge mode each for a period of three weeks. For each mode, analysts collected approximately 5-days of data for each installed wind capacity scenario (i.e., 1, 5, and 10 MW). Project researchers also tested multiple NGK standard discharge profiles (as shown on page 91). The following is a description of a portion of the testing data analyzed by project analysts, starting first with the discharging operation and then moving on to the charging operation. A sampling of testing data can be found in the tables on page 26. The entire dataset can be found in Table 8, Table 9, and Table 10 beginning on page 27.

Figure 4 depicts the operation of the DESS, its SOC, the output from the effective wind farm, and the combined output of the DESS and the effective wind farm (i.e. the net output that the grid sees at the point of interconnection, herein labeled “Total”) for 12/11/2009. The selected NGK standard discharge profile for this particular operating day was profile #1. With a peak demand hour of 15:00 and a SOC of 100%, the battery discharged at a constant rate of approximately 1,000 kW for 6 hours from 12:00 to 18:00, as expected. The SOC at the end of the discharge period was 23.3%.

⁴ Although, Xcel Energy performed a preliminary investigation of this mode of operation, the University of Minnesota is contracted to provide a more detailed analysis. Xcel Energy is scheduled to receive the final deliverable for that analysis in June 2011.

⁵ Because of a software glitch in the PCS logic, the initial times selected for peak demand hours and allowed charging windows are not those specified in Table 2. However, the analysis to be conducted by the U of Mn is expected to use these values.




Figure 4: Basic GS, Discharge Profile #1, Fully Charged (12/11)

Figure 5 displays system performance data for discharge profile #1 for a partially-charged battery. At the completion of the previous charging session (partly shown in the figure) the SOC of the battery was 44.5%, which was not capable of providing the energy required by the scheduled profile. Therefore, the PCS delayed the start of the discharge by 1 hour and 45 minutes and started to discharge at 1,000 kW at 13:45. After discharging for approximately 2.5 hours at a constant 1,000 kW, the DESS stopped discharging at 16:14. By delaying the discharge start time and expediting the discharge end time, the DESS was still able to discharge during the defined peak demand period. The SOC at the end of the discharge period was 12.4%.




Figure 5: Basic GS, Discharge Profile #1, Partially Charged (12/15)

Researchers also tested the NGK standard discharge profile #4 during the Basic GS testing period. Figure 6 displays the data for a sample discharge period on 1/8/2010. The user specified peak demand hours of 10:00 and 15:00 for the individual discharge periods for this profile. As expected, with a fully-charged battery, the PCS discharged the battery for 3.2 hours at a constant rate of approximately 1,000 kW for each scheduled discharge period. The DESS discharged 3.25 MWh in the first discharge period and 3.26 MWh in the second. The SOC at the completion of the second discharge period was 16.9%.




Figure 6: Basic GS Discharge Profile #4, Fully-Charged (1/8)

The combined output of the DESS and MWD facility cannot exceed 12 MW at the point of grid interconnection due to contractual reasons between MWD and MISO. Thus, when the output of the wind farm is above 11 MW while the DESS is discharging, the PCS curtails the output of the battery accordingly to not exceed this threshold. Figure 7 is an example of a when this occurs during the Basic GS mode of operation for discharge profile #1. As shown in the figure, the wind farm was producing power at or near its rated capacity coincident to the scheduled discharge period for the DESS. As a result, the PCS limited the battery discharge rate between 275-1,000 kW throughout the discharge period. Thus, the storage device was only able to discharge 4.87 MWh of energy during the discharge period rather than the expected 6 MWh. The SOC at the end of the discharge period was 40%.




Figure 7: Basic GS, Discharge Profile #1, Actual Wind Farm Output (12/25)

All of the NGK standard discharge profiles are scheduled to have a final SOC at or near 10% upon completing its complete discharge schedule. However, as illustrated by the figures and Table 8, the DESS is currently capable of discharging more than the scheduled energy amount. Because the performance of the NaS modules gradually degrades over time, NGK conservatively estimated the discharge duration times using end-of-life conditions.

For each discharge period, project analysts normalized the amount of energy discharged with the percent change in SOC. For example, on 12/11/2009 the DESS discharged 6.04 MWh as it went from an initial SOC of 99.6% to a final SOC 23.3%. Thus, the normalized discharged energy for this particular day was 7.9 MWh/%⁶. Figure 8 and Figure 9 display this calculated value for each discharge period during the Basic GS testing period for profiles #1 and #5, respectively.

As illustrated in both figures, there is considerable variability in the results from one day to the next. Furthermore, Figure 9 displays additional interesting behavior that was not originally accounted for by any of the project participants. In the figure, the “I” data series represents the first discharge period for profile #4, whereas the “II” data series represents the second. From the figure, the normalized discharge energy is dependent on the SOC range it spans while discharging. By definition, the II data series is always over a lower SOC range than the I data series since it is the second discharge period. Therefore, it appears that the battery delivers more discharge energy per percent change in SOC for higher states of charge than lower states of charge. After discussions with NGK, project analysts attribute the variability in these results to inaccuracies in current measurements by the NGK battery controller as well as the manner in which NGK calculates SOC (i.e. using Ah discharged rather than kWh discharged).

⁶ $6.04 \div (99.6\% - 23.3\%)$




Figure 8: Normalized Discharge Energy Based on Change in State of Charge (Profile #1)




Figure 9: Normalized Discharge Energy Based on Change in State of Charge (Profile #4)

In general, the PCS performed as expected during the discharging operation of the Basic GS mode of operation, but project analysts did uncover some unexpected operation. For any partial discharge period, project analysts expected the final SOC to be 10% (the minimum allowed SOC value). However, as shown in Table 8 this was not always the case. According to S&C, the final SOC value did not exactly equal 10 % due to (a) higher than expected efficiencies in the PCS⁷ and (b) NGK calculating SOC based on Ahs rather than kWhs. Furthermore, for profile #4, the PCS did not accurately calculate the start and end times for partial discharge periods, even after accounting for the high PCS efficiency and any inaccuracies in the SOC measurement. Notified by Xcel Energy of the error, S&C will account for it in the updated software to be installed by Q3 2010.

Figure 10 displays system operation data while the DESS is charging under the wind-only mode during the evening of 12/24/2009 and 12/25/2009. The capacity of the effective wind farm for this charging period was 10 MW, and the allowed charging period was from 22:30 to 07:00. At 22:30, with a SOC of 24.6%, the battery began to charge at its maximum allowed charge rate and continued to do so throughout the entire charging period because the output of the effective wind farm exceeded 1,100 kW. As a result, the only difference between the Total and Effective Wind Farm data series was an offset of 1,100 kW. At 04:27 at a SOC of 93.6%, the PCS began to reduce the maximum allowed charging rate of the battery according to the step-down charging algorithm controlled by the NGK battery controller. At 05:51, the battery achieved a SOC of 100% and remained idle for the remaining portion of the allowed charging window. During the charging period, the DESS consumed 7.11 MWh of energy while the effective wind farm generated nearly 72 MWh.




Figure 10: Basic GS: Wind Only Charging Operation (12/24-12/25)

⁷ For discharging, S&C assumed a constant efficiency of 95% for the PCS; however, it appears that the PCS is ~96-97% efficient.

Figure 11 displays system performance data while the unit charges under the wind-only option for the late evening and early morning hours of 12/11/2009 and 12/12/2009. For this charging period, the allowed charging period remained from 22:30 to 7:00, but the capacity of the effective wind farm was 1 MW. At 22:30, with a SOC of 23.3%, the battery began charging at the same rate at which the effective wind farm generated power. Because the effective wind farm output was less than 1,100 kW, the combined output of the storage device and the wind farm was zero, resulting in no net energy being injected into the grid. However, the effective wind farm was not able to generate enough energy to fully charge the battery during the defined charging period. Overall, the effective wind farm generated approximately 3.05 MWh, and the DESS consumed 3.07 MWh during the charging period. The SOC at the completion of the charge period was 57.3%.




Figure 11 Basic GS: Wind-Only Charging Operation (12/11-12/12)

Figure 12 displays the DESS while charging under the wind-grid charging option on the evening of 12/31 and 1/1. Again, the allowed charging period was from 22:30 to 7:00 the next day. At 22:30, with an initial SOC of 16.8%, the battery began charging at a one-to-one rate with the output of the effective wind farm, as the output of the effective wind farm was below 1,100 kW. However, once the time specified by the Grid-Enabled Charging Hour set-point (02:45) was reached, the DESS charged at its maximum allowed rate. The battery continued to charge at this rate until the allowed charging period expired, ending with a SOC of 78.5%. While the DESS charged at 1,100 kW, the combined output of the DESS and effective wind farm acted as a net load to the grid. During the charging period, the total amount of energy generated from the effective farm was 2.55 MWh, whereas the DESS consumed 5.79 MWh. However, during the grid-enabled portion of the charging period, the effective wind farm generated 1.39 MWh and the DESS consumed 4.60 MWh.





Figure 12: Basic GS: Wind-Grid Charging Operation (12/30-12/31)

Project researchers evaluated the amount of charging energy available for the DESS to help identify an appropriate ratio of wind to storage capacity for the application of charging from a wind facility. Figure 13 displays the average amount of charge energy the DESS consumed during the allowed charging period for each wind scenario for both the wind-only and wind-grid charging options. For the 1 MW scenario, the battery was never able to receive a full charge. Even though in the wind-only scenario 5 MW of wind performed only slightly better than 1 MW of wind, in the wind-grid scenario the battery attained a full charge for 5 of the 7 days, with the majority of charging energy coming from the wind farm. For the 10 MW scenario, the battery



was able to obtain a near-full or full charge more than half of the time for both charging variations. Because there was already sufficient energy to charge the battery from the wind farm for most instances, the ability to charge from the grid did not result in significant increases in final SOC values.

Figure 13: Average DESS Charge Energy for Basic GS Mode of Operation

Similar to the discharge operation, project analysts normalized the amount of charge energy with the percent change in SOC for each charging period. Figure 14 displays the calculated values for each charging period for both charging modes. Similar to the discharging data, the charging data exhibits variability in the results from one day to the next but does so at a slightly less degree of variance. Again, project analysts suspect that the primary source of variability in the results is inaccuracies in NGK's calculation of the SOC.





Figure 14: Normalized Charge Energy Based on Change in State of Charge

As mentioned before, the NGK battery controller implements charging constraints on the battery whenever it approaches a full state of charge. To test the consistency of this constraint, project analysts tracked at what state of charge the maximum allowed charge rate was reduced for each charging session that attained a sufficient amount of charging energy. Figure 15 displays the corresponding SOC values for each maximum allowed charge rate listed in Table 3 on page 15. Each maximum allowed charge rating has a significant amount of variability in the SOC values. Furthermore, the NGK controller did not implement every maximum allowed charge rate as the



battery progressed to a 100% SOC. Project analysts suspect that the resolution of the data and inaccuracies in NGK's SOC calculations were the primary sources of variability in the results. The maximum allowed charge rate returned to 1,100 kW once the SOC dropped below 92-93% as expected.

Figure 15: Maximum Allowed Charge Rate as Function of SOC

In addition to tracking the energy in and out of the DESS during the charging and discharging periods, project analysts also tracked the operation of the auxiliary load throughout the testing period. Figure 16 displays the operation of the DESS and the power draw of the auxiliary loads for 12/11. As illustrated, the module heaters operated at a variable rate depending on battery operation and ambient weather conditions. For the majority of discharge periods, the auxiliary energy requirements of the DESS were minimal⁸. For this particular discharge period, the total energy requirement of the auxiliary load was 0.06 MWh and .28 MWh for the charging period. These results were similar for the other days analyzed. During the testing of the Basic GS mode of operation, the overall efficiency of the DESS, including the auxiliary energy requirements of the device, averaged 73.7%.




Figure 16: DESS and Auxiliary Power Output (12/11)

The results of the University of Minnesota's analyses in this area can be found in Appendix 1.

Conclusions

Overall, the DESS performed as expected for the majority of scenarios tested in the Basic GS mode of operation. When discharging according to profile #1, the PCS operated at the appropriate times for both full and partial discharge periods. For profile #4, the PCS operated as expected when there was sufficient energy available for a full discharge, but for a partial discharge period S&C must modify the PCS software. For the wind-only charging mode, the amount of energy consumed by the DESS while charging was near or equal to the amount of energy generated by the effective wind farm during the charging session. In the wind-grid charging mode, the PCS correctly charged at its maximum allowed rate during the appropriate times.

For an allowed charging window of 8.5 hours, the 1 MW wind scenario is not sufficient to fully charge the battery in a single charging session. On the contrary, the 10 MW wind scenario provides sufficient energy to charge the battery with a large amount of excess wind energy left over. For the 5 MW scenario, there was a large degree of variability in the results, thus project

⁸ The minimum power draw of the auxiliary load of the PCS is 6 kW due to the power requirements of the power electronics.

researchers recommend additional tests, especially for the 5 MW scenario. This will enable project researchers to better understand the appropriate amount of wind energy needed for the time-shifting application. According to the data collected for this particular testing period, results show that the optimal ratio of wind farm capacity to DESS capacity for time shifting applications is greater than 5:1, but less than 10:1.

Table 4 lists the system performance data of interest for each testing variation conducted in the Basic GS mode of operation. For the Basic GS testing period, the average mileage of the DESS was 22,170 kW/day. Moreover, the battery never exceeded more than one discharge cycle in any given day, averaging 0.77 cycles throughout the tests. The average daily auxiliary energy requirement was 720 kWh/day. The overall efficiency of the DESS with and without the auxiliary energy requirements averaged 73.7% and 85.1%, respectively.

The University of Minnesota investigated this further in 2010/11 (see Appendix 1) and determined that the optimal ratio of storage to wind for the sole purpose of shifting wind-only generation is 200 – 400 kW storage per MW installed wind, under the obligation that storage should be offered as a generating resource for 6 peak load hours everyday.

Table 4: Basic GS System Performance Data Statistics Summary

Mode	Installed Wind Capacity (MW)	Discharge Profile	Mileage⁹ (kW/day)	Daily Discharge Cycle Usage¹⁰	Aux Energy Requirement (kWh/day)	$\eta_1$¹¹	$\eta_2$¹²
Wind-Only	1	1	17,501	0.69	876	69.4%	87.1%
Wind-Only	5	1	21,726	0.61	870	70.0%	85.6%
Wind-Only	10	1	23,258	0.93	616	78.4%	85.2%
Wind-Grid	1	5	17,414	0.77	734	72.8%	84.5%
Wind-Grid	5	5	31,987	0.80	674	75.4%	84.5%
Wind-Grid	10	5	21,134	0.83	550	76.4%	83.6%

⁹ Mileage is the metric used to gauge the “stress” of the duty profile imposed on the battery. It is the cumulative sum of the absolute value of the change in PCS power settings from one time step to the next.

¹⁰ NGK has multiple daily discharge cycles, or profiles, which vary in shape, duration and number of discharge periods. These are further described in the NaS Battery Durability section of this document.

¹¹ η_1 , also known as “eta_1” measures the DESS Overall System Efficiency, including auxiliary loads.

¹² η_2 , also known as “eta_2” measures the DESS Overall System Efficiency, excluding auxiliary loads.

Table 5: Basic GS Selected Discharge Results

Discharge Date	Discharge Start Time 1 (CST)	Discharge End Time 1 (CST)	Discharge Start Time 2 (CST)	Discharge End Time 2 (CST)	Peak Demand Hour 1 (CST)	Peak Demand Hour 2 (CST)	Discharge Profile	Total PCS Discharge Energy 1 (MWh)	PCS Battery Energy 1 (MWh)	Total PCS Discharge Energy 2 (MWh)	PCS Battery Energy 2 (MWh)	Discharge Period 1 Initial SOC	Discharge Period 1 End SOC	Discharge Period 2 Initial SOC	Discharge Period 2 End SOC
12/11	12:00	18:00	N/A	N/A	1500	N/A	1	6.04	0.06	N/A	N/A	99.6%	23.3%	N/A	N/A
12/15	13:45	16:13	N/A	N/A	1500	N/A	1	2.49	0.04	N/A	N/A	44.5%	12.5%	N/A	N/A
12/25	12:00	17:59	N/A	N/A	1500	N/A	1	4.87	0.07	N/A	N/A	100.0%	40.3%	N/A	N/A
1/8	8:22	11:36	13:23	16:37	1000	1500	5	3.25	0.05	3.26	0.02	100.0%	59.7%	59.5%	16.9%

Table 6: Basic GS: Wind Only Selected Charging Performance Data

Charge Start Date	Charge Start Time (CST)	Charge End Time (CST)	Scaling Factor	PCS Charge Energy (MWh)	PCS Batteries Energy (MWh)	Charge Period Initial SOC	Charge Period Final SOC	Time at 100% SOC (CST)	Grid-Enabled Charge Hour (CST)	Effective Wind Energy Available (MWh)	Grid-Enabled PCS Charge Energy (MWh)	Grid-Enabled Period Battery Charge Energy (MWh)	Grid-Enabled Effective Wind Energy Available (MWh)	Grid-Enabled Charging Period Delta (MWh)
12/11	22:30	6:59	8.7%	3.07	0.28	23.3%	57.3%	N/A	N/A	3.05	N/A	N/A	N/A	N/A
12/24	22:30	6:59	86.7%	7.11	0.23	24.6%	100.0%	5:51	N/A	71.96	N/A	N/A	N/A	N/A

Table 7: Basic GS: Wind and Utility Selected Charging Performance Data

Charge Start Date	Charge Start Time (CST)	Charge End Time (CST)	Scaling Factor	PCS Charge Energy (MWh)	PCS Batteries Energy (MWh)	Charge Period Initial SOC	Charge Period Final SOC	Time at 100% SOC (CST)	Grid-Enabled Charge Hour (CST)	Effective Wind Energy Available (MWh)	Grid-Enabled PCS Charge Energy (MWh)	Grid-Enabled Period Battery Charge Energy (MWh)	Grid-Enabled Effective Wind Energy Available (MWh)	Grid-Enabled Charging Period Delta (MWh)
12/30	22:30	6:59	8.7%	5.79	0.29	16.8%	78.5%	N/A	245	2.52	4.60	0.14	1.39	3.34

Table 8: Basic GS All Discharge Results

Discharge Date	Discharge Start Time 1 (CST)	Discharge End Time 1 (CST)	Discharge Start Time 2 (CST)	Discharge End Time 2 (CST)	Peak Demand Hour 1 (CST)	Peak Demand Hour 2 (CST)	Discharge Profile	Total PCS Discharge Energy 1 (MWh)	PCS Batteries Energy 1 (MWh)	Total PCS Discharge Energy 2 (MWh)	PCS Batteries Energy 2 (MWh)	Discharge Period 1 Initial SOC	Discharge Period 1 End SOC	Discharge Period 2 Initial SOC	Discharge Period 2 End SOC
12/11	12:00	18:00	N/A	N/A	1500	N/A	1	6.04	0.06	N/A	N/A	99.6%	23.3%	N/A	N/A
12/12	13:18	16:41	N/A	N/A	1500	N/A	1	3.41	0.04	N/A	N/A	57.1%	12.9%	N/A	N/A
12/13	13:20	16:39	N/A	N/A	1500	N/A	1	3.35	0.05	N/A	N/A	56.3%	13.3%	N/A	N/A
12/14	13:44	16:16	N/A	N/A	1500	N/A	1	2.56	0.04	N/A	N/A	45.3%	12.6%	N/A	N/A
12/15	13:45	16:13	N/A	N/A	1500	N/A	1	2.49	0.04	N/A	N/A	44.5%	12.5%	N/A	N/A
12/16	12:00		N/A	N/A	1500	N/A	1	6.02	0.06	N/A	N/A	97.5%	21.5%	N/A	N/A
12/17	13:14	16:45	N/A	N/A	1500	N/A	1	3.54	0.05	N/A	N/A	59.1%	13.3%	N/A	N/A
12/18	14:16	15:43	N/A	N/A	1500	N/A	1	1.46	0.03	N/A	N/A	30.4%	11.5%	N/A	N/A
12/19	12:55	17:05	N/A	N/A	1500	N/A	1	4.20	0.04	N/A	N/A	68.1%	14.2%	N/A	N/A
12/20	14:11	15:47	N/A	N/A	1500	N/A	1	1.61	0.03	N/A	N/A	32.5%	11.6%	N/A	N/A
12/22	12:00	17:59	N/A	N/A	1500	N/A	1	6.03	0.07	N/A	N/A	99.9%	24.1%	N/A	N/A
12/23	11:59	17:59	N/A	N/A	1500	N/A	1	6.03	0.07	N/A	N/A	100.0%	23.8%	N/A	N/A
12/24	12:00	17:59	N/A	N/A	1500	N/A	1	6.02	0.07	N/A	N/A	100.0%	24.7%	N/A	N/A
12/25	12:00	17:59	N/A	N/A	1500	N/A	1	4.87	0.07	N/A	N/A	100.0%	40.3%	N/A	N/A
12/26	12:00	17:59	N/A	N/A	1500	N/A	1	6.03	0.06	N/A	N/A	100.0%	24.1%	N/A	N/A
12/27	12:00	17:59	N/A	N/A	1500	N/A	1	6.04	0.07	N/A	N/A	99.8%	23.7%	N/A	N/A
12/28	12:00	17:59	N/A	N/A	1500	N/A	1	6.01	0.08	N/A	N/A	100.0%	24.4%	N/A	N/A
12/30	N/A	N/A	13:22	16:36	N/A	1500	5	N/A	N/A	3.26	0.02	N/A	N/A	59.5%	16.9%
12/31	9:07	10:51	14:07	15:51	1000	1500	5	1.75	0.04	1.75	0.05	78.8%	57.2%	57.1%	34.6%
1/1	8:30	11:30	13:29	16:30	1000	1500	5	3.02	0.05	3.03	0.03	96.5%	59.3%	59.2%	19.9%
1/2	9:13	10:46	14:13	15:46	1000	1500	5	1.56	0.03	1.56	0.04	76.0%	56.8%	56.6%	36.8%
1/3	8:36	11:23	13:36	16:24	1000	1500	5	2.79	0.04	2.82	0.03	93.6%	58.9%	58.6%	22.0%
1/4	9:25	10:34	14:25	15:34	1000	1500	5	1.16	0.03	1.17	0.03	70.7%	56.3%	56.0%	41.3%
1/5	8:42	11:16	N/A	N/A	1000	N/A	5	2.58	0.04	N/A	N/A	90.3%	58.2%	N/A	N/A
1/6	N/A	N/A	13:42	16:17	N/A	1500	5	N/A	N/A	2.59	0.04	N/A	N/A	77.1%	44.4%
1/7	8:23	11:36	13:22	16:36	1000	1500	5	1.95	0.08	2.03	0.09	100.0%	76.7%	76.6%	52.2%
1/8	8:22	11:36	13:23	16:37	1000	1500	5	3.25	0.05	3.26	0.02	100.0%	59.7%	59.5%	16.9%

Discharge Date	Discharge Start Time 1 (CST)	Discharge End Time 1 (CST)	Discharge Start Time 2 (CST)	Discharge End Time 2 (CST)	Peak Demand Hour 1 (CST)	Peak Demand Hour 2 (CST)	Discharge Profile	Total PCS Discharge Energy 1 (MWh)	PCS Batteries Energy 1 (MWh)	Total PCS Discharge Energy 2 (MWh)	PCS Batteries Energy 2 (MWh)	Discharge Period 1 Initial SOC	Discharge Period 1 End SOC	Discharge Period 2 Initial SOC	Discharge Period 2 End SOC
1/9	9:36	10:23	14:36	15:23	1000	1500	5	0.79	0.03	0.79	0.03	65.5%	55.8%	55.5%	45.5%
1/10	8:23	11:37	13:23	16:37	1000	1500	5	3.24	0.04	3.27	0.02	99.9%	59.4%	59.4%	16.6%
1/11	8:23	11:36	13:22	16:36	1000	1500	5	3.23	0.05	3.26	0.02	99.9%	59.7%	59.7%	17.1%
1/12	8:50	11:09	13:50	16:09	1000	1500	5	2.33	0.04	2.33	0.04	86.8%	58.1%	57.7%	27.7%
1/13	8:23	11:36	13:23	16:36	1000	1500	5	3.23	0.04	3.25	0.02	99.7%	59.9%	59.5%	17.3%
1/14	8:23	11:36	13:22	16:36	1000	1500	5	3.22	0.05	3.25	0.02	99.7%	59.7%	59.6%	17.1%
1/15	9:36	10:24	14:36	15:23	1000	1500	5	0.80	0.03	0.79	0.03	65.7%	55.7%	55.5%	45.6%
1/16	8:23	11:37	13:23	16:37	1000	1500	5	3.24	0.03	3.26	0.02	99.9%	59.7%	59.6%	17.0%
1/17	9:29	10:30	14:29	15:30	1000	1500	5	1.03	0.04	1.03	0.04	68.7%	56.1%	55.9%	42.9%
1/18	8:23	11:37	13:23	16:36	1000	1500	5	3.24	0.04	3.25	0.02	99.9%	59.7%	59.5%	17.2%
1/19	8:49	11:09	13:50	16:09	1000	1500	5	2.35	0.04	2.35	0.04	87.0%	57.8%	57.6%	27.3%
1/20	8:23	11:36	13:23	16:37	1000	1500	5	3.24	0.04	3.26	0.02	100.0%	59.9%	59.7%	17.1%
1/21	8:37	11:22	N/A	N/A	1000	N/A	5	2.76	0.04	N/A	N/A	92.8%	58.4%	N/A	N/A

Table 9: Basic GS: Wind Only All Charging Performance Data

Charge Start Date	Charge Start Time (CST)	Charge End Time (CST)	Scaling Factor	PCS Charge Energy (MWh)	PCS Batteries Energy (MWh)	Charge Period Initial SOC	Charge Period Final SOC	Time at 100% SOC (CST)	Grid-Enabled Charge Hour (CST)	Effective Wind Energy Available (MWh)	Grid-Enabled PCS Charge Energy (MWh)	Grid-Enabled Period Battery Charge Energy (MWh)	Grid-Enabled Effective Wind Energy Available (MWh)	Grid-Enabled Charging Period Delta (MWh)
12/11	22:30	6:59	8.7%	3.07	0.28	23.3%	57.3%	N/A	N/A	3.05	N/A	N/A	N/A	N/A
12/12	22:30	6:59	8.7%	3.94	0.44	12.8%	56.3%	N/A	N/A	3.92	N/A	N/A	N/A	N/A
12/13	22:30	6:59	8.7%	2.91	0.51	13.2%	45.5%	N/A	N/A	2.87	N/A	N/A	N/A	N/A
12/14	22:30	6:59	8.7%	2.86	0.52	12.6%	44.5%	N/A	N/A	2.87	N/A	N/A	N/A	N/A
12/15	22:30	6:59	43.3%	8.03	0.26	12.5%	97.5%	N/A	N/A	16.02	N/A	N/A	N/A	N/A
12/16	22:30	6:59	43.3%	3.42	0.27	21.6%	59.2%	N/A	N/A	3.46	N/A	N/A	N/A	N/A
12/17	22:30	6:59	43.3%	1.62	0.39	13.1%	30.6%	N/A	N/A	1.73	N/A	N/A	N/A	N/A

Charge Start Date	Charge Start Time (CST)	Charge End Time (CST)	Scaling Factor	PCS Charge Energy (MWh)	PCS Batteries Energy (MWh)	Charge Period Initial SOC	Charge Period Final SOC	Time at 100% SOC (CST)	Grid-Enabled Charge Hour (CST)	Effective Wind Energy Available (MWh)	Grid-Enabled PCS Charge Energy (MWh)	Grid-Enabled Period Battery Charge Energy (MWh)	Grid-Enabled Effective Wind Energy Available (MWh)	Grid-Enabled Charging Period Delta (MWh)
12/18	22:30	6:59	43.3%	5.23	0.47	11.4%	68.2%	N/A	N/A	5.63	N/A	N/A	N/A	N/A
12/19	22:30	6:59	43.3%	1.69	0.34	14.1%	32.6%	N/A	N/A	1.73	N/A	N/A	N/A	N/A
12/20	22:30	6:59	43.3%	0.06	0.46	11.5%	12.1%	N/A	N/A	0.00	N/A	N/A	N/A	N/A
12/22	22:30	6:59	86.7%	7.21	0.16	24.1%	100.0%	5:52	N/A	23.41	N/A	N/A	N/A	N/A
12/23	22:30	6:59	86.7%	7.12	0.22	23.8%	100.0%	6:48	N/A	18.21	N/A	N/A	N/A	N/A
12/24	22:30	6:59	86.7%	7.11	0.23	24.6%	100.0%	5:51	N/A	71.96	N/A	N/A	N/A	N/A
12/25	22:30	6:59	86.7%	5.63	0.34	40.2%	100.0%	6:58	N/A	27.74	N/A	N/A	N/A	N/A
12/26	22:30	6:59	86.7%	7.15	0.19	24.1%	99.8%	N/A	N/A	33.81	N/A	N/A	N/A	N/A
12/27	22:30	6:59	86.7%	7.17	0.19	23.7%	100.0%	5:55	N/A	51.15	N/A	N/A	N/A	N/A
12/28	22:30	6:59	86.7%	1.93	0.31	24.2%	44.6%	N/A	N/A	3.47	N/A	N/A	N/A	N/A

Table 10: Basic GS: Wind and Utility All Charging Performance Data

Charge Start Date	Charge Start Time (CST)	Charge End Time (CST)	Scaling Factor	PCS Charge Energy (MWh)	PCS Batteries Energy (MWh)	Charge Period Initial SOC	Charge Period Final SOC	Time at 100% SOC (CST)	Grid-Enabled Charge Hour (CST)	Effective Wind Energy Available (MWh)	Grid-Enabled PCS Charge Energy (MWh)	Grid-Enabled Period Battery Charge Energy (MWh)	Grid-Enabled Effective Wind Energy Available (MWh)	Grid-Enabled Charging Period Delta (MWh)
12/30	22:30	6:59	8.7%	5.79	0.29	16.8%	78.5%	N/A	245	2.52	4.60	0.14	1.39	3.34
12/31	22:30	6:59	8.7%	5.80	0.41	34.5%	96.6%	N/A	245	3.22	4.29	0.15	1.65	2.79
1/1	22:30	6:59	8.7%	5.33	0.36	19.7%	76.0%	N/A	245	1.13	4.61	0.19	0.44	4.37
1/2	22:31	6:59	8.7%	5.38	0.37	36.7%	93.7%	N/A	245	0.96	4.54	0.13	0.17	4.50
1/3	22:30	6:59	8.7%	4.62	0.32	21.9%	70.6%	N/A	245	0.00	4.61	0.15	0.00	4.75
1/4	22:30	6:59	8.7%	4.66	0.37	41.1%	90.3%	N/A	245	0.00	4.62	0.14	0.00	4.76
1/6	22:30	6:59	43.3%	5.23	0.42	44.4%	100.0%	3:56	245	40.70	0.61	0.23	20.78	-19.95

Charge Start Date	Charge Start Time (CST)	Charge End Time (CST)	Scaling Factor	PCS Charge Energy (MWh)	PCS Batteries Energy (MWh)	Charge Period Initial SOC	Charge Period Final SOC	Time at 100% SOC (CST)	Grid-Enabled Charge Hour (CST)	Effective Wind Energy Available (MWh)	Grid-Enabled PCS Charge Energy (MWh)	Grid-Enabled Period Battery Charge Energy (MWh)	Grid-Enabled Effective Wind Energy Available (MWh)	Grid-Enabled Charging Period Delta (MWh)
1/7	22:30	6:59	43.3%	4.53	0.41	52.2%	100.0%	3:06	245	35.94	0.09	0.26	15.16	-14.80
1/8	22:30	6:59	43.3%	4.62	0.32	16.9%	65.6%	N/A	245	0.00	4.61	0.15	0.00	4.76
1/9	22:30	6:59	43.3%	5.09	0.34	45.4%	100.0%	4:14	245	32.48	0.52	0.22	14.29	-13.55
1/10	22:30	6:59	43.3%	7.87	0.20	16.6%	100.0%	6:44	245	23.38	3.24	0.10	10.83	-7.49
1/11	22:30	6:59	43.3%	6.59	0.24	17.0%	86.8%	N/A	245	12.12	4.61	0.09	9.96	-5.25
1/12	22:31	6:59	43.3%	6.72	0.25	27.7%	100.0%	6:02	245	8.66	2.38	0.14	3.46	-0.95
1/13	22:30	6:59	86.6%	7.85	0.16	17.3%	100.0%	6:45	245	31.18	3.28	0.08	14.72	-11.36
1/14	22:30	7:00	86.6%	4.63	0.26	16.9%	65.7%	N/A	245	0.00	4.61	0.12	0.00	4.73
1/15	22:30	6:59	86.6%	5.10	0.34	45.6%	100.0%	4:18	245	23.38	0.56	0.22	11.26	-10.48
1/16	22:30	6:59	86.6%	4.92	0.23	17.0%	68.6%	N/A	245	0.00	4.61	0.12	0.00	4.73
1/17	22:30	6:59	86.6%	5.39	0.33	42.8%	100.0%	6:17	245	2.60	2.76	0.15	0.00	2.91
1/18	22:30	6:59	86.6%	6.58	0.20	17.1%	87.0%	N/A	245	2.60	4.61	0.08	0.00	4.70
1/19	22:30	6:59	86.6%	6.88	0.26	27.2%	100.0%	5:53	245	32.04	2.26	0.14	18.19	-15.78
1/20	22:30	6:59	86.6%	7.16	0.18	17.1%	92.8%	N/A	245	5.20	4.61	0.09	0.87	3.83

Economic Dispatch (ED)

Introduction

Another value proposition in the W2B Test Plan is an assessment of the obtainable value of storage in a wholesale energy market when providing the function of arbitrage. For the ED mode of operation, the DESS followed set-points derived from an algorithm that uses forward and spot energy prices in the MISO market and settings from the user. Although the battery was never officially offered into the MISO market, project analysts estimated the settlement results. Xcel Energy tested the battery in this mode for a period of 7 days. A brief description of the results is included below with greater detail provided in the supplemental information on page 38.

Theory

The revenue potential from operating a storage device under an arbitrage control scheme is well documented [Denholm, Walawakar]. However, studies of this nature typically only consider day-ahead (DA) prices when scheduling a storage device into the market, ignoring any potential opportunities for additional profits to be gained from real-time (RT) prices.

MISO has two operating energy markets in which a market participant (MP) can either supply or demand energy: a DA market and a RT market. Operating on hourly intervals, the DA market is purely financial (i.e. no electrons are injected into or extracted from the grid). As a result, it tends to be “well-behaved” in the sense that energy prices are relatively predictable from one day to the next. Conversely, the RT market, which operates on a 5-min interval basis, is tied to near real-time grid conditions. As a result, the RT market serves as a balancing market, meaning that it settles deviations between the scheduled and actual grid state. Each market has its own respective Locational Marginal Price (LMP); however, in well-designed markets, the majority of DA and RT prices are similar in value for the same time period. Generally, this is the case in MISO. Nevertheless, changes in the DA schedule are inevitable due to many factors such as inaccurate load and supply forecasts, transmission congestion, and system contingencies. As a result, RT energy prices are more volatile than DA prices, creating an opportunity for additional benefit to storage.

When the battery is in the ED mode, the ED algorithm generates and issues automated set-points to the DESS. Xcel Energy’s Market Operations department developed the algorithm with the objective to optimize the operation of the battery within both the DA and RT energy markets, thereby minimizing the costs of ownership¹³. Using historical and forecasted market information, a trader can configure the algorithm to minimize the charging costs of the battery and maximize its discharging revenue. The PCS still honors all charging and discharge constraints for the storage device while in this mode.

Performance Data

Project participants tested the battery in the ED mode for a continuous one-week period from 6/1/2010 to 6/7/2010, collecting data at a one-minute resolution. The algorithm used DA and RT prices for the NSP.NSP Commercial Price Node (CPNode) in MISO. Analysts evaluated the

¹³ Beuning, Steve. “Battery Financial Input Data Control Schematic.”

technical performance of the DESS and calculated the hypothetical financial return. During the testing period, project analysts updated the DA schedule and the mean RT energy price values daily¹⁴. To define the hourly RT values, project researchers used a 20-day rolling average of historical RT pricing data.

Overall, the DESS was able to follow the set-points issued by the ED algorithm with sufficient accuracy. However, there was a delay of 3-5 minutes between when the algorithm issued a set-point and when the DESS responded to it. Project analysts believe the primary source for the delay was in the transfer process of the 5-min RT LMP file from Xcel Energy to GridPoint via the File Transfer Protocol (FTP) server. Below is a description of the performance of the battery and the financial results for the period of performance, along with a high-level summary of the weekly results.

Figure 17 displays the results of the scheduling process in the DA market based on the economic parameters specified by the user and the hourly DA LMPs. As prices increased in the DA market, the battery gradually went from charging at high rate to discharging at a high rate, which was expected and desired. Figure 18 displays the corresponding hourly revenue from the DA market. For the week, the battery cleared the market to charge approximately 45,000 kWh at an average price of \$18/MWh. For discharging, the battery cleared approximately 32,000 kWh in the DA market at an average price of \$40/MWh. The combined weekly revenue from the DA market was \$490.




Figure 17: Day-Ahead Market Scheduling Process (6/1-6/7)

¹⁴ Values were not updated on 6/5.




Figure 18: Day-Ahead Market Revenue (6/1-6/7)

Figure 19 displays the DESS output, the DESS auxiliary power requirement, the SOC of the unit, and the requested set-point issued by the ED algorithm. Every day at 00:00, the DESS began to operate according to its DA schedule for that day to the best of its ability. As the algorithm instructed the DESS to operate according to its DA schedule, it also issued additional commands to the battery when it was following pricing signals from the RT market. The total response of the DESS was a combination of the set-points generated by the ED algorithm for both energy markets. Because of its inherent uncertainty, the auxiliary power draw of the DESS, which averaged 29 kW for the week, was always treated as unscheduled market activity (i.e. it settles in the RT market). As shown in the figure, when the DESS approached a full SOC, it was unable to follow the requested set-point due to the charging constraints implemented by the NGK battery controller.




Figure 19: DESS System Performance Data and Requested Set-Point (6/1-6/7)

Whenever the DESS deviated from its DA schedule, regardless of whether or not it was instructed to do so by the algorithm, it was operating within the RT market. Activity in the RT market settles at the corresponding hourly RT LMP. Figure 20 displays the calculated hourly average of RT activity for the MP and the RT LMPs for each hour. In the figure, positive RT activity is the equivalent of purchasing power in the market (i.e. negative cash return to the MP), and negative RT activity is the equivalent of selling power in the market (i.e. positive cash return to the MP). Figure 21 displays the corresponding hourly revenue from the RT market. Including the power requirements for the auxiliary load, the DESS had 15,800 kWhs of positive RT activity at an average price of \$42/MWh. Conversely, the DESS had 20,400 kWhs of negative RT activity at an average price of \$21/MWh. The total combined revenue from the RT market was -\$250.




Figure 20: Activity / Obligations in the Real-Time Market (6/1-6/7)




Figure 21: Real-Time Market Revenue (6/1-6/7)

Figure 22 highlights one of the risks when operating in the RT market. On 6/5 from 19:00-19:59, the battery was operating in the RT market. For the first half of the hour, RT prices averaged around \$24/MWh. Then at 19:25, the 5-min RT LMP jumped up sharply over the next 15 minutes, reaching as high as \$576/MWh. As a result, the hourly RT LMP for that hour averaged out to be \$145/MWh¹⁵. This resulted in the MP having to pay \$121 for 837 kWh of charging energy while only receiving \$18 for 129 kWh of discharge energy. As a result, the MP lost approximately \$103 for the hour.




Figure 22: Real-Time Market Activity (6/5)

In addition to the risk illustrated in Figure 22, all unscheduled activity in the RT market is charged Revenue Sufficiency Guarantee (RSG) charges. MISO levies these administrative charges to ensure that other MPs are “made whole” (i.e. they receive enough revenue to cover their expenses incurred from their DA schedule). Although these charges are not shown in Figure 21, they do impact the financial standing of the MP in the RT market.

For the week, RSG charges totaled \$58, which was 18% of the overall RT revenue for the week. The total daily gross revenue is a summation of the revenue obtained from the DA and RT markets. Figure 23 displays the hourly values, and Figure 24 provides a high-level summary of the final results for the week.

¹⁵ The hourly RT LMP values are a time-weighted average of the ex post 5-min RT LMP values, which can vary from ex ante 5-min RT LMP values that are shown in Figure 22.




Figure 23: Gross Total Revenue (6/1-6/7)

Gross Revenue	\$240	Net Revenue (w/ RSG)	\$182
Charge Revenue	-\$989	Discharge Revenue	\$1,331
Total Charge Energy (kWh)	37,638	Total Discharge Energy (kWh)	34,209
Charging Avg (\$/MWh)	26	Discharging Avg (\$/MWh)	39
Total Heater Revenue	-\$102	Total Heater Energy (kWh)	4,958
Ideal Gross Revenue	\$445	RSG Charge	-\$58
overall efficiency	76.7%	Delta (\$/MWh)	13
Cycle Count	5	DC Discharge (Ah)	55,711

Figure 24: High-Level Summary of ED Results (6/1-6/7)

After accounting for RSG charges, the net revenue for the week was \$182. The DESS discharged 34,209 kWh and consumed 37,683 kWh for charging, with an additional 4,958 kWh of energy required for its auxiliary loads. The average weekly charging and discharging rate was \$26/MWh and \$39/MWh, respectively. If the unit were able to exactly follow its DA schedule as well as perfectly satisfy every requested DA_Opt and RT_Only command, the gross revenue would have been \$445. However, due to energy constraints of the battery and the aforementioned latency issue, the MP was unable to earn this amount. Throughout the week, the DESS averaged an overall efficiency of 76.7%. Over the course of the operating period, the average daily discharge activity of the battery was 7,958 Ah, which resulted in 0.77 cycles per NGK's cycle counting algorithm.

The results of the University of Minnesota's analyses in this area can be found in Appendix 1.

Conclusions

For the majority period of time, the DESS performed, within its limits, as expected in the ED mode of operation. Project analysts recommend that the DESS be tested in this mode of operation for an additional period of time to improve the user settings as well as to gauge the variability in results over an extended period of time. In addition, project participants are

interested in controlling the battery strictly off set-points derived from the RT market to determine the corresponding value achieved by the DESS.

Currently, the potential for arbitrage in the MISO market at the selected CPNode is limited as shown by the small spread in the average charge and discharge rates. However, project analysts may obtain improved results by optimizing the ED algorithm user settings and defining the expected DA and RT energy prices with less error. Notwithstanding any improvements obtained by optimizing the ED algorithm settings, it is difficult for a MP to optimize the operation of a bulk storage device in the MISO market because of its inherent energy constraints and the potential to be exposed to market risk in a variety of manners. Project analysts should work closely with MISO to discuss how a market resource such as the DESS would be best utilized in the energy market.

Table 11 lists the system performance data of interest for the one week testing period of the Economic Dispatch mode of operation. During this testing period, the average mileage of the DESS was 25,508 kW/day. Again, the battery never exceeded more than one discharge cycle in any given day, averaging 0.77 cycles over the week. The average daily auxiliary energy requirement was 709 kWh/day. The overall efficiency of the DESS with and without the auxiliary energy requirements averaged 78.1% and 87.3%, respectively.

Table 11: Economic Dispatch System Performance Data Statistics Summary

Mode	Mileage (kW/day)	Daily Discharge Cycle Usage	Aux Energy Requirement (kWh/day)	η_1	η_2
Economic Dispatch	25,508	0.77	709	78.1%	87.3%

The University of Minnesota analyzed this further in 2011 (see Appendix 1), using 2010 data, and developed a method for screening nodes in the NSP system. They found that the variance, range and absolute error of MISO's real-time (RT) prices, and the variance of the day-ahead (DA) prices are good predictors of the total revenue one could expect from an energy storage device with characteristics of the sodium-sulfur battery system tested.

Supplemental Information for ED Mode

Figure 25 provides a detailed breakdown of the system performance data for the ED mode of operation, with a description of the categories located below.

% DA_Only Operation Mode	81%	% DA_Opt Operation Mode	11%
% Rogue Operation Mode	5%	% RT_Only Operation Mode	9%
% Requested Idle	6%	% Actual Idle	24%
% DA_Only Charge Energy	77.1%	% DA_Only Discharge Energy	78.7%
% DA_Opt Charge Energy	3.1%	% DA_Opt Discharge Energy	12.1%
% RT_Only Charge Energy	18.9%	% RT_Only Discharge Energy	6.8%
% Rogue Charge Energy	0.8%	% Rogue Discharge Energy	2.3%
% True Up Charge Energy (over)	1.8%	% True Up Discharge Energy (over)	2.4%
% True Up Charge Energy (under)	44.4%	% True Up Discharge Energy (under)	17.7%
DA_Only Charge Rev	-\$791	DA_Only Discharge Revenue	\$1,281
DA_Opt Charge Revenue	-\$1	DA_Opt Discharge Revenue	\$187
RT_Only Charge Revenue	-\$380	RT_Only Discharge Revenue	\$106
Rogue Charge Revenue	-\$9	Rogue Discharge Revenue	\$20
True Up Charge Revenue (over)	-\$14	True Up Discharge Revenue (over)	\$34
True Up Charge Revenue (under)	\$206	True Up Discharge Revenue (under)	-\$298
DA_Only Charge Avg Price (\$/MWh)	28	DA_Only Discharge Avg Price (\$/MWh)	46
DA_Opt Avg Charge Price (\$/MWh)	16	DA_Opt Avg Discharge Price (\$/MWh)	36
RT_Only Charge Avg Price (\$/MWh)	33	RT_Only Discharge Avg Price (\$/MWh)	24
Rogue Charge Avg Price (\$/MWh)	17	Rogue Discharge Avg Price (\$/MWh)	19
True Up Charge Avg Price (\$/MWh) (over)	21	True Up Discharge Avg Price (\$/MWh) (over)	38
True Up Charge Avg Price (\$/MWh) (under)	19	True Up Discharge Avg Price (\$/MWh) (under)	40
DA Charge Award (kWh)	45000	DA Discharge Award (kWh)	-32000
DA Charge Award Avg Rate (\$/kWh)	18	DA Discharge Award Avg Rate (\$/kWh)	40
DA Charge Penalty	\$83	DA Discharge Penalty	\$66

Figure 25: High-Level Summary of Weekly ED Results (6/1-6/7)

The “% ‘mode’ Operation Mode” categories (e.g. ‘DA_Only’ Operation mode) provide the amount of time the battery was in each particular mode of operation. The DA_Only operation mode is active whenever the battery is operating as a result of it trying to meet its DA obligation¹⁶. Conversely, the DA_Opt operation mode is active when the battery has a DA obligation for that hour and is operating in the RT market. Finally, the RT_Only operation mode is active when there is no DA obligation for that hour but the battery is operating in the RT

¹⁶ If the battery has a DA obligation but is not operating, it is not considered to be in the DA_Only mode.

market. The Rogue operation mode is a catch-all that accounts for all the unexpected and delayed activity of the DESS.

The “% Requested Idle” category tracks the amount of time that the ED algorithm instructed the battery to be idle (i.e. to not produce or consume any power). Conversely, the “% Actual Idle” category trends the actual amount of time the DESS was idle, either due to energy constraints of the battery, system alarms, or other factors affecting performance. Note that the modes do not add up to 100% because there are some overlaps between the modes. First, whenever the battery is in the DA_Opt mode, it is also in the DA_Only mode. Second, delayed operation of the DESS may be accounted for by both the “% Requested Idle” and “% Rogue Operation Mode” categories.

The “% ‘mode’ Charge / Discharge Energy” categories trend the respective amount of charge/discharge energy that occurred while in that mode relative to the total amount of charge/discharge energy over the entire period of performance¹⁷. For example, the “% RT_Only Charge Energy” category shows a value of 18.92%; therefore, approximately 7,100 kWh of charge energy was acquired while the battery was in the RT_Only mode. The “% True Up Charge / Discharge Energy (over)” categories track the amount of energy that the MP either bought in the RT market when it charged at a rate greater than expected or sold in the RT market when it discharged at a rate greater than expected. The “% True Up Charge / Discharge Energy (under)” categories track the amount of energy that the MP either sold in the RT market when it charged at a rate less than expected or bought in the RT market when it discharged at a rate less than expected. For example, the “% True Up Charge Energy (over)” value was 1.8%, which means that the DESS exceeded its DA schedule for charging by approximately 677 kWh for the week. The “% True Up Discharge Energy (under)” value was 17.7%, which means that the DESS was short on its obligation to serve as a generator for a total of approximately 6,050 kWh.

The “‘mode’ Charge / Discharge Revenue” categories calculate the respective amount of charge or discharge revenue that occurred while in that mode. For example, the DESS earned \$1,281 by discharging in the DA_Only mode but had to pay \$298 to fulfill its DA obligation as a generator. The “‘mode’ Charge/Discharge Avg Price (\$/MWh)” categories give the average rate that the DESS paid or earned while in that mode. It is simply the absolute value of the respective revenue divided by the respective amount of energy.

The “DA Charge/Discharge Penalty” categories calculate the penalty a MP incurs by having to true up the MP’s DA position in the RT market. Because this is a penalty, a positive value equates to the MP having to either pay more or earn less in the RT market than the MP would have in the DA market. For example, if the unit is scheduled in the DA market to charge at 500 kW but is actually charging at 800 kW and the RT price is less than the DA LMP, the penalty is negative because this is a benefit to the MP. Conversely, if the unit is scheduled in the DA market to discharge at 500 kW but is only discharging at 250 kW and the RT price is more than the DA LMP, then the penalty is positive. The DA Charge Penalty and Discharge Penalty for the week of 6/1-6/7 were \$83 and \$66, respectively.

¹⁷ Respective energy amounts for each mode of operation were estimated based on instantaneous energy values.

Frequency Regulation

Introduction

One value proposition in the W2B Test Plan is to evaluate the ability of large-scale battery storage technology to provide the market service of frequency regulation both as a load and a generator. Under this mode, the DESS follows a frequency regulation signal derived from changes in the Area Control Error (ACE) for the MISO market.

Theory

Ancillary services are required services that support generation and transmission functions for the bulk electric power grid. One type of ancillary service, frequency regulation, is primarily intended to assist a balancing authority in maintaining its ACE to within the limits prescribed by the North American Electric Reliability Corporation (NERC) control performance standards.

Positive ACE represents an over-generation situation, where larger ACE values mean greater amounts of over-generation. Conversely, negative ACE represents an under-generation situation, where larger negative ACE values mean greater amounts of under-generation. A regulating resource is defined as an online resource (e.g., generation, storage, or responsive load) connected to an Automatic Generation Control (AGC) system with the intent to balance the random and rapid fluctuations in generation and/or load on an intra-minute basis [Kirby].

Because regulation set-points are typically updated every 2-6 seconds, units providing regulation typically have good ramping capability. Regulating units that can respond to control signals in a timely and accurate manner enable a balancing authority to reduce the overall amount of regulating reserves it must procure, thereby increasing system efficiency [Makarov]. Indeed, some storage advocates argue that faster responding resources should be compensated more than traditional generation-based ancillary service resources.

Below is a description of the logic used by the NSP Energy Management System (EMS) to generate the frequency regulation signal for the battery. The code calls for the battery to charge whenever the ACE is greater than the maximum allowed value, discharge whenever the ACE is less than the minimum allowed value, and be idle whenever the ACE is within the allowed dead-band range. NSP EMS updates the control set-point every 4 seconds. The PCS still honors all charging and discharge constraints for the storage device while in this mode. Please refer to the architecture discussion on page 105 for an overview of the data flows and a description of the variables listed below.

Positive MISO ACE (i.e., over generation):

If $MISO_ACE > AceDb_BatU$, calculated regulation signal will be

$$\text{Calculated Setpoint}_i = \text{Scaling_factor} * (MISO_ACE - AceDB_BatU).$$

The charge command sent to the battery will be

$$\text{Target Power}_i = \text{Target Power}_{i-1} + \min(\text{Calculated Setpoint}_i, \text{positive ramp rate} / 60 * \text{AGC cycle time})$$

If the charge command to be sent to the battery is greater than the maximum allowed limit, then the battery will be commanded to charge at its maximum allowed rate.

Negative MISO ACE (i.e., under generation):

If $\text{MISO_ACE} < \text{AceDb_BatL}$, calculated regulation signal will be

$$\text{Calculated Setpoint}_i = \text{Scaling_factor} * (\text{MISO_ACE} - \text{AceDB_BatL})$$

The discharge command sent to the battery will be

$$\text{Target Power}_i = \text{Target Power}_{i-1} - \max(\text{Battery Calculated Setpoint}_i, \text{negative ramp rate} / 60 * \text{AGC cycle time})$$

If the discharge command to be sent to the battery is lower than the minimum allowed limit, then the battery will be commanded to discharge at its maximum allowed rate.

Allowable MISO ACE Deviations (i.e., stable operation):

If $\text{AceDb_BatL} \leq \text{MISO_ACE} \leq \text{AceDb_BatU}$, the command sent to the battery will be

$$\text{Target Power}_i = 0$$

Performance Data

Project participants tested the battery in the Frequency Regulation mode for a total of six 24-hour periods. For three of the days, researchers selected a configuration with a scaling factor of 100% and an ACE dead-band range of ± 100 MW. For the other three days, researchers selected a configuration with a scaling factor of 100% and an ACE dead-band range of ± 200 MW. Figure 26 displays the MISO ACE over a 24-hour period at 4-second resolution for one of the ± 100 MW testing periods, which occurred between 3/4/2010 and 3/5/2010. As shown by the figure, the ACE varied greatly throughout the entire day with multiple instances of large deviations in both the positive and negative directions.




Figure 26: MISO ACE (3/4-3/5)

Figure 26 also shows the amount of energy “embedded” in the ACE signal over time (i.e. the integration of the ACE signal). This line reflects whether the system tends to have an over- or under- supply situation for a given time period. For this particular period of interest, the MISO footprint had a net positive energy grid condition (i.e. excess generation) of 1,062 MWh.

Table 12 lists some of the statistical properties of the ACE signal for this testing period along with the other five testing periods. As illustrated by the table, it was common for MISO to experience a large range in ACE values that exhibited a large degree of variability. Coincidentally, all six days selected for testing had a positive bias in the ACE signal.

Table 12: MISO ACE Statistics

	± 100 MW ACE Dead-Band			± 200 MW ACE Dead-Band		
Date	4-Mar	8-Mar	24-Mar	22-Mar	30-Mar	4-May
Maximum (MW)	1,110	958	967	1,106	1,719 ¹⁸	918
Minimum (MW)	-926	-809	-796	-842	-895	-1,041
Average (MW)	44	34	44	34	76	37
Standard Deviation (MW)	235	246	240	246	259	231
Energy Composition (MWh)	1,062	814	1061	827	1,852	885

Figure 27 displays a portion of the corresponding operation of the battery as a result of the ACE profile shown in Figure 26. The battery rapidly switched from full charging to full discharging operation frequently throughout the period of interest as a result of fluctuations in the ACE. However, whenever the ACE was within the allowed dead-band range, the DESS was idle, as expected.




Figure 27: Zoomed-In View of Frequency Regulation Mode of Operation (3/4-3/5)

¹⁸ For unknown reasons, on 3/30, MISO underwent a 10-minute period in which it experienced continuously large ACE values in excess of 1,000 MW. It was during this time that the overall maximum value of 1,719 MW was witnessed.

Overall, the PCS generally behaved as expected based on the logic specified by the NSP EMS regulation code for all six operating periods. However, while in this mode, the PCS frequently and randomly issued temporary Inhibit Alarms (approximately 50 to 80 alarms) lasting between 4-8 seconds¹⁹. The dead-band setting did not appear to be a factor in the number of alarms issued. According to S&C, the Inhibit Alarms were the result of DC Over-Voltages that occurred when the DESS rapidly changed from charge or discharge to zero. S&C states the newest version of the PCS software will account for this condition and will not issue an alarm as a result.

Table 13 lists the primary DESS performance statistics for the Frequency Regulation mode of operation for the profile shown in Figure 26 along with the other testing periods. As expected, for a larger ACE dead-band window the DESS was less active. In the ± 100 MW scenarios, the average mileage²⁰ was 2,012,252 kW/day and the DESS was idle for approximately 7.5 hours on average. In addition, the maximum idle duration period varied between 205-272 seconds. In the ± 200 MW scenarios, the average mileage was 1,543,603 kW/day, and the DESS was idle for approximately 14.2 hours on average. Furthermore, the maximum idle duration period varied between 641-673 seconds. Maximum ramp-up and ramp-down rates experienced by the DESS were similar for both testing configurations. Moreover, the maximum amount of required charge and discharge energy along with the cumulative amount of energy absorbed or provided by the DESS appeared to be more dependent on the ACE signal and less on the dead-band setting.

Table 13: DESS Frequency Regulation Performance Statistics (3/4-3/5)

	± 100 MW ACE Dead-Band			± 200 MW ACE Dead-Band		
Starting Date	4-Mar	8-Mar	24-Mar	22-Mar	30-Mar	4-May
Mileage (kW/day)	2,102,876	1,873,935	2,059,944	1,597,289	1,556,917	1,476,602
Max Ramp Rate Up (kW/min)	24	19	18	19	19	18
Max Ramp Rate Down (kW/min)	-23	-18	-26	-19	-24	-19
% Time Spent Idle	33.1%	30.1%	31.3%	56.5%	58.8%	61.9%
Maximum Idle Duration Period (sec)	226	205	272	641	648	673
Maximum Required Charge Energy - 60 min (kWh)	748	680	735	545	494	515
Maximum Required Discharge Energy - 60 min (kWh)	439	505	507	357	135	342
Maximum Required Charge Energy - 30 min (kWh)	465	395	456	388	423	437

¹⁹ For an Inhibit or Trip Alarm, PCS reports the SOC and the maximum discharge capacity as 0.

²⁰ Mileage is the metric used to gauge the “stress” of the duty profile imposed on the battery. It is the cumulative sum of the absolute value of the change in PCS power settings from one time step to the next. As a reference, a repeating 24-hr duty profile consisting of 5 minutes at 1,000 kW, 5 minutes at 0 kW, 5 minutes at -1,000 kW, and 5 minutes at 0 kW has a mileage of 288,000 kW/day.

	± 100 MW ACE Dead-Band			± 200 MW ACE Dead-Band		
Starting Date	4-Mar	8-Mar	24-Mar	22-Mar	30-Mar	4-May
Maximum Required Discharge Energy - 30 min (kWh)	447	338	323	206	167	340
Maximum Required Charge Energy - 15 min (kWh)	252	250	249	251	251	244
Maximum Required Discharge Energy - 15 min (kWh)	258	223	229	233	146	256
24-Hr Cumulative Energy Usage (kWh)	3,466	1,514	2,991	2,241	3,947	2,205
Total Battery Ampere-Hour Discharge (DC Ah)	10,912	13,190	11,360	6,287	4,635	5,875

Figure 28 displays the energy requirements of the DESS and its corresponding change in state of charge for the 3/4-3/5 testing period. As shown in the figure, over the 24-hour period the DESS received a net charge of approximately 3,500 kWh. However, the DESS was never unable to provide either regulation-up or regulation-down capability at its nominal capacity due to energy limitations.




Figure 28: Frequency Regulation Energy Requirements and DESS SOC (3/4-3/5)

However, this was not the case for all the testing periods. Figure 29 displays the energy requirements of the DESS and its corresponding change in state of charge for the 3/24-3/25 testing period. From 6:39-8:34, the DESS was unable to provide full regulation-down capability due to the charging restraints employed by the NGK battery controller whenever the battery approaches a full state of charge. At 6:39 with a SOC of 96.4%, the maximum charge capacity of the DESS reduced to 962 kW. At 6:51 with a SOC of 97.2%, it dropped to 825 kW. Fortunately, the regulation set-points started to instruct the DESS to discharge, which alleviated the energy

constraint. At 8:32 with SOC of 92.6%, the maximum charge capacity increased back up to 962 kW; and, at 8:34 with a SOC of 93.3%, full charge capacity was restored.




Figure 29: Frequency Regulation Energy Requirements and DESS SOC (3/24-3/25)

Table 13 lists the maximum required amount of charge and discharge energy required over any continuous 15-, 30-, and 60-minute period for each testing period. For the 3/4/2010 testing period, the 60-minute charging energy requirement was 748 kWh and occurred from 16:05-17:04, while the 60-minute discharging energy requirement was 439 kWh and occurred from 19:20 to 20:19. Note that the 30-minute discharging energy requirement (447 kWh), which happened from 23:08-23:37, is larger than the 60-minute energy requirement. This phenomenon is explained by Figure 30, which displays the time intervals during which the maximum 60-minute (on the left) and 30-minute (on the right) discharge periods occurred. Unlike the 60-minute interval, there was a 30-minute interval during the testing period containing a minimal amount of charging, resulting in the larger energy requirement.




Figure 30: Maximum Discharge Energy Requirements (3/4-3/5)

As with all generating units on AGC, no unit exactly follows its requested set-point the instant it is issued. Although it is difficult to perceive in Figure 27, there was a slight, but persistent, delay of about 4-8 seconds between the time when the NSP EMS issued a set-point and when the DESS charged or discharged at the specified rate. Analysts are unable to determine the system or communication link that was the primary contributor to this latency. Moreover, there were other instances in which the DESS did not charge and/or discharge exactly at the expected magnitude and/or time. To gauge the ability of the DESS to follow the frequency regulation signal, analysts calculated the percentage of issued set-points that the DESS was able to meet for varying amounts of allowed deviation in magnitude, as shown in Figure 31. For example, with an allowed deviation of ± 100 kW, the DESS was able to successfully meet 78-80% and 84-86% of the set-points for the ± 100 MW and ± 200 MW scenarios, respectively. Because of the aforementioned latency, there will always be a residual amount of error for the DESS as displayed by the asymptotic behavior of the line charts in Figure 31.




Figure 31: Accuracy and Responsiveness of DESS to Regulation Dispatch Signal

The type and magnitude of impact on the overall performance of the DESS as a result of the duty profiles imposed on the unit during the Frequency Regulation mode of operation is uncertain at this time. Project analysts are uncertain if the traditional definition of cycle usage used by NGK (as described in the battery technology overview on page 83) is adequate in assessing the effective usage of the battery during this mode of operation. Table 13 lists the total amount of DC ampere-hours discharged from the battery during each testing period. For each one of the ± 100 MW scenarios, the equivalent cycle usage of the battery according to the NGK algorithm was 1 cycle²¹. For the ± 200 MW scenarios, the equivalent cycle usage of the battery varied between 0.55-0.68 cycles. Project analysts suspect that this cycle calculation method is unlikely to be an accurate depiction of the wear-and-tear on the battery while in this mode because it is solely dependent on the amount of energy discharged and does not account for the corresponding power profile imposed on the battery.

Because frequency regulation is the most expensive ancillary service, it provides participants in the ancillary service market with the greatest financial return in the short-term. However, a

²¹According to NGK, the nominal discharge capacity of the 1 MW NaS battery is 13,200 Ah

market participant should first understand the long-term impacts of this type of operation on the stored energy resource (SER) before makes any significant investment in the technology. Only after this information is ascertained will the asset owner be able to determine if this operational mode is still cost-effective overall in the long run. The University of Minnesota will perform a preliminary investigation on this topic and report on its findings in their report to Xcel Energy, which is scheduled to be delivered June 2011.

Conclusions

The DESS performed well in the Frequency Regulation mode of operation. Despite a delay of 4-8 seconds in the routing of the signal, the storage device responded promptly and accurately once it did receive the control set-point. When providing regulation, the DESS displayed excellent ramping capabilities on a continuous basis by being able to effectively follow the rapidly changing set-points that NSP EMS issued. Additional testing and close collaboration with NGK is required to assess the impact this mode has on the long-term performance and lifespan of the unit. Once greater clarity around this issue is obtained, a market participant can weigh the risk of degradation in future system performance and/or expected life with the value obtained by offering the unit to provide regulating reserves in MISO's Ancillary Service Market (ASM). Xcel Energy has plans to officially submit the DESS into the MISO ASM in the summer of 2010 and will report on the results.

Table 14 lists the system performance data of interest for the Frequency Regulation testing period. The average mileage of the DESS was 1,777,928 kW/day. The battery never exceeded more than one discharge cycle in any given day, averaging 0.81 cycles over the two testing variations. The average daily auxiliary energy requirement was 500 kWh/day. The overall efficiency of the DESS with and without the auxiliary energy requirements averaged 78.9% and 86.8%, respectively.

Table 14: Frequency Regulation System Performance Data Statistics Summary

Mode	ACE Dead-band	Mileage (kW/day)	Daily Discharge Cycle Usage	Aux Energy Requirement (kWh/day)	η_1	η_2
Frequency Regulation	100	2,012,252	1.00	309	83.2%	86.1%
Frequency Regulation	200	1,543,603	0.63	690	74.6%	87.4%

Wind Smoothing

Introduction

Another value proposition in the W2B Test Plan is to evaluate the ability of large-scale battery storage technology to reduce the variability in power output from a wind facility. Project analysts used the Wind Smoothing mode to test this proposition by using a 1st order lag function to vary the charging and discharging rates of the battery based on the output of the effective wind farm. Project analysts tested the battery in this mode for multiple installed wind capacity scenarios and multiple ramping constraints scenarios. Below is a description of a system performance data collected for a select number of ramping events encountered during the testing period. Additional data is included at the end of this section, beginning on page 52.

Theory

In this mode of operation, the PCS attempts to maintain the ramp rate of the effective wind farm to within a user-specified limit by using the battery to counter increases or decreases in wind power output. By doing so, system operators can be allotted additional time to react to changes in the wind output, which result in greater grid reliability and more efficient dispatch decisions.

For this mode of operation, S&C implemented a first-order lag function algorithm for the smoothing logic that resides on the PCS²². In the algorithm, a user effectively dictates the tolerance on the allowed ramping rate by specifying the time constant input parameter, which has units of minutes. According to NGK, the time constant effectively serves as the reciprocal of the ramping rate limitation (% of installed capacity/min). For example, a ramping limitation of 2%/min will require a time constant of 50 min. Below is a description of the logic utilized by the PCS for the wind smoothing mode, as provided by S&C. The PCS still honors all charging and discharge constraints for the storage device while in this mode.

The concept behind wind smoothing is that wind is a rapidly changing resource. This results in a 'noisy' power output. Using a battery, the output of the wind turbine or wind farm can be smoothed by taking power over the average and putting it into a battery, and taking power below the average and supplying battery energy. This results in a smooth output. [S&C Electric, Introduction to Wind Smoothing Logic]




Figure 32: Block Diagram of Wind Smoothing Logic

²² Logic residing on the PCS requires that the initial SOC of both modules be 50% for this mode. Therefore, if the battery is put into Wind Smoothing mode but does not meet this requirement, the PCS charges or discharges each module string at its maximum allowed rate, accordingly, until it satisfies this requirement. The PCS registers this as the “Pre-Wind Smoothing” mode.

Wind power from the wind turbine comes in on the left top of the diagram in Figure 32. It is in per unit (PU) values, where 1PU is the rating of the battery (not the wind farm). A low pass filter (moving average) is done on the wind power giving SmoothedWindPower.

Below the wind power are the SOC set point and the average SOC of the battery strings. If the average SOC is below the average (40% vs. 50%) we generate a recovery power, in this case 10% times the proportionally constant (Kp) of -1 or -10% (-0.1PU). In this case -.1 asks for the battery to charge at 10% to bring the SOC back to the SOCSetPoint with the result of SOCRecoveryPower.

SOCRecoveryPower is added to the SmoothedWindPower as the desired output of the combined wind farm and battery. The actual wind power is subtracted from the desired output and the error is sent to the battery system as the commanded wind power. So if the desired output is 5MW, and the wind power is 5.5MW, the result is -0.5MW or a charge power of 500kW. This should result in a combined output of 5MW, 5.5MW from the turbine, and - 0.5MW from the battery. [S&C Electric, Wind Smoothing Logic]

Performance Data²³

Project analysts tested the DESS in the Wind Smoothing mode for a total of 18 days. For each installed wind capacity scenario (i.e. 1, 5, and 10 MW), project analysts selected a time constant of 20, 40, and 60 minutes. Each configuration of the storage unit was tested for approximately a two-day period, gathering data at a 10-second resolution. After initial analysis by project analysts, S&C uncovered a major error in its smoothing code that resulted in improper operation for larger time constant values. In addition, analysts detected several other errors in the smoothing code. As a result, analysts deemed multiple time periods in each dataset as invalid. For purposes of this initial analysis, project analysts filtered through the raw files and analyzed only valid sections. Xcel Energy is working with S&C to correct these source code errors so that the updated operating software will resolve these bugs. The following is a description of a portion of the testing data analyzed for the 20 minute time constant scenario. Testing data for the other configurations is not listed due to the detected errors.

Figure 33 displays a portion of the performance data for the 20 minute time constant scenario. For the time period shown, the DESS was able to smooth out the wind output as expected for the given time constant setting a majority of the time. However, there were instances in which the smoothing capability of the unit was limited as a result of its power rating. At around 01:45 and again at 03:20, the ramp-up rate of the effective wind farm exceeded the maximum charging capacity of the DESS. Consequently, the ability of the DESS to limit the ramp rate of the wind farm to within the desired limit was compromised. From 4:35-5:50, the DESS again experienced a longer time period in which it was forced to operate at its maximum charging capacity. Starting at 6:30, the scaled wind farm gradually ramped down its production over the course of the next 7 hours. During that time, the DESS was able to effectively limit its ramping rate as expected for a majority of the time with a few instances in which it was operating at its maximum discharge rating.

²³ Although, Xcel Energy performed a preliminary investigation of this mode of operation, the University of Minnesota is contracted to provide a more detailed analysis. Xcel Energy is scheduled to receive the final deliverable for that analysis in June 2011.




Figure 33: Time Constant = 20 min; Scaling Factor = 43.3% (2/1)

Table 15 and Table 16 list the ramping statistics of the Effective Wind, Total, and the DESS data variables for a selected number of ramping cases experienced during the testing period. The ramp-up event shown in Figure 33 is listed as ID 8. Over the course of 75 minutes, the wind farm increased its output nearly 3,000 kW, resulting in an average rate of change of 39 kW/min. Moreover, the maximum instantaneous rate of change during this event was 134 kW/min. In response, the DESS increased its charging rate by nearly a 1,000 kW, which resulted in a reduction of 13 kW/min and 56 kW/min in the average and instantaneous rate of change in the combined power output, respectively.

As stated previously, the desired objective for this mode of operation is to provide system operators with greater flexibility when accommodating the variability in wind by reducing the magnitude of the ramp event and extending the time over which the change in power output occurs. To measure this benefit, project analysts calculated the correlation between the Effective Wind and Total data series for each defined ramp event and listed the value in Table 16. A large positive correlation is undesirable because that signifies that the Effective Wind and Total variables are moving in unison, thus providing grid operators with little to no additional time to make and execute improved dispatch decisions. For the ramp-up event from 4:35-5:50, the correlation was 0.94, which was expected due to the similar nature of the two data series, as shown in Figure 33. The high correlation value was the result of the aforementioned constraint

on charging capacity as well as the specified time constant value being too tolerant of changes in the wind output²⁴.

As the scaled wind farm began to gradually decrease its output in the right half of Figure 33, there were a series of smaller ramp-up and ramp-down events interspersed throughout. Starting at 9:15, a ramp-down event occurred (ID #11), as the scaled wind farm decreased its output from -3,440 kW to -1,959 kW over the course of 20 minutes. Consequently, the average and maximum rate of change was 74 kW/min and 107 kW/min, respectively. However, with the DESS going from slightly charging (234 kW) to discharging near its full capacity (-950 kW), the grid saw a net change in power of only 297 kW, which resulted in an average rate of change of 15 kW/min and a maximum rate of change of 30 kW/min. The correlation between the Effective Wind and Total data series during this ramping period was 0.80.

Immediately after this ramp-down event, the wind farm underwent a brief ramp-up event (ID #12) in which the power increased by approximately 880 kW. The DESS responded by going from discharging at 950 kW to charging at 88 kW. As a result, the average rate of change in the combined power output was 8 kW/min and the correlation between the Effective Wind and Total data series was -0.71, signifying that the two variables were actually trending in opposite directions (i.e. one was increasing while the other was decreasing).

²⁴ Lower correlation values are expected for higher time constant settings.

Table 15: Effective Wind and Total Ramping Statistics for Selected Ramping Periods

ID	Start Time (CT)	End Time (CT)	Duration (min)	Direction	Effective Wind					Total				
					Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)	Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)
1	2/15/10 17:05	2/15/10 17:40	35	down	-991	-645	346	10	23	-722	-745	-23	1	3
2	2/15/10 17:45	2/15/10 18:20	35	up	-697	-986	-289	8	18	-730	-743	-13	0	4
8	2/1/10 4:35	2/1/10 5:50	75	up	-1805	-4751	-2946	39	134	-1843	-3800	-1957	26	78
9	2/1/10 6:50	2/1/10 7:10	20	down	-4074	-3099	975	49	126	-4097	-3747	350	17	32
10	2/1/10 7:10	2/1/10 7:30	20	up	-3099	-4128	-1028	51	64	-3747	-3755	-7	0	13
11	2/1/10 9:15	2/1/10 9:35	20	down	-3440	-1959	1481	74	107	-3206	-2909	297	15	30
12	2/1/10 9:35	2/1/10 9:55	20	up	-1959	-2837	-877	44	94	-2909	-2749	161	8	13
18	1/23/10 10:20	1/23/10 12:15	115	down	-8551	18	8569	75	286	-8698	-1081	7617	66	286
26	1/24/10 8:40	1/24/10 9:35	55	up	-2067	-5624	-3557	65	188	-2320	-4455	-2135	39	173
27	1/24/10 10:25	1/24/10 11:20	55	up	-5740	-9768	-4029	73	223	-5543	-8598	-3056	56	155

Table 16: DESS Ramping Statistics for Selected Ramping Periods

ID	Start Time (CT)	End Time (CT)	Duration (min)	Direction	DESS								
					Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)	Delta SOC	Scaling Factor	Time Constant (min)	Correlation
1	2/15/10 17:05	2/15/10 17:40	35	Down	269	-100	-369	11	24	0.40%	8.7%	20	-0.05
2	2/15/10 17:45	2/15/10 18:20	35	Up	-33	243	276	8	18	0.60%	8.7%	20	0.21
8	2/1/10 4:35	2/1/10 5:50	75	Up	-38	951	989	13	76	9.60%	43.3%	20	0.94
9	2/1/10 6:50	2/1/10 7:10	20	Down	-23	-648	-625	31	107	-2.00%	43.3%	20	0.50
10	2/1/10 7:10	2/1/10 7:30	20	Up	-648	373	1021	51	61	-0.30%	43.3%	20	0.11
11	2/1/10 9:15	2/1/10 9:35	20	Down	234	-950	-1184	59	95	-1.30%	43.3%	20	0.80
12	2/1/10 9:35	2/1/10 9:55	20	Up	-950	88	1038	52	107	-1.10%	43.3%	20	-0.71
18	1/23/10 10:20	1/23/10 12:15	115	Down	-147	-1099	-952	8	93	20.80%	86.6%	20	0.99
26	1/24/10 8:40	1/24/10 9:35	55	Up	-253	1169	1422	26	80	5.50%	86.6%	20	0.92
27	1/24/10 10:25	1/24/10 11:20	55	Up	197	1170	973	18	100	9.20%	86.6%	20	0.95

Figure 34 displays a portion of the performance data for the 1 MW installed wind capacity scenario. Because of the smaller effective wind farm size, the DESS was able to effectively limit the variability in power output during a brief ramp-up event followed closely by a brief ramp-down event (ID #1 and 2). From 17:05-17:40, the scaled wind farm reduced its output approximately 350 kW. The average rate of change for the scaled wind farm during this ramp-down event was 10 kW/min, and the maximum rate of change was 23 kW/min. However, the average and maximum rate of change in the combined output was 1 kW/min and 3 kW/min, respectively. The correlation between the Effective Wind and Total data series was -0.05. From a system dispatch perspective, there was effectively no change in the output of the scaled wind farm, thereby minimizing the need to deviate from the current generation schedule.




Figure 34: Time Constant = 20 min; Installed Wind Capacity = 1 MW (2/15)

Figure 35 displays a portion of the performance data for the 10 MW installed wind capacity scenario. Unlike the 1 MW scenario, the DESS was unable to effectively limit the ramping rate of the scaled wind farm during a series of ramp-up events that occurred during the morning hours of 1/24/2010 (ID #26 and #27). Starting at 8:40, the scaled wind farm increased its output more than 3,550 kW over a span of 55 minutes. The average rate of change was 65 kW/min, and the maximum rate of change was 188 kW/min. In response, the DESS went from discharging at 250 kW to charging at or near its maximum allowed charge rate of 1,100 kW. Even though the DESS reduced the average rate of change to 39 kW/min, it was only able to reduce the maximum rate of change that the grid experienced to 173 kW/min. As illustrated by the figure, the Effective Wind and Total data series were highly correlated for this ramp event with a correlation value of 0.92. Thus, a grid operator would not be allotted much additional time to identify a more efficient dispatch decision during this ramping event. For the second ramp-up event from 10:25 to 11:20, project analysts calculated similar results, as shown in the tables.




Figure 35: Time Constant = 20 min; Installed Wind Capacity = 10 MW (1/24)

Figure 36 displays another portion of the performance data for the 10 MW installed wind capacity scenario. Again, the DESS was unable to effectively limit the ramping rate of the scaled wind farm for the ramp-down event that occurred from 10:20-12:15 on 1/23/2010 (ID #18). Over the course of nearly two hours, the wind farm decreased its output by approximately 8,500 kW, resulting in an average rate of change of 75 kW/min²⁵. To limit the change in output of the wind facility, the DESS increased its discharging rate in response. Before 11:30, the DESS discharged at its maximum rate intermittently. After 11:30, it discharged at 1,100 kW for nearly the remainder of the ramping event. Again, the DESS reduced the average rate of change for the ramp event to 66 kW/min but was not able to affect the maximum rate of change (286 kW/min). In addition, due to the prolonged ramp rate period, the SOC of the battery fell 21%, from 79.9% to 58.9%. The correlation for the Effective Wind and Total data series for this ramp-down event was 0.99, again not providing grid operators with much additional time. To decrease the correlation value, a larger time constant and greater storage capacity is required.




Figure 36: Time Constant = 20 min; Installed Wind Capacity = 10 MW (1/23)

The results of work by University of Minnesota in this area can be found in Appendix 1.

²⁵ At 12:15, MWD incurred an unexpected, brief outage that lasted approximately 15 minutes.

Conclusions

For select periods of time, the DESS performed as expected in the Wind Smoothing mode of operation for the 20 minute time constant scenario. For the 40 and 60 minute scenarios, project analysts deemed the data sets invalid due to the degree of errors detected in the data.

The DESS was able to effectively limit the rate of change in the effective wind farm for the ramping events encountered in the 1 MW scenario. However, for the 10 MW scenario, the rate of change in the scaled wind farm encountered by the DESS during the testing period was too great for it to effectively handle. For the 5 MW wind scenario, the DESS was successful in limiting the ramp rates of some events but not for others.

Once the errors in the source code are corrected by S&C, project analysts need to conduct additional analysis for this mode of operation, especially for the 5 MW wind capacity scenario. In addition, project analysts need to determine the most appropriate time constant setting based on the needs of the system, and evaluate the potential of encountering energy-constrained scenarios while the DESS provides the wind smoothing function.

Table 17 lists the system performance data of interest for the Wind Smoothing testing period. The average mileage of the DESS was 467,745 kW/day. The battery never exceeded more than one discharge cycle in any given day, averaging 0.41 cycles over the three testing variations. The average daily auxiliary energy requirement was 928 kWh/day. The average overall efficiency of the DESS with and without the auxiliary energy requirements averaged 72.5% and 89.6%, respectively.

The University of Minnesota analyzed this further and determined that the optimal storage to wind ratio for generation shifting would also be suitable for limiting the ramp rate of wind generation. Moreover, these two tasks could be combined for maximum benefit to the system.

Table 17: Wind Smoothing System Performance Data Statistics Summary

Mode	Installed Wind Capacity (MW)	Time Constant (min)	Mileage (kW/day)	Daily Discharge Cycle Usage	Aux Energy Requirement (kWh/day)	η_1	η_2
Wind Smoothing	1 MW	20	132,463	0.06	1,193	67.4%	90.8%
Wind Smoothing	5 MW	20	239,510	0.23	1,057	69.0%	90.3%
Wind Smoothing	10 MW	20	1,031,262	0.95	533	81.2%	87.8%

Table 18: Effective Wind and Total Ramping Statistics for all Ramping Periods

ID	Start Time (CT)	End Time (CT)	Duration (min)	Direction	Effective Wind					Total				
					Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)	Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)
1	2/15/10 17:05	2/15/10 17:40	35	down	-991	-645	346	10	23	-722	-745	-23	1	3
2	2/15/10 17:45	2/15/10 18:20	35	up	-697	-986	-289	8	18	-730	-743	-13	0	4
3	2/15/10 21:40	2/15/10 22:40	60	down	-883	-554	330	5	20	-816	-789	28	0	7
4	2/16/10 5:25	2/16/10 6:35	70	up	-215	-647	-431	6	20	-237	-261	-23	0	3
5	1/31/10 20:00	1/31/10 20:30	30	up	-164	-1028	-863	29	56	-330	-377	-46	2	24
6	1/31/10 22:20	1/31/10 22:50	30	up	-457	-2573	-2116	71	119	-232	-1374	-1142	38	87
7	1/31/10 23:00	1/31/10 23:35	35	down	-2256	-955	1301	37	76	-1401	-1277	124	4	18
8	2/1/10 4:35	2/1/10 5:50	75	up	-1805	-4751	-2946	39	134	-1843	-3800	-1957	26	78
9	2/1/10 6:50	2/1/10 7:10	20	down	-4074	-3099	975	49	126	-4097	-3747	350	17	32
10	2/1/10 7:10	2/1/10 7:30	20	up	-3099	-4128	-1028	51	64	-3747	-3755	-7	0	13
11	2/1/10 9:15	2/1/10 9:35	20	down	-3440	-1959	1481	74	107	-3206	-2909	297	15	30
12	2/1/10 9:35	2/1/10 9:55	20	up	-1959	-2837	-877	44	94	-2909	-2749	161	8	13
13	1/22/10 13:20	1/22/10 14:25	65	up	-2920	-6827	-3907	60	181	-2837	-5658	-2821	43	114
14	1/22/10 17:15	1/22/10 17:35	20	down	-7274	-2475	4799	240	370	-7309	-3616	3693	185	332
15	1/22/10 17:40	1/22/10 17:55	15	up	-2671	-8498	-5827	388	643	-3770	-7299	-3529	235	411
16	1/22/10 17:55	1/22/10 18:05	10	down	-8498	-2679	5820	582	578	-7299	-3778	3522	352	349
17	1/22/10 18:15	1/22/10 19:25	70	up	-5527	-8460	-2933	42	327	-4529	-7255	-2726	39	196
18	1/23/10 10:20	1/23/10 12:15	115	down	-8551	18	8569	75	286	-8698	-1081	7617	66	286
19	1/23/10 16:15	1/23/10 17:30	75	up	-133	-2218	-2084	28	150	18	-1494	-1511	20	72
20	1/23/10 17:35	1/23/10 18:20	45	up	-1783	-5496	-3713	83	187	-1548	-4295	-2747	61	147
21	1/23/10 18:20	1/23/10 18:30	10	down	-5496	-3008	2487	249	258	-4295	-3792	502	50	49
22	1/23/10 18:30	1/23/10 20:00	90	up	-3008	-9801	-6793	75	348	-3792	-8601	-4809	53	251

					Effective Wind					Total				
ID	Start Time (CT)	End Time (CT)	Duration (min)	Direction	Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)	Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)
23	1/24/10 1:15	1/24/10 2:30	75	down	-8856	-3304	5552	74	263	-9154	-4404	4750	63	250
24	1/24/10 2:40	1/24/10 3:45	65	up	-3431	-9335	-5904	91	268	-4530	-8136	-3606	55	202
25	1/24/10 5:50	1/24/10 8:40	170	down	-9531	-2067	7464	44	205	-9328	-2320	7008	41	192
26	1/24/10 8:40	1/24/10 9:35	55	up	-2067	-5624	-3557	65	188	-2320	-4455	-2135	39	173
27	1/24/10 10:25	1/24/10 11:20	55	up	-5740	-9768	-4029	73	223	-5543	-8598	-3056	56	155

Table 19: DESS Ramping Statistics for all Ramping Periods

					DESS								
ID	Start Time (CT)	End Time (CT)	Duration (min)	Direction	Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)	Delta SOC	Scaling Factor	Time Constant (min)	Correlation
1	2/15/10 17:05	2/15/10 17:40	35	Down	269	-100	-369	11	24	0.40%	8.7%	20	-0.05
2	2/15/10 17:45	2/15/10 18:20	35	Up	-33	243	276	8	18	0.60%	8.7%	20	0.21
3	2/15/10 21:40	2/15/10 22:40	60	Down	67	-235	-302	5	19	-0.60%	8.7%	20	0.33
4	2/16/10 5:25	2/16/10 6:35	70	Up	-22	386	408	6	20	2.20%	8.7%	20	0.64
5	1/31/10 20:00	1/31/10 20:30	30	Up	-166	651	817	27	42	0.80%	43.3%	20	0.43
6	1/31/10 22:20	1/31/10 22:50	30	Up	225	1199	974	32	59	4.10%	43.3%	20	0.95
7	1/31/10 23:00	1/31/10 23:35	35	Down	855	-322	-1177	34	79	0.30%	43.3%	20	0.53
8	2/1/10 4:35	2/1/10 5:50	75	Up	-38	951	989	13	76	9.60%	43.3%	20	0.94
9	2/1/10 6:50	2/1/10 7:10	20	Down	-23	-648	-625	31	107	-2.00%	43.3%	20	0.50
10	2/1/10 7:10	2/1/10 7:30	20	Up	-648	373	1021	51	61	-0.30%	43.3%	20	0.11
11	2/1/10 9:15	2/1/10 9:35	20	Down	234	-950	-1184	59	95	-1.30%	43.3%	20	0.80
12	2/1/10 9:35	2/1/10 9:55	20	Up	-950	88	1038	52	107	-1.10%	43.3%	20	-0.71
13	1/22/10 13:20	1/22/10 14:25	65	Up	83	1169	1086	17	112	12.20%	86.6%	20	0.97
14	1/22/10 17:15	1/22/10 17:35	20	Down	-35	-1141	-1106	55	80	-4.30%	86.6%	20	0.98
15	1/22/10 17:40	1/22/10 17:55	15	Up	-1099	1199	2298	153	233	-1.00%	86.6%	20	0.92

					DESS								
ID	Start Time (CT)	End Time (CT)	Duration (min)	Direction	Initial kW	Final kW	Delta kW	Avg Slope (kW/min)	Max Slope (kW/min)	Delta SOC	Scaling Factor	Time Constant (min)	Correlation
16	1/22/10 17:55	1/22/10 18:05	10	Down	1199	-1099	-2298	230	231	-0.40%	86.6%	20	0.95
17	1/22/10 18:15	1/22/10 19:25	70	Up	998	1205	207	3	240	8.10%	86.6%	20	0.84
18	1/23/10 10:20	1/23/10 12:15	115	Down	-147	-1099	-952	8	93	- 20.80%	86.6%	20	0.99
19	1/23/10 16:15	1/23/10 17:30	75	Up	151	724	573	8	80	8.70%	86.6%	20	0.96
20	1/23/10 17:35	1/23/10 18:20	45	Up	235	1201	966	21	120	8.60%	86.6%	20	0.98
21	1/23/10 18:20	1/23/10 18:30	10	Down	1201	-784	-1985	198	230	0.60%	86.6%	20	0.58
22	1/23/10 18:30	1/23/10 20:00	90	Up	-784	1200	1984	22	134	11.70%	86.6%	20	0.98
23	1/24/10 1:15	1/24/10 2:30	75	Down	-298	-1100	-802	11	138	- 14.40%	86.6%	20	0.98
24	1/24/10 2:40	1/24/10 3:45	65	Up	-1099	1199	2298	35	134	10.60%	86.6%	20	0.97
25	1/24/10 5:50	1/24/10 8:40	170	Down	203	-253	-456	3	134	- 25.80%	86.6%	20	0.98
26	1/24/10 8:40	1/24/10 9:35	55	Up	-253	1169	1422	26	80	5.50%	86.6%	20	0.92
27	1/24/10 10:25	1/24/10 11:20	55	Up	197	1170	973	18	100	9.20%	86.6%	20	0.95

Dispatched Wind Leveling

Introduction

One of the value propositions in the W2B Test Plan is to evaluate the ability of large-scale battery storage technology to reduce the uncertainty of a variable generation resource. In the Wind Leveling mode, the DESS was used to hedge against error in the power forecast for the effective wind farm, thereby minimizing the impacts of uncertainty on the system. During this mode, the storage device varied its charging and discharging operations to minimize the difference between the expected and actual power output for the wind facility. Project participants tested this mode for each installed wind capacity scenario using a persistence forecast²⁶.

Theory

Similar to conventional generators, wind facility operators, as MPs in the MISO market, must schedule the energy output from their facility with system operators. A MP has the option of scheduling the forecasted output of their wind facility in either the DA or RT market. Xcel Energy submits their wind into the DA market; and like all DA participants, Xcel Energy must submit their DA bids no later than 10:00 AM (CST) for the next operating day. Thus, when bidding wind in the DA market, MPs must forecast their wind output up to 38 hours in advance. As already confirmed by several studies, wind speeds and power forecast errors increase with forecast lead time [Ortech Power, NERC]. The benefit of using energy storage for wind leveling, therefore, becomes more valuable for longer forecast horizons.

Additionally, as discussed in the Economic Dispatch section, if the forecasted amount of wind energy deviates from the actual amount, the MP is forced to true up their position in the RT market. Although this true up process may or may not be at uneconomical prices, there is a large degree of uncertainty in the process and that uncertainty exposes the MP to market risk.

Furthermore, although renewable generation resources are not currently susceptible to RSG charges, MISO may alter their energy tariff in the future to start assigning these charges to wind facility operators for activity in the RT market. Therefore, in the future, it may become more important for a MP to have an accurate wind energy forecast for market settlement purposes.

For the Wind Leveling mode of the DESS, a user specifies the desired power output value for the effective wind farm. As the actual power output from the scaled farm deviates from the desired (i.e. scheduled) value, logic residing on the PCS commands the battery to charge and discharge to compensate for the difference. For example, if the forecast under-predicts the actual output of the scaled wind farm, the DESS will charge at a rate that minimizes the scheduling error. Likewise, if the forecast over-predicts the actual output of the scaled wind farm, the DESS will discharge at a rate that minimizes the scheduling error.

While in this mode, the user monitors the output of the MWD site in real-time. In the event of significant deviations between the scheduled and actual values, the user will update the desired power set-point to minimize the mismatch and conserve battery operation. Ideally, over time, the amount of energy over-forecasted will be approximate to the amount of energy under-forecasted,

²⁶ Herein, persistence forecasting refers to using current power output to forecast future output.

thereby keeping the SOC of the battery near 50%. The PCS still honors all charging and discharge constraints for the storage device while in this mode.


Performance Data²⁷

Project analysts tested the battery in the Wind Leveling mode of operation over a period of six separate days for various durations ranging from 5.5 to 8.4 hours while collecting data at a resolution of one minute. Updating the desired combined power set-point every 30 minutes, researchers tested the battery for the 1, 5, and 10 MW installed wind capacity scenarios. The following is a description of a portion of the testing data analyzed by project analysts.

Figure 37 displays the scheduled and actual amounts of power from the wind generation facility when supported by the DESS for the 1 MW scenario, tested on 3/12 from 9:15-16:00. Figure 38, on the next page, gives a breakdown of the corresponding DESS operation and its SOC as well as the output from the effective wind farm for the same time period.

As illustrated, the DESS enabled the effective wind farm to follow the scheduled amount with minimal deviations. For example, from 10:15-10:45, the scheduled power output from the scaled farm was 80 kW. However, during that time, the effective wind farm increased its power output from roughly 80 kW to 430 kW. In response, the DESS increased its charge rate accordingly to accommodate the increase in power generation. At 10:45, the user updated the scheduled power output to 430 kW, which resulted in a reduction in the charging operation of the DESS as shown in Figure 38.

At no point during this testing period did the DESS operate at its maximum allowed rate. Thus, any deviations experienced were the result of latency in either the system architecture or the PCS. However, because the latency was minimal, project analysts were unable to detect the primary source. The average of the absolute value of the deviations for this testing period was 5



kW, and the maximum deviation was 41 kW. The SOC went from an initial value of 44.9% to a final value of 43.8%, indicating that the amount of over-forecasted energy was approximate to the amount of under-forecasted energy during the testing period.

²⁷ Although, Xcel Energy performed a preliminary investigation of this mode of operation, the University of Minnesota is contracted to provide a more detailed analysis. Xcel Energy is scheduled to receive the final deliverable for that analysis in June 2011.




Figure 38: DESS, Effective Wind, and SOC, 1 MW Installed Wind Capacity (3/12)

Figure 39 and Figure 40 display the same data series for the 5 MW scenario analysts tested on 3/9 from 13:00-19:00. Similar to before, the actual output closely followed the scheduled amount with assistance from the DESS. Unlike the 1 MW scenario, the DESS operated at its maximum rates while trying to minimize the mismatches between the scheduled amount and actual amount. However, the DESS was still able to continue having the effective wind farm follow its scheduled output. For this test, the average of the absolute value of deviations was 22 kW, and the maximum deviation was 323 kW. The SOC decreased 5.2% as it went from 50.1% to 44.9%, indicating that there was a slight bias in over-forecasting the power output from the scaled wind farm during the testing period.




Figure 39: Scheduled vs. Actual Wind Power Output, 5 MW Installed Wind Capacity (3/9)




Figure 40: DESS, Effective Wind, and SOC, 5 MW Installed Wind Capacity (3/9)

Figure 41 and Figure 42 display the testing results for the 10 MW scenario, conducted on 3/11 from 9:30-17:00. For this scenario, the variability from the 10 MW wind farm was more than the DESS could effectively handle for a portion of the testing period. For example, at 10:00, the user updated the scheduled output of the scaled farm from 3,600 kW to 4,300 kW. However, due to the steady increase in generation, the DESS was unable to hold that value after roughly 5 minutes as the scaled wind farm continued to increase its capacity while the DESS was already charging at its maximum capacity. At 10:30, the user again updated the scheduled output to 6,700 kW, but again, the continuous increase in power generation resulted in the DESS being unable to hold the scheduled value after approximately 5 minutes. At around 10:40, the effective wind farm began leveling off, so the magnitude of the deviation did not continue to increase as it had from 10:00 to 10:30. Analysts encountered similar behavior at 13:00 and again at 15:30 as the DESS discharged at its maximum capacity as a result of sharp drop-offs in wind power production.

The average of the absolute deviation values for this testing period was 178 kW, and the maximum deviation was 1,917 kW. Although the initial and final SOC values experienced a net change of only 1.1% during the testing period, the SOC experienced sizeable shifts due to the ramp-up from 9:30 – 11:00 (42.0% to 57.0%) and the ramp-down from 14:30 – 16:30 (53.3% to 43.5%).




Figure 41: Scheduled vs. Actual Wind Power Output, 10 MW Installed Wind Capacity (3/11)




Figure 42: DESS, Effective Wind, and SOC, 10 MW Installed Wind Capacity (3/11)

To gauge the ability of the DESS to have the effective wind farm follow the scheduled power output on a basis relative to the amount of installed wind capacity, project analysts calculated the percentage of deviations that were within a 2%, 5%, and 10% of installed wind capacity dead-band for each wind scenario²⁸. Table 20 lists the corresponding allowed deviation ranges (kW) for each installed wind capacity scenario.

²⁸ Researchers used absolute values for this analysis and thus did not differentiate between under-forecasted and over-forecasted data.

For example, if in the 1 MW wind scenario there was a deviation with an absolute value of 75 kW, the DESS would have been successful for the 10% criterion but not for the 2% or 5% cases since it exceeded the corresponding maximum allowed absolute values (20, 50 kW). As another example, if in the 10 MW scenario there was a deviation with an absolute value of 175 kW, the DESS would have been successful for all three cases (i.e., 2%, 5%, and 10%).

Figure 43 displays the results of this analysis for each of the six testing periods. Because of the larger allowed deviation range for the higher wind capacity scenarios, the results from the various wind scenarios were similar (sans the 3/11 testing date). At a 2% tolerance, at least 96% of the deviations for the 1 MW and 5 MW scenarios fell within the allowed range for the testing data collected. For the 10 MW scenario, the results varied significantly (97.2% and 76.3%), thus making it difficult to draw any conclusive results.

Table 20: Relative Allowed Deviations in Scheduled vs. Actual Wind Power as a Function of Wind Capacity

Allowed Deviation Range (\pm kW)			
	Allowed Deviation Percentage		
Installed Wind Capacity (MW)	2%	5%	10%
1	20	50	100
5	100	250	500
10	200	500	1,000




Figure 43: Percentage of Deviations within Allowed Range

Conclusions

Overall, the DESS performed well for the 1 MW and 5 MW testing periods. The results for the 10 MW scenario varied too much, preventing analysts from drawing any detailed insights. For all the scenarios, the DESS performed as expected, responding to changes in the output from the effective wind farm rapidly and accurately. The 1 MW DESS is effectively capable of leveling 1 MW of installed wind capacity. However, additional testing data is required for the 5 MW and 10 MW scenarios to better determine the leveling capability of the DESS for a more statistically valid set of wind profiles. In addition, project analysts should conduct additional testing for this mode, substituting forecasted values from the company's various wind forecasting programs for the scheduled output value and then evaluate the difference in results compared to the persistence methodology.

Table 21 lists the system performance data of interest for the Wind Leveling testing period. The average mileage of the DESS was 125,360 kW/day. The battery never exceeded more than one discharge cycle in any given day, averaging 0.56 cycles over the three testing variations. The average daily auxiliary energy requirement was 834 kWh/day. The average overall efficiency of the DESS with and without the auxiliary energy requirements averaged 67.6% and 91.6%, respectively.

Table 21: Wind Leveling System Performance Data Statistics Summary

Mode	Installed Wind Capacity (MW)	Mileage (kW/day)	Daily Discharge Cycle Usage	Aux Energy Requirement (kWh/day)	η_1	η_2
Wind Leveling	1 MW	34567	0.32	1230	44.2%	95.8%
Wind Leveling	5 MW	145723	0.54	344	83.3%	90.2%
Wind Leveling	10 MW	195791	0.82	929	75.3%	88.8%

DESS Operation Universal to All Modes of Operation

Xcel Energy's Transmission System Operations (TSO) department can issue either a VAR or voltage (for the low-side of the 480 V-34.5kV transformer) set-point using the company's EMS. The EMS sent the set-point to GridPoint which relayed it onto the PCS. If the PCS receives a kVA signal, it attempted to provide or absorb the requested amount of reactive power within its limits. If the DESS received a voltage signal, the unit provided the amount of reactive power required to hold the specified voltage within its limits. The total power rating of the DESS is 1.25 MVA. If this rating was exceeded due to the combination of requested power and reactive power, the DESS reduced its VAR output until the MVA was below its maximum rating.

General Conclusions and Lessons Learned

The previous sections have provided insights and conclusions related to specific modes of operation. The following is a list of the general conclusions related to the DESS as a whole, based on the tests conducted to date and the related testing conditions:

- ❑ The overall efficiency of the DESS, accounting for the auxiliary energy requirements, displayed considerable variation as a function of mode of operation, ranging from 67.6% to 78.9%.
- ❑ The efficiency of the DESS, not accounting for the auxiliary energy requirements, displayed less variation as a function of mode of operation, ranging from 85.1% to 91.6%.
- ❑ The DESS never exceeded more than one discharge cycle in any 24-hour period for any mode of operation.
- ❑ The DESS mileage varied significantly depending on the mode of operation. Based on the mileage metric, the Frequency Regulation mode of operation was the most aggressive mode while the Economic Dispatch mode was the least aggressive.

In addition, project analysts took a few moments to look back and answer the question “What should we have done differently?” Below are those observations as related to the system architecture, analytics, project siting and other lessons learned.

System Architecture

- ❑ When working with multiple data systems that interact with one another to varying degrees, it is critical to ensure that the method of connectivity between any two systems is compatible and within the original scope of work.

In regards to interfacing with a remote operator, S&C stated in their specification that the PCS was capable of supporting either the Distributed Network Protocol 3.0 (DNP3) or Modbus Plus (MB+) protocols for the SCADA interface. However, this requirement was not accounted for when Xcel Energy was in contract negotiations with GridPoint to provide their services to the project. Several months into the project, the communication team realized that the protocol GridPoint was planning on using to communicate with the PCS was not compatible with the PCS. As a result, GridPoint had to submit a change order request to Xcel Energy to revise its original plan and enable GridPoint to incorporate the DNP3 protocol into their servers. This added to the cost of the project and extended the project schedule by approximately 6 weeks.

- ❑ A first-of-a-kind control system covering multiple modes of operation spans a wide array of skill sets and requires an extensive amount of development time.

Project participants required an extensive amount of time to define in detail the various modes of operation, which required multiple iterations to the PCS specification and control set-points list. Consequently, S&C was delayed in beginning their required programming tasks by several weeks. Although the first iteration of the points list was issued in August of '08, the final version of the PCS specification was not completed until March '09. Although some work on the communication system was done in parallel to work on the modes of operation, the communication team was dependent on several of the functional requirements outlined by the operation modes. Thus, work on the communication system was also delayed.

- ❑ Once designed, a first-of-a-kind control system also requires an extensive amount of programming time and a thorough commissioning process.

After the design specification and control set-points list was finalized, S&C started to program the PCS, originally scheduling one month to complete the task. To minimize the amount of errors encountered in the field, S&C and GridPoint performed lab-to-lab testing over the course of several weeks to ensure data connectivity between the two systems. S&C also performed in-house testing of the software to minimize errors in the control logic²⁹. After the completion of these tasks, S&C installed the W2B software on the PCS at the project site in April 2010.

To verify the PCS operated according to the specification, Xcel Energy generated a field commissioning document³⁰. During the field testing procedures, project analysts encountered multiple errors that were not originally accounted for during the lab testing. To account for these errors, S&C responded by implementing an updated version of the software in July 2009. However, over the course of several months that followed, project analysts continued to find additional errors in the control logic as they explored each mode of operation in greater detail. Xcel Energy is working with S&C on correcting the identified errors and plans on uploading the newest software version in Q3 2010.

- ❑ Smart grid applications such as the W2B Project and others are changing the traditional utility IT paradigm in that network based equipment is now starting to make its presence out in the field. Therefore, it is important to develop a long-term strategy that outlines a formal procedure for installing and maintaining these types of devices in their new operating environments.

As mentioned in the description of some of the interfaces, the W2B communication team implemented Ruggedcom devices throughout the design of the system to enable the different components to communicate with one another. A RX1000 router, RS910 switch, and RS900 switch were installed at the Luverne site.

Prior to the project, Xcel Energy's Communication Infrastructure department was not familiar with these devices because Xcel Energy's preferred IT platform is CISCO. As a result, the department initially did not agree to assist with installing and supporting these devices. However, after discussing the matter, the Communication Infrastructure department agreed that the decision to go with Ruggedcom devices was appropriate for the given application.

Ultimately, engineers from Xcel Energy's Substation Engineering Design department installed the Ruggedcom devices at the site after working closely with support engineers from Ruggedcom over several days. However, ongoing support of the devices is still problematic in that the engineers familiar with these devices are located in Minneapolis.

- ❑ In order to utilize the full charge-discharge range of the battery (i.e. a swing from +1MW to -1MW and vice versa) when providing frequency regulation, the AGC system must be capable of issuing both positive and negative MW commands.

²⁹ S&C Electric Company. "Wind to Battery Software Factory Test Procedure (Version 4).

³⁰ Xcel Energy. "Wind-to-Battery Field Commissioning Testing".

During the design of the W2B communication system, the team realized that Xcel Energy's NSP EMS system could only send out a positive MW command to units on AGC control. Thus, the battery would have been unable to provide regulation both as a generator and as a load. As a result, the project team contacted Siemens, Xcel Energy's EMS provider, to determine the required programming changes that would enable the AGC system to issue both positive and negative MW commands. Because it was important to project sponsors to show the battery capable of providing frequency regulation both when it was charging and discharging, a Statement of Work between Xcel Energy and Siemens was drafted to perform the required code changes. After initial lab testing and field testing with the battery, the updated AGC code was successfully implemented in June 2009, approximately one month after its expected availability date. In addition to the month delay, the modification added to the project cost.

- ❑ Other lessons learned from the W2B project related to the communications and control architecture include the following:
 - Include in the points list a nominal maximum charge and discharge rate and an emergency charge and discharge capacity rate;
 - For each analog output set-point specify an allowed input range, data type, resolution, sign convention, scaling, and a master;
 - When implementing a control points list, be sure to include a read or “echo” on all analog outputs to verify that the correct value for each set-point has been issued;
 - When implementing a control points list, map all analog outputs to inputs so that a user can verify whether the unit has received and successfully administered the requests;
 - Provide whatever department that will be responsible for responding to system alarms with the desired level of detail on system status information;
 - The power electronics associated with an electrochemical storage device should include a generator droop response functionality to automatically respond to perturbations in grid frequency³¹;
 - Before a loss of communication alarm is issued, it first shall exceed a minimum time duration.
- ❑ As for the PCS control logic, project analysts have identified potential modifications for some of the modes of operation that could enhance their respective value.
 - While testing the Wind Smoothing mode, project researchers identified multiple periods in which the DESS was used to smooth volatility that was unlikely to result in difficulty for system operators. Thus, project researchers may want to work closely with S&C engineers to investigate other smoothing logic that still has the storage device supporting the wind facility during critical ramping events but remains idle during periods of temperate volatility. This modification would minimize battery operation and extend system life.

³¹ Currently, the DESS maintains a constant power output regardless of changes in grid frequency.

- For the Wind Leveling mode, project researchers recommend that an allowed dead-band be placed around the desired target level so that the DESS only operates when the absolute value of the deviations exceed a certain threshold. Again, because the grid can handle a certain amount of uncertainty (i.e. noise) in power output from any type of generating facility, there is not a strong system need to have a generator exactly follow its generation scheduled. By implementing this feature, DESS operation will be reserved for more critical times, thereby minimizing battery operation and extending system life. Furthermore, the control logic should be able to accept a schedule for a given forecast horizon and resolution that a user can specify upfront. This modification will avoid the limitation of requiring the user to manually update the set-point.

Analytics

- ❑ When defining a project test plan, researchers shall identify only the most appropriate and/or effective analytics approach for each value proposition in order to establish a plan that is reasonable in scope and yet extensive enough to cover important research areas.

Xcel Energy worked with internal and external analysts and researchers to identify multiple value propositions that warranted investigation for the W2B Project. While all the propositions were valid and justified, together they covered an expansive range of research topics concerning storage and wind energy. As a result, it was difficult for project researchers to identify the most appropriate and/or effective analytics approach for each value proposition.

Furthermore, once project researchers identified a method of analysis and began collecting data, it was readily apparent that additional time was required for the data gathering and analysis phase of the project to adequately cover each value proposition. In addition to the multiple modes of operation, project researchers encountered multiple errors in the datasets due to variety of reasons ranging from user input error, communication outages, and unexpected PCS operation. Regardless of the cause, each invalid dataset required project researchers to retest the battery, resulting in greater time requirements.

- ❑ Establish a central on-site data repository that collects data from all the appropriate sources with uniform time stamps.

For the W2B Project, GridPoint used the DNP3 protocol to collect and archive data, which project researchers then used in their analysis. However, because DNP3 is a polling protocol and can not simultaneously access two separate device, analysts were unable to work with time -synchronized data whenever they had to access two separate data sources. Because the difference in time stamps was only a few seconds, the impacts on data analysis was minimal. However, the impact on the project researchers' ability to troubleshoot the system was much greater.

- ❑ Conduct analyses on both simulated and empirical data.

For the wind-coupled modes (i.e., Basic GS, Wind Smoothing, and Wind Leveling), testing was dependent on the output of the scaled wind farm, which was never identical for any two given testing periods. Thus, it was difficult for project analysts to directly compare results from one day to another due to non-uniform testing conditions. One way in which project analysts can get around this limitation is by conducting a similar analysis on simulated data rather than just empirical data. NREL has developed a model of the NaS battery that will

enable Xcel Energy and other project participants to carry out this type of analysis if there is sufficient interest and resources.

- ❑ Other lessons learned from the W2B project related to analytics include the following:
 - If possible, explicitly measure the energy embedded in output of the effective wind farm;
 - On the user interface page for the Economic Dispatch mode, include information on the current price bin, SOC bin, and what market mode the DESS is operating under.

Project Siting and Logistics

- ❑ Although locating the battery next to a wind farm provided many benefits, the rural location of the project site introduced multiple logistical issues for project participants.

Luverne, MN is approximately a four hour drive from Minneapolis, MN, which is where Xcel Energy's Substation Design and Construction Department is located. This was the primary department involved in the installation and commissioning of the communication and control equipment for Xcel Energy. Due to the extended drive between the two locations, it was difficult to schedule time for Xcel Energy engineers to head out to the W2B site for the initial installation as well as to return to the site throughout the project whenever troubleshooting was required.

In addition, because of the remoteness of the location, Xcel Energy had difficulty agreeing upon an internal department that would provide on-site support. Ultimately, Xcel Energy's Angus Anson plant accepted this responsibility; however, being located in Sioux Falls, SD, they are still approximately 30 minutes away from the site.

By locating the battery in a more central location, project participants expect to see a reduction in down time during troubleshooting and more willingness from other internal departments to accept ownership responsibilities.

Other Lessons Learned

- ❑ When working with a team that consists of multiple departments and outside vendors, it is critical to clearly define roles and responsibilities at the onset.

Because no single department or organization had all the required knowledge, the project team consisted of multiple Xcel Energy departments and outside vendors. As a result, some of the project participants were uncertain about roles and responsibilities for each of the members, resulting in delay in the project schedule.

- ❑ When establishing long-term business arrangements with vendors, it is critical to establish fair but favorable business arrangements for the company that are mutually agreed upon and signed by both parties.

Xcel Energy originally selected V2Green to provide their Intelligent Distributed Generation Solution to the W2B Project. Although the initial agreement was only for the first year of operation, the tacit agreement between directors at Xcel Energy and V2Green was that due to the R&D nature of the project, in which both parties stood to benefit by acquiring additional knowledge, V2Green would continue to offer its services to Xcel Energy at a discounted rate.

However, in September 2008, GridPoint acquired V2Green, which brought in new GridPoint directors for the Xcel Energy account. During negotiations regarding the extension of GridPoint's services to the project, Xcel Energy believed that the new GridPoint directors did not acknowledge the nature of the original agreement when they submitted the proposal for extending their services. As a result, Xcel Energy investigated alternative control and data acquisition methods and decided to implement an in-house solution to replace GridPoint. Consequently, the amount Xcel Energy paid GridPoint only covered a service period of a little over a year, excluding any additional charges for change order. In addition, Xcel Energy had to spend additional funds to develop an in-house solution.

- ❑ When working with first-of-a-kind technology it is important to always account for both short-term and long-term ownership responsibilities.

For this project, there were two primary areas of ownership responsibility: 1) Activities related to providing on-site support for ongoing O&M procedures for the NaS battery, the PCS, and the communication system, and 2) Activities related to coordinating with Xcel Energy's TSO department and Minwind for system outages taken at the site.

To the extent possible, it is critical to identify the department(s) with this responsibility either at the outset of the project or as soon as logistically possible. Because it determines what alarms it wants to receive and how it goes about receiving said alarms, this department needs to be included in the design and implementation of the system architecture.

Furthermore, project participants need to work with the on-site responders to categorize the available alarms and define the appropriate responses for each type. Lastly, to avoid the risk of serious injury or death to support personnel, the department with ownership responsibilities needs to work with the TSO and other appropriate outside parties (i.e. Minwind) to define the protocol that is to be followed when scheduling an outage at the site.

Lessons Learned From the University of Minnesota Research

- ❑ Battery system performance is consistent with the manufacturer's representations. *Testing results largely confirm the claims made by NGK Insulators as to the expected performance, including: efficiency, responsiveness, charging and discharging times, operating temperatures, and system loads.*
- ❑ The optimum percentage of battery capacity to wind farm capacity (for the Luverne, MN battery system and wind conditions) appears to be between 20% and 40%, based on arbitrage value, offering such a generation resource for 6 peak load hours every day. *This suggests that a storage system capacity between 2.3 MW and 4.6 MW would be optimum for capturing off-peak wind energy coming from the MinWind 11.5 MW wind farm. Having more storage capacity would have diminishing returns with respect to arbitrage value, and having less would not be able to capture enough off-peak wind on average.*
- ❑ Within that optimum percentage range, the battery system should be suitable to simultaneously perform both arbitrage and a ramp-rate control functions, thereby increasing its value. *This suggests that a battery system could be used both for smoothing a wind resource's output ramp rate and providing a time shift/arbitrage function with the same system during the same time periods, which would create more value for grid than would be possible by operating the system exclusively in one mode or the other.*

- ❑ Under today's MISO market rates and conditions, offering the battery system in the ancillary services market is expected to deliver more revenue than operating the system for arbitrage value. *Best case economic analyses for the economic dispatch and the ancillary services operational options resulted in total battery system life revenues of \$1.6 million and \$2.4 million, respectively, under today's MISO rates and conditions for this type of energy storage system.*

Usefulness of the Information Gained

Xcel Energy is grateful to the Renewable Development Fund for supporting our Wind-To-Battery energy storage demonstration. The Company, the utility industry, the wind energy industry, and the energy storage industry (nationally and internationally) have all benefited from the information gained from this project

- ❑ We have proven that this type of storage technology can perform functions that can help us manage the variability of wind energy on our operating system.
- ❑ We have gained significant knowledge & insights into the value of energy storage as wind integration tool for the utility, wind providers, and the grid, including:
 - The potential for reduced baseload cycling costs due to wind variability
 - The capability to use battery for multiple integration functions simultaneously
 - The identification of the key energy storage system functions of value to the grid and its utility customers, ultimately resulting in better service at lower costs
 - Methods for determining how much and where to site energy storage on the grid to maximize its value to the electric system.
- ❑ Our learnings have reached the world. We have shared our learnings with industry, governments, and academia through over 30 speaking engagements, three published reports and countless outside inquiries.
 - We contributed input to the utility and energy storage industries on utility system and customer needs, including functionality and costs.
 - We participated in increased collaboration and sharing between energy storage users, federal and state policy-makers, and the energy storage industry, ultimately enriching the conversations around energy storage and its potential for supporting the integration of large penetrations of renewable resources onto utility grids.
- ❑ We have used the results of this demonstration and testing to identify additional applications for energy storage on utility distribution systems and obtained regulatory support for two additional energy storage projects that will be used to demonstrate its potential for managing the variability & uncertainty of solar PV.

Benefits to Funders

Xcel Energy's funders and customers have benefited from:

- ☐ A better understanding of the ways in which the increased flexibility (because of being both a dispatchable load and a dispatchable generator) energy storage can have, over that of traditional gas peaking resources, may provide overall system cost benefits, once energy storage prices become competitive with traditional peaking resources.
- ☐ The Company gaining an understanding of how to determine in what price range energy storage deployments will be cost beneficial to our customers and using that information to provide input to the energy storage industry as to the costs that will likely be needed to be cost beneficial to utility customers and potentially deployed more widely on a utility grid.
- ☐ The commercial use of the Wind-To-Battery system providing fast-response, ancillary services to the MISO after testing.
- ☐ The Company's expertise in specifying the essential energy storage system functions of value to the grid and its utility customers, ultimately resulting in better service at lower costs.
- ☐ The use of the Wind-To-Battery system as a means to validate system modeling work currently being done by the MISO.
- ☐ The potential use of energy storage on distribution system to help manage potential grid issues related to system reliability and performance expected with increased penetrations of distributed generation, including the potential for using the same storage resources to integrate both off-peak wind resources and distributed solar PV resources.

The potential for affordable energy storage systems in next five years is real, and because of this demonstration and associated analyses, the Company is in a much better position to know when it's right for our customers.

Project Objectives Achievement Checklist

- ☐ Evaluate the ability of large-scale battery storage technology to effectively firm wind energy, enabling a shift of wind-generated energy from off-peak to on-peak.
Complete. The report goes into significant detail as to how this can be done and ways in which such functionality can provide economic value.
- ☐ Evaluate the ability of the DESS system to reduce the need for the utility to compensate for the variability and uncertainty impacts of wind against other grid balancing procedures.
Complete. Work done by the Company and the University of Minnesota investigated these aspects through their investigations into the smoothing, economic dispatch and ancillary services functions in particular.
- ☐ Evaluate the potential for battery-storage technology to provide ancillary service support to the grid;
Complete. The energy storage system was operated to successfully demonstrate frequency regulation and other ancillary services.
- ☐ Assess the obtainable value of storage in the Midwest ISO (MISO) market for current wind penetration scenarios.
Complete. The University of Minnesota evaluated the economic value of storage based on time shift/arbitrage operations and ancillary services operations.

- ❑ Assess the overall operating characteristics of the DESS system, including impacts on system performance as a function of operational mode and external weather conditions.

Complete. The following operational modes were tested with complete success in a variety of weather conditions over more than two year of testing: Basic Generation Storage, Economic Dispatch, Frequency Regulation, Wind Smoothing, Wind Leveling, and Other Ancillary Services.

Public Policy Considerations

Great Plains Institute (GPI) has been working with Xcel Energy over the past year to assist in preparation of policy recommendations to support the potential expansion of electric energy storage on the Xcel Energy system if the results of this project and others indicate that energy storage is determined to be a valuable and effective tool to integrate intermittent renewable energy on the system. Xcel Energy and GPI convened a series of policy work group meetings and webinars to help provide input and advice on policy recommendations which would help support expansion of electric energy storage options. The main objective of the policy work group is outlined below.

Policy Work Group Approach and Process

Work Group Objective

Identify policy changes necessary to expand the deployment of electric energy storage and provide flexibility for application to generation, transmission or distribution systems.

A series of questions in each Policy Focus Areas was discussed with the policy work group in a series of meetings/webinars on September 23rd, 2009, December 16th, 2009 and April 13th, 2010 along with follow-up interviews with several individuals (subject matter experts).

These policy issues were divided into jurisdictional areas including the Federal Energy Regulatory Commission (FERC), MISO, State regulatory arena and utility policies to facilitate discussion and help clarify recommendations.

Policy Focus Areas:

- ☐ What policy changes are needed in order to **expand the deployment** of energy storage for generation, transmission or distribution system applications?
- ☐ What additional policy changes are needed in order to **maximize the [public] reliability benefits** of energy storage for generation, transmission or distribution system applications?
- ☐ What additional policy changes are needed in order to **maximize the [public] economic benefits** of energy storage for generation, transmission or distribution system applications?
- ☐ What additional policy changes are needed in order to **maximize the [public] environmental benefits** of energy storage for generation, transmission or distribution system applications?

Key Assumptions For Analysis

Electric energy storage options such as Compressed Air Energy Storage (CAES), batteries, flywheels, and hydrogen energy storage are still in the development stage with limited operational experience except for several large scale pumped-storage hydro projects such as Ludington³². Several new demonstration projects using these technologies are being funded by DOE as part of their Smart Grid demonstration grants. As a result, operational and financial

³² The Ludington pumped storage facility on Lake Michigan, built in the early 1970s by Consumers Power and Detroit Edison, has over 1,800 MW of capacity. Because of its location, it is now being considered for its ability to load follow wind energy.

regulations and policies are still in the early stages of development by FERC and regional transmission organizations such as MISO and PJM Interconnection.

The policy work group based their work on several key assumptions regarding the electrical grid and future generation options:

- ❑ Wind energy will continue to expand in the MISO footprint and will cause increasing system operating issues and transmission congestion issues for the MISO around wind integration, load following, cost of generation alternatives and value of quick-response electric energy storage options.
- ❑ There will be potential areas of economic value for electric energy storage including:
 - Enhancing variable renewable generation by time shifting, curtailment avoidance, smoothing and ramp rate control.
 - Reduced power plant cycling and availability requirements including spinning reserve value, Operating and Maintenance (O&M) savings, and avoided costs associated with turning down baseload generation to minimum operating levels where they are not designed to operate.
 - Transmission and distribution grid systems support including ancillary services such as frequency regulation, wind curtailment avoidance, peak shaving and power quality.
 - Hidden dispatch cost avoidance.
 - Natural gas price hedge.
 - Deferral of costs associated with transmission and distribution investments.
- ❑ Long-term environmental and regulatory benefits from carbon dioxide (CO₂) regulations are difficult to quantify until federal requirements around CO₂ reductions, taxes or cap and trade are completed and the additional value of storing renewable energy under those assumptions can be quantified.

Principles and Guidelines

The policy work group used the following principles and guidelines to work through the major policy questions and provide recommendations:

1. Policy should encourage optimizing storage investments in support of overall system efficiency and cost effectiveness.(Cost, reliability and environmental benefit)
2. Policy should generate the most good for the largest number of customers

Policy Work Group Participants

Xcel Energy

Frank Novachek, Project Sponsor
Nancy Pellowski, Project Support
Jim Himelic, Project Analyst
Betsy Engelking, Resource Planning
Lloyd Hilgard, Energy Supply
Dan Pfeiffer, Government Affairs
Liam Noailles, Market Operations
Marty Smith, Environmental Policy
Steve Beuning, Market Operations

External Participants

Rolf Nordstrom, Great Plains Institute
Mike Gregerson, Great Plains Institute
Mark Willers, Minwind Energy LLC
Matt Schuerger, Energy Systems Consulting Svs
Rahul Walawalkar, Customized Energy Solutions
Stan Selander, Great River Energy
Harold Gotschall, Technology Insights
Nathaniel Baer, Iowa Environmental Council
Larry Johnston, SUMMPA
Tom Wind, Iowa Stored Energy Park

Key Policy Considerations and Recommendations

The following summarizes key discussions and recommendations discussed by the work group for further consideration as policy development relevant to electric energy storage evolves.

FERC and MISO Policy Areas

1. There is no FERC approved tariff for electric energy storage in the MISO market
 - a. *Discussion:* Since the issuance of this recommendation, the MISO has submitted a proposed electric energy storage tariff to FERC, which was conditionally approved in an order on May 10th, 2010. Additional clarification was requested by FERC on some of the tariff language. This was completed on June 9th, 2010.
 - b. *Recommendation:* The W2B project will start to operate in July 2010 in the MISO market under the new electric energy storage tariff. Any further recommendations for changes to help support the expansion of electric energy storage in the MISO market will be supported by future operating experience and determination of benefits by Xcel Energy.
2. Electric energy storage may need to be considered a separate asset class to support expanded deployment
 - a. *Discussion:* Electric energy storage devices in most energy markets are not given any flexibility on asset classification or operating options to maximize the asset in the energy generation or transmission marketplace.
 - b. *Recommendation:* Allow longer term electric energy storage devices, which can operate 4 to 8 hours, to provide both energy delivery and frequency regulation services in the MISO market to maximize operating and revenue potential; and, consider the option of SERs to be paid for capacity services and bid into day ahead markets.

3. There may be many different ways, depending on the timing, of how SER can provide services to the MISO market
 - a. *Discussion:* SERs, especially those owned by integrated utilities, should have the flexibility to provide multiple services as a generation, transmission and/or distribution asset, either simultaneously or as conditions change.
 - b. *Recommendation:* Allow SERs to be service providers for the generation, transmission and/or distribution portions of the electric utility without penalty or restriction.
4. Electric energy storage devices that use net energy for frequency regulation services are expected to pay retail rates for energy
 - a. *Discussion:* If SER devices can help with frequency regulation services, then they should not be penalized by paying retail rates for the electricity they use.
 - b. *Recommendation:* Allow SER to pay wholesale rates for energy use during frequency regulation services.
5. MISO does not do planning for assets below 5MW
 - a. *Discussion:* Unless SERs are aggregated, it will be difficult to get study results from MISO that can show the proper location and benefits for SER devices as transmission or generation assets.
 - b. *Recommendation:* Request MISO to make a special category of study for SER services with a minimum size, such as 5 MW, to be determined.
6. Quick response assets such as battery and flywheel SERs are not given special valuation by MISO beyond the normal spinning reserve payments given to conventional generation
 - a. *Discussion:* SERs can provide a valuable service with very quick, sometimes sub-minute, response services to MISO that would be valuable in certain locations and time periods.
 - b. *Recommendation:* Request that MISO and FERC look at a special valuation for SERs such as batteries and flywheels that can provide very quick response services.

Environmental/Reliability Policy Areas

1. Cost Allocation for regional transmission projects related to wind power development will help determine some valuations of electric energy storage in remote areas
 - a. *Discussion:* The MISO is completing the Regional Generator Outlet Study (RGOS) for the Midwest region, along with a new transmission cost allocation tariff to be submitted to FERC by July 15th, 2010.
 - b. *Recommendation:* Once new cost allocation tariffs are available for wind related transmission projects, determine a methodology for assessing the value of electric energy storage devices in terms of maximizing the use of wind energy resources on new transmission lines.
2. Greenhouse Gas (GHG) Valuation from a cap and trade regulation or a carbon tax will help determine environmental benefits of electric energy storage devices

- a. *Discussion:* Electric energy storage devices that can provide storage and peak period release of renewable energy can have valuations above those services to the normal energy market and enable more variable renewable resources on the grid.
- b. *Recommendation:* Modeling should be conducted to determine minimum carbon price levels that would result in significant benefits to renewable electric energy storage.

Recent Policy Developments

Two new processes moved forward in FERC and the MISO recently that were deemed by the policy work group to be important for the future successful expansion of electric energy storage devices within the MISO system.

1. FERC Order on MISO Stored Energy Resources Tariff:

As noted in the discussion above (FERC and MISO policy recommendation #1), FERC issued a conditional order accepting MISO's Stored Resource Compliance Filing under Docket No. ER07-1372-017 and ER09-1126-000 on May 10th, 2010. This conditional order requested tariff revisions in response to comments submitted by Xcel Energy and Beacon Power. A revised filing has been made by MISO on June 9th, 2010 to correct some of the tariff language.

Xcel Energy has noted in its March 23rd FERC comments that there are remaining issues to be resolved by MISO's Markets Subcommittee and requested FERC to require an update on the progress of the initiative to more fully incorporate long term storage in 2012.

2. FERC Technical Conference "To Provide Guidance on Issues Related to Frequency Regulation Compensation in the ISO/RTO Markets"

FERC held a technical conference May 26th, 2010 on Frequency Regulation Compensation, which is an important valuation benefit for quick-response electric energy storage devices such as used by the W2B project. This technical conference is part of FERC's review of this issue under Docket No. ED10-11.

Panelists included experts from Beacon Power Corp., AES Energy Storage, ISO New England, KEMA Inc., PJM Interconnection, New York ISO, Alcoa Power Generating Inc. and California ISO.

Presentations were also made by Todd Ramey, MISO Executive Director of Market Administration and Rahul Walawalkar, Vice President, Emerging Technologies and Markets, Customized Energy Solutions, Ltd. Rahul was a participant in the Xcel Energy policy work group.

Participants were asked to comment in two particular areas important to quick-response electric energy storage devices such as used by the W2B project:

- *Session 1- Value of Higher-Quality Frequency Regulation Service in Organized Electric Markets.* This session explored the value of new energy technologies that have the potential to respond to a regulation dispatch signal faster, and follow it more accurately, than traditional resources on automatic generation control.

- *Session 2- Performance, Compensation and Market Design.* This session explored whether existing pricing mechanisms for frequency regulation services reflect the quality of the service provided, and whether reforms are needed.

A full transcript and copies of all presentations can be found at www.ferc.org under “Technical Conference to provide guidance on issues relating to Frequency Regulation Compensation in the ISO/RTO Markets”.

Several panelists during the technical conference brought up issues that could help in determining the economic value of electric energy storage.

1. Compensation models should value both speed and accuracy of response by electric energy storage device and compensate regulation providers based upon the speed and accuracy in which they regulate the grid.
2. ISO-New England’s two-component formula appears to work particularly well in compensating regulation services by having compensation based on the amount of capacity available and on the resource’s total amount of actual up and down movement.

3. FERC’s Office of Energy Policy and Innovation on June 11, 2010 issued a formal request for comments regarding rates, accounting and financial reporting for new electric storage technologies under Docket No. AD10-13-000.

Conclusions and Further Research and Investigation

Further recommendations for modification of the MISO electric energy storage tariff may be part of FERC’s investigation on Regulation Compensation. The W2B Project results may be useful to MISO as supporting data.

Recommendations from the policy work group will be prioritized by Xcel Energy for further work pending testing results from the project.

Supplemental Information - System and Technology Overview

Note: Information that is protected by the Confidentiality Agreements with NGK and S&C Electric is blacked out in the public version.

Sodium Sulfur (NaS) Energy Storage Technology

Introduction

At the beginning of this project, Xcel Energy evaluated multiple types of utility-scale electrochemical storage technologies. For the project, Xcel Energy desired a battery that could satisfy the following functional requirements:

- ☐ Minimum power capacity of 1 MW
- ☐ Minimum discharge duration of 6 hours at the nominal power rating
- ☐ Minimum of 300 annual charge-discharge cycles
- ☐ Capable of providing frequency regulation and voltage support
- ☐ Modular and scalable in design.

In addition, the technology needed to be commercially available and have a sound track record. After careful consideration, Xcel Energy selected the NaS technology for the W2B Project because it was the only battery available that met all the aforementioned requirements.

NGK commercialized the NaS technology in 2002. NGK is headquartered in Nagoya, Japan and is currently the only manufacturer of NaS batteries in the world. Today, the company's annual manufacturing capacity is 90 MW but NGK plans to increase that to 150 MW by the summer of 2010³³. Although NGK does not have any official pricing forecasts, the company is consistently working on reducing the cost of their product.

As with all technologies, NaS batteries have several pros and cons that need to be individually addressed for each specific proposed application. Table 22 lists some of the general pros and cons of NaS batteries.

Table 22: NaS Battery Pros and Cons

Pros	Cons
Modular	Large upfront initial cost
Mature technology	High auxiliary load draw for certain modes
Long system life	High internal operating temperatures and risk of causing long-term damage to battery and / or surrounding area
Accurate and timely response	
High ramp rate capabilities	
Minimal physical siting constraints	
No emissions, noise, or vibration during operation	
Low maintenance requirements	

³³ Pending on customer demand, NGK may further increase their annual manufacturing capacity to 210 MW.

NaS batteries have three characteristics that enable their flexibility. First, a NaS battery has a sizeable discharge capacity of several hours at its nominal capacity. Second, the storage device has the ability to rapidly switch back and forth between charging and discharging without resulting in any immediate damage to the battery³⁴. Third, a NaS battery can respond to dynamic control signals in a timely and accurate manner. Thus, NaS batteries can help manage the operation of intermittent, non-dispatchable renewable energy, provide ancillary services, and reduce inefficiencies in energy markets. However, this flexibility in operation comes at a large cost premium over traditional generation technology, which must be considered when performing a cost-benefit analysis.

Cell Construction and Electrochemistry

As with all forms of electrochemical storage, the performance of a NaS battery is rooted in the design and characteristics of its cells. A NaS battery cell consists of molten sulfur (S) at the positive electrode and molten sodium (Na) at the negative electrode with a solid beta alumina (Al_2O_3) electrolyte situated in between. This is unlike other batteries, which have solid electrodes and a liquid electrolyte. Figure 44 displays a cut-away view of a standard NaS battery cell.




Figure 44: NaS Cell Structure [ESA]

The sodium electrode is located in the center of the cell and is encapsulated by the beta alumina electrolyte, which in turn is surrounded by the sulfur electrode. The dimensions of each cell are .515 m in height and .09 m in diameter. Each cell has a nominal capacity of 632 ampere-hours (Ah) at a voltage of 2 volts (V).

³⁴ While there may not be any immediate harm to the battery in rapidly switching back and forth between charging and discharging, this type of operation may gradually reduce system performance over time.

NaS cells contain internal resistance that reduces its overall efficiency. This internal resistance is a function of multiple factors such as cell temperature, state of charge, and cycle count [Lutz].

As with all batteries, chemical reactions occur whenever the battery charges or discharges. Figure 45 illustrates the chemical reaction that occurs within a NaS cell when charging and discharging.




Figure 45: Chemical Reaction of NaS Cell [NGK Literature]

Figure 46 displays the respective half-cell reactions at each electrode and the overall reaction of the cell during charging and discharging.




Figure 46: Chemistry of NaS Cell during Operation [EPRI]

When the battery discharges, sodium, serving as the anode, traverses through the annulus and oxidizes at the sodium/beta alumina interface to produce sodium ions (Na⁺) and free electrons (e⁻). The sodium ions traverse through the beta alumina electrolyte while the electrons travel through the external circuit. Because the beta alumina electrolyte is good conductor of Na⁺ but not of e⁻, self-discharging of the cells is minimal. The Na⁺ and e⁻ meet up at the positive electrode, which serves as the cathode, and mixes with a sulfur particle to form a two-phase liquid mixture of sodium pentasulfide (Na₂S₅). After all the free sulfur reacts with the sodium, the Na₂S₅ starts to convert into single-phase sodium polysulfides (Na₂S_{5-x}) until discharging stops. The entire chemical reaction is reversed for the charge process. Discharging is an exothermic process, and charging is an endothermic process.

Although cell voltage can be derived from thermodynamic principles, the actual performance of each NaS cell is unique. Figure 47 is a display of the open circuit voltage (OCV) of a NaS cell as a function of the SOC. Down to a SOC of 40-25%, the OCV remains constant at 2.075V, as the two-phase mixture of S and Na_2S_5 remains present inside the cell. As discharging continues, all the cell material is converted into a single-phase solution of Na_2S_{5-x} , and voltage decreases linearly until discharging stops.

Furthermore, the rate of heat absorption / dissipation in the one-phase region is double the rate when the battery is in the two-phase region [Lutz].

Figure 47: NaS Two-Phase and Single-Phase Chemistry (NGK Literature)

Figure is protected by Confidentiality Agreement with NGK

Module and Unit Construction

Individual battery modules are composed of individual cells connected in a parallel-series configuration. These modules are then also wired together in a parallel-series configuration to form a module that provides the desired electrical properties. NGK offers two types of cell modules: a load-leveling module and a power-quality module. The principal difference between the two is the electrical configuration of the cells and the electrical protection scheme deployed. The primary application for NaS batteries is load-leveling. Figure 48 is a cutaway display of a standard NaS module.




Figure 48: NaS Battery Module [NGK Literature]

NGK incorporated several internal controllers for the battery to ensure proper operation of the unit. For every five battery modules, there is one module controller that monitors cell temperature and voltage data for each module. The module controller compiles this voltage and temperature data and relays the information to a master battery controller. If temperatures in any one of the modules become too high, the module controller will trip the heater circuit. The module controllers are housed in the battery enclosure cabinet and are connected to the central battery controller via a field bus network cable.

Integrating the performance data from all the module controllers, the master battery controller communicates with the power conversion system to protect the battery from potentially harmful operation such as over-charging or over-discharging the unit. In addition, if the master battery controller detects an abnormal operating condition in one of the module strings, it will send a signal to the power electronics to disconnect that string. Included in the master controller are all the necessary disconnects, fuses, and circuit breakers. It is located in a cabinet at the opposite end of the module controllers. Finally, the master controller serves as the control interface for both the battery Human-Machine Interface (HMI) and the S&C power electronics.

Thermal Considerations

NaS batteries have unique thermal considerations that must always be accounted for by the owner / operator. To keep the Na and S located at the electrodes at a low internal resistance, NaS batteries need to operate at elevated temperatures. The normal operating temperature range of a NaS battery is between 300-340 °C.

NGK has implemented several thermal features to help maintain these temperature ranges. To begin with, NGK encapsulates each individual cell with sand to insulate the cells in addition to providing structural rigidity. Furthermore, NGK designed an air-tight vacuum for the gap between the inner and outer module walls and surrounded each module with a thermal enclosure.

. Each

module also comes equipped with a 7.2 kW heater. The module controller operates the heater whenever the battery module approaches the minimum allowed temperature. In the event any of the modules goes outside of this range, the master battery controller will issue a signal to the power electronics device to cease operation.

There are two simultaneous processes that affect the amount of heat generated when the battery is operating. When discharging, the battery generates heat from the internal exothermic chemical reaction as well as from Ohmic heating (i.e. I^2R heating). However, when charging, although Ohmic heating is still present, the battery absorbs heat due to the internal endothermic chemical reaction. For discharging at moderate to high rates, battery temperature typically increases because the amount of heat generated from the chemical reaction and the Ohmic heating is greater than the amount of heat lost to the surrounding environment. Conversely, battery temperature typically decreases gradually during charging because the combination of the heat absorbed by the internal endothermic chemical reaction and the heat lost to the ambient air is greater than the Ohmic heat. When the battery is idle, its temperature decreases at a rate greater than when charging because there is no Ohmic heating. Figure 49 is an example of how temperature varies while the battery is either charging, discharging, or idle.




Figure 49: Battery Temperature as a Function of Charging and Discharging

When locating the battery in regions with cold weather, the owner / operator of the battery should exercise great care because there is risk in inflicting permanent damage upon the storage device. If there is a loss of grid power while the battery is fully-charged, there is no immediate risk to the long-term health of the storage device as long as the temperature of the battery does not drop below 0°C. However, if a battery is partially discharged and there is an extended outage, permanent module damage may result depending on the state of charge of the battery.





Figure 50: Outage Response Time as Function of Depth of Discharge [NaS Instruction Manual]

Figure is protected by Confidentiality Agreement with NGK



The W2B Project is the first demonstration of a NaS battery in a cold-weather climate. As a result, NGK engineers had significant concerns regarding the impact of temperatures commonly seen during winter in southwestern Minnesota on battery performance. Therefore, NGK engineers designed cold-climate battery enclosures to provide the modules with additional thermal insulation³⁷. To insulate the electronics for the battery management system (BMS), NGK included two cold-climate control cabinets.

³⁶ Depth of Discharge (%) = 1 – SOC (%).

³⁷ These cold-climate enclosures include adjustable dampers that require manual adjustments on a seasonal basis.

NaS SOC Calculation and Battery Efficiency

NGK tracks the SOC of its modules in a unique manner. Because it has no way to directly measure the SOC, NGK estimates the SOC using the following formula³⁸

$$SOC = \frac{AH_{rated} - \int I_{DC} dt}{AH_{rated}}$$

Although NGK believes that the calculation is highly accurate, if the battery is not periodically recalibrated, erroneous values can result. [REDACTED]

[REDACTED] To ensure proper SOC calibration, NGK recommends that its customers perform a complete charge-discharge cycle once per week at a minimum.

NGK batteries benefit from a high degree of system efficiency relative to other storage mediums. However, over time, the efficiency of a NaS battery gradually decreases due to degradation in cell material. NGK estimates the overall efficiency (DC) for a battery module averages 85% over its predicted system life (75% for AC efficiency). According to NGK, the Coulombic efficiency of NaS battery modules is 100%³⁹. The efficiency of a module is not significantly affected by the DOD.

NaS Battery Durability

NGK has multiple reference discharge profiles that are specifically designed to optimize long-term system performance. These profiles, shown in Figure 51, vary in shape, duration, and number of discharge periods. To maximize the amount of energy available from each discharge period, a system dispatcher can select one of the trapezoidal profiles in which the battery undergoes a gradual ramp-up and ramp-down in power production. Alternatively, a dispatcher can also select a constant power profile at the expense of less energy available for discharging.

³⁸ [REDACTED]

³⁹ Coulombic efficiency is the efficiency in which charged energy is recovered while discharging the battery (i.e. it measures the amount of ampere-hours lost).





Profile #	# of Discharges	Discharge Profile
1	1	
2	1	
3	1	
4	2	

Figure 51: NGK Standard Discharge Profiles

Figure 52 is an example of standard battery operation according to NGK. As illustrated in the figure, after completing its charge in the early morning hours, the battery is idle until it begins to discharge in the evening hours according to discharge profile #1. After completing its discharge cycle, the storage unit resumes charging shortly thereafter. However, if the battery is used to help balance the output of a wind farm or is scheduled into a wholesale market, it may be exposed to a more strenuous duty profile than what is shown in Figure 52. Figure 53 is one example of the type of non-standard battery operation that can occur.




Figure 52: Example of Standard NGK Battery Operation




Figure 53: Example of Non-Standard NGK Battery Operation

At the beginning stages of the project, Xcel Energy informed NGK of its plans to operate the battery in a more aggressive manner than had been done in previous installations. In response, NGK agreed to monitor the battery performance throughout the project to better understand how long-term performance was impacted over time.

As with all storage technologies, the predicted life of a battery is a critical factor in determining the total cost of ownership. [REDACTED]




Figure 54: NGK Cycle Counting Logic

Figure is protected by Confidentiality Agreement with NGK

*Equations are protected by
Confidentiality Agreement with NGK*

As with all electrochemical storage technologies, the average depth of discharge is a critical factor in determining the total cycle life of a battery. [REDACTED]
[REDACTED] In addition to depth of discharge, another critical variable that impacts the useful life of a NaS battery is cell temperature.
[REDACTED]





Figure 55: NaS Cycle Life as a Function of Depth of Discharge [EPRI]

Figure is protected by Confidentiality Agreement with NGK





Project-Specific Battery Details

The 1 MW, 7.2 MWh NaS battery purchased for the W2B Project is roughly the size of two tractor trailers stacked upon one another and weighs approximately 75 tons. The battery system consists of 20 load-leveling modules configured in two parallel strings of 10 individual modules connected in series as shown in Figure 56.



Figure 56: NaS Battery Object Hierarchy

Figure is protected by Confidentiality Agreement with NGK

Table 23 lists the general specifications of the 1 MW NaS battery used for this project [NGK NaS Owner's Manual].

Table 23: General 1 MW Battery Specifications

Site Conditions (Exterior)	<ul style="list-style-type: none"> • Ambient Temperature (standard): -30 to 45 (°C) • Ambient Temperature (cold-climate enclosures): -45 to -30 (°C) • Relative Humidity: 0-100% • Altitude: h< 2000m
Battery System Specifications:	<ul style="list-style-type: none"> • Nominal Rated Power: 1.05 MW (DC); 1 MW (AC) • [REDACTED] • Nominal Energy Capacity: 7.58 MWh (DC); 7.2 MWh (AC) • Efficiency: ~75% (AC) • Cycle Life: 300 cycles/yr at 90% depth of discharge for 15 years • Nominal Voltage: 640 V (DC) • DC Voltage Range: 465-745 V • DC Current Range: -900 A (charge) to +1400 A (discharge) • Mean Operation Temperature: 300 (°C) • Temperature Range for Operation: 300 to 340 (°C) • Auxiliary Heating Power: 144 kW (208 V ((AC) • Energy Density: 2.18 kWh/kg • Power Density: 0.294 kW/kg
Battery System Configuration:	<ul style="list-style-type: none"> • Modules: 20 50 kW battery modules arranged in two strings of 10 modules each • [REDACTED] ○ Dimensions: 2.2 x 1.78 x .730 (m) ○ Weight: 3,400 kg • [REDACTED] • Battery management system <ul style="list-style-type: none"> ○ 1 Battery system controller ○ 4 module controllers (1 per stack of 5 modules)

Maintenance Procedures

According to the literature, the NaS battery has relatively minimal maintenance requirements when compared to other battery technologies such as lead-acid or flow batteries. NGK recommends users to remotely monitor the performance data, specifically the maximum and minimum cell temperatures and voltages, on a daily basis to ensure normal operation. NGK also recommends a visual site inspection of the battery on a weekly basis. Every three years, NGK requires a more in-depth servicing of the battery, which includes replacing certain consumable parts, visually inspecting connections, measuring resistance values, and recalibrating components. These maintenance procedures are either to be performed by NGK personnel or by NGK-certified field technicians. NGK recommends that its clients take a preventative maintenance approach when servicing the battery. According to NGK, this approach minimizes system down time and helps to ensure that the battery attains its estimated 15 year life.

Power conversion system

Introduction

The PCS is a microprocessor-based system of power electronics, consisting of an inverter / rectifier (DC-to-AC and AC-to-DC converter) connected to a series of choppers⁴⁰ (DC-to-DC converters). The PCS is connected in parallel with the NaS battery to automatically convert electricity back and forth between AC and DC for charging and discharging operations with the grid. The PCS also provides users with control functionality and system status information. The unit is designed for outdoor, unattended operation, and has local and remote control, monitoring, and data-archiving capabilities.

The PCS communicates with NGK's master battery controller to control all operation functions related to the battery. The PCS has the ultimate responsibility of protecting the battery from damage due to excessive charging and/or discharging for all modes of operation. The PCS has a nominal continuous power rating of 1,250 kVA and connects to the local electric circuit via a three-phase 34.5 kV, wye-connected four-wire interconnection.

Nominal specifications for the DESS are summarized in Table 24 below:

Table 24: Nominal Specifications for DESS


Description	Value
Nominal Real Power Capacity	±1,000 kW
Maximum Apparent Power Capacity	±1,250 kVA
Nominal Interconnection Voltage	34.5 kV (three-phase)
Current Rating	1504 A
Nominal DC Voltage Per String	640 V
DC Voltage Range Per String	
Discharge	465 V
Charge	745 V
DC Current Range Per String⁴¹	
Discharge	0 – 1400 A
Charge	-900 – 0 A
Response Speed	< 16 ms
Nominal Accuracy	±1% of kW/kVAR set-point

⁴⁰ A chopper is a device that converts DC electricity from one voltage to another to either boost or buck system voltage.

⁴¹ The NGK battery controller treats positive as discharging and negative as charging, unlike the convention used elsewhere where positive is charging and negative is discharging.

Physical Layout

The DESS is contained in three groups of enclosures: one group for the PCS equipment, a second enclosure for the 480:34.5kV transformer, and a third group for the NaS battery control equipment. The PCS equipment is contained in a group of four interconnected and adjoining enclosures.



*Figure is
protected by
Confidentiality
Agreement with
S&C Electric*

Figure 57: PCS Enclosures

Physical Operating Principles and Electrical Layout

At its core, the operating principle of the PCS is based on converter technology and controls developed around insulated gate bipolar transistors (IGBTs). To charge the battery, AC electricity from the grid passes through the PCS, where it is transformed into DC electricity and then stored in the battery. To discharge the battery, the PCS converts DC electricity from the battery into AC electricity and then supplies it to the grid.

Figure 58 is an electrical 1-line diagram of the PCS. For system protection, a DC circuit breaker is located between each NaS battery string and the PCS. Controlled by the PCS, the breakers allow the PCS to be isolated from the NaS battery for maintenance needs and to disconnect and shut down the battery as a protective measure if necessary. An 800 V(DC) bus is located between the choppers and the inverters and regulates power and voltage. The AC side of the inverter is connected to the 480V(AC) bus. A 1.25 MVA transformer boosts the voltage from 480 V to 34.5 kV to allow for the DESS to connect to the MWD bus⁴².

⁴² Please refer to the architecture section for an entire overview of the electrical connectivity of the battery and wind farm.




Figure 58: PCS 1 Line Diagram

The PCS also contains a 208 V(AC) three-phase, wye-connected 150 kVA auxiliary transformer to provide power to the battery module heaters. Under normal operation, the AC grid powers this auxiliary transformer. However, in the event of a grid outage, a transfer switch adjacent to the battery will switch the power supply of the transformer from the grid to the backup generator so that the module heaters can continue to operate and maintain the battery modules at a safe operating temperature.

In addition to being compliant with the required codes and standards⁴³, the PCS has several safety features embedded in its design. The PCS comes equipped with an emergency shutdown switch that performs a rapid but controlled shutdown of the DESS by opening up the DC and AC circuit breakers, which prevents the DESS from operating. In addition, the PCS monitors the battery ground connection and will disconnect itself from the NaS battery and issue an alarm to system operators in the event of a fault. Furthermore, the PCS also monitors temperature sensors located in each enclosure to ensure normal operating temperatures.

The PCS is designed to limit the current total harmonic distortion at the point of interconnection to less than 5% when the PCS is operating at a capacity of at least 500 kW for both charging and discharging modes of operation. The PCS is also protected from over-current and over-voltage transients and surges. Lastly, at no time will the PCS energize a grid during a system outage (i.e. it is not capable of islanding).

Unlike traditional grid-tied inverters that play a passive role in regulating system voltage, the DESS is a dynamic unit that is capable of providing and absorbing reactive power to and from the grid to regulate system voltage using real-time controls. A user-specified binary software bit allows the PCS to regulate system voltage either by responding to a voltage set-point (for the low-side of the 480V-34.5kV transformer) or a VAR set-point. With this capability, the DESS is able to assume a more autonomous role in supporting system voltage, while providing system operators with greater flexibility.

PCS Alarms

In the event of an extreme operating condition, the PCS will enter into an alarm state. The PCS categorizes alarms into two-levels of severity: low-severity (transient alarms) and high-severity (persistent alarms). The PCS recovers from low-severity alarms through an auto-restart function, which does not require corrective action from a person. High-severity or persistent alarms prohibit auto-restart, and require intervention and corrective action from an S&C engineer or certified technician. Irrespective of the fault type, the PCS HMI can be accessed for details about the type of alarm that has occurred, the likely root cause, the adjustments or repairs that might be needed, and whether or not the system may be reset and re-started.



⁴³ IEEE 1547, IEEE519-1993, IEEE C62.45-2002, IEEE C62.41.2-2002, IEEE C37.90.1-2002

PCS HMI

The PCS comes equipped with an HMI that allows for a user to operate and troubleshoot the DESS.

It enables an on-site operator to perform several functions on the DESS and is still accessible when the emergency shutdown switch is engaged.

A user can operate the DESS through the HMI by specifying the appropriate operating commands. In addition, the HMI provides the operator with detailed information on the real-time operating parameters of the system (e.g. voltage, current, and power), as well as trending information and any alarms. Furthermore, the HMI allows the operator to startup and shutdown the DESS to manage planned outages. Because the PCS is browser-based, it is accessible from any network-connected computer. As a result, the HMI can be accessed remotely by a user in possession of the appropriate access credentials.

All the PCS HMI screens and settings that are user-adjustable can be adjusted either locally or remotely. To establish a local connection, an operator is physically on-site and logged into the HMI. To establish a remote connection, an operator logs into the HMI via the Secure Shell (SSH) network protocol. This remote connection allows a remote operator to request system status information as well as to issue operating commands to the DESS.

PCS Modes of Operation

The DESS has three modes of operation: local-only, local-remote, and remote-only. The PCS categorization of the W2B modes of operation is listed in Table 25.

Table 25: PCS Types of Modes of Operation

<u>Local-Only</u>	<u>Local-Remote</u>	<u>Remote-Only</u>
Local Var Only Run	Basic GS	Dispatch to Serve Frequency Regulation
Local Power Var Run	Wind Smoothing	ED
	Dispatched Wind Leveling	
	Emergency Charge	
	Test SOC	

For the Local-Only modes, the PCS responds to inputs from the local HMI only, ignoring all remote operating commands. In the Local Var Only Run mode, the DESS is capable of providing only reactive power and can respond to either a VAR set-point or voltage set-point. In the Local Power VAR Run mode, the DESS is capable of providing reactive power along with real power from a user specifying a specific kW command.

In the Local-Remote modes of operation, a user specifies the input settings for a particular mode of operation and the PCS determines the actual kW command. In the Remote-Only mode of operation, the PCS receives a kW command from a remote system operator and attempts to follow the signal to the best of its abilities. For reactive power in both the Local-Remote and Remote-Only modes of operation, a remote system operator specifies a voltage or VAR set-point for the DESS.

PCS Server-Client Designation

The PCS has two masters that can write set-points to it. The first master is the local RCY remote terminal unit (RTU) that relays production data from the wind farm to the PCS. The second master is GridPoint, which serves the role of the remote external controller. To prevent one master from inadvertently over-riding a set-point written by the other, the RCY RTU and the GridPoint master can write only to set-points that have been assigned to them. In addition, both masters have a “watch-dog” timer for the PCS that consists of a rolling counter that updates every second. If the timer of either master is not updated after 20 seconds, the PCS equates this as loss of communication with that respective master and will enter into the appropriate default mode of operation. The PCS interface with both masters is carried out using DNP3. These interfaces are discussed in greater detail in the system architecture section.

Maintenance and System Lifetime

S&C has designed the PCS to perform over an extended period of time with minimal maintenance requirements. S&C estimates the PCS system lifetime at 20 years.

S&C provides remote monitoring services that consist of an S&C engineer monitoring the PCS on a daily basis to identify and report any potential system malfunctions involving the PCS. If a malfunction does occur, the S&C engineer will troubleshoot the PCS.

Maintenance of the PCS includes a series of monthly and yearly checks on the device to ensure proper operation. Every 30-60 days, a technician needs to replace the air filter in the PCS. On a yearly basis, an Xcel Energy field technician needs to visually inspect the PCS components for any significant or unusual wear and tear, verify connections at all the terminals, verify appropriate control set-points and system settings, and check for rust.

DESS Overall System Efficiency

The overall efficiency of the DESS depends on multiple factors such as the mode of operation, the efficiency of the battery modules, the efficiency of the PCS, and ambient weather conditions. To get a baseline of the efficiency of the unit, project analysts measured the DC efficiency (i.e. the electrochemistry efficiency) and the AC efficiency (with and without the auxiliary load) for a 24-hour period using a standard daily charge-discharge profile while varying the depth of discharge. For this specific test, project participants did not account for any impacts of ambient weather conditions.

The team designated $\eta_{AC,1}$ to measure the overall efficiency of the DESS, which accounts for the amount of AC energy the PCS discharged ($MWh_{d,AC}$), the amount of AC energy the PCS used to charge ($MWh_{c,AC}$), and the energy draw of the auxiliary loads ($MWh_{aux,AC}$). The team designated $\eta_{AC,2}$ to measure only the efficiency of the DESS when the auxiliary energy draw was excluded. Analysts designated η_{DC} to calculate the efficiency of the battery modules (i.e. the electrochemistry efficiency) by measuring the amount of DC energy into and out of the battery modules ($MWh_{d,DC}$ and $MWh_{c,DC}$).

$$\eta_{AC,1} = \frac{MWh_{d,AC}}{MWh_{c,AC} + MWh_{aux,AC}}$$

$$\eta_{AC,2} = \frac{MWh_{d,AC}}{MWh_{c,AC}}$$

$$\eta_{DC} = \frac{MWh_{d,DC}}{MWh_{c,DC}}$$

Figure 59 displays the efficiency values for varying depths of discharge over a 24 hour period. As shown by the figure, the $\eta_{AC,1}$ efficiency is heavily dependent on the amount of time that the DESS operates within the time period of interest due to two primary reasons made evident by Table 26.




Figure 59: Overall System Efficiency

Table 26: DESS Efficiency Test Data

Performance Data						Efficiency		
Depth of Discharge	AC Charge (MWh)	AC Discharge (MWh)	AC Auxiliary (MWh)	DC Charge (MWh)	DC Discharge (MWh)	η_1	η_2	η_{DC}
90%	8.57	7.03	0.24	8.25	7.22	79.9%	82.1%	87.5%
70%	6.60	5.54	0.42	6.34	5.69	78.9%	83.9%	89.8%
50%	4.75	4.01	0.77	4.56	4.11	72.6%	84.4%	90.1%
30%	2.87	2.45	0.94	2.76	2.48	64.3%	85.3%	89.7%
10%	1.00	0.84	1.09	0.96	0.83	40.2%	83.9%	85.9%

First, when the DESS is idle, the module temperatures fall at an accelerated rate compared to when the DESS operates, as discussed previously. As a result, the module heaters are required to operate at a greater frequency to keep the module temperatures within the required range.

Second, with less charge-discharge operation, $MWh_{aux,AC}$ becomes a larger contribution to the efficiency calculation relative to $MWh_{d,AC}$ and $MWh_{c,AC}$. The $\eta_{AC,2}$ efficiency does not appear to

be sensitive to the depth of discharge as it varies from a minimum of 82.1% to a maximum of 85.3%. The electrochemistry efficiency of the NaS battery, which is slightly higher than $\eta_{AC,2}$ due to the conversion losses in the PCS, ranges between 85.9% - 90.1%. Project analysts suspect the slightly larger range may be attributed to the manner in which NGK calculates the battery SOC and insufficient meter accuracy.

PCS Efficiency

S&C states the efficiency of the PCS shall be at least 95% for both charging and discharging operations. During the project, analysts attempted to calculate these efficiencies using empirical data to track actual energy losses as electricity converted back and forth between AC and DC. However, it was difficult for project analysts to develop a methodology that accurately calculated these values for a multitude of reasons.

Project analysts alternated the PCS between charging and discharging for different power settings ranging from 25 kW to 1,100 kW for approximately 30 minutes for each setting⁴⁴. Project analysts calculated the PCS efficiency using the following calculations for the PCS operated as an inverter and rectifier⁴⁵.

$$\eta_{PCS,inv} = \frac{kW_{AC}}{kW_{DC}}$$

$$\eta_{PCS,rec} = \frac{kW_{DC}}{kW_{AC}}$$

Figure 60 displays the efficiency of the PCS while it converts power from AC to DC to charge the battery at various power ratings. As shown in the figure, the values are unreasonably high with some values exceeding 100% at the lower settings, which is not feasible. While the results improve slightly for greater PCS Power settings, some of the values are still larger than expected.




Figure 60: PCS Rectifier Efficiency

⁴⁴ This entire test was not carried out continuously and was broken out into four separate data collection sessions.

⁴⁵ Project participants also tried to calculate the efficiency of the PCS using energy values rather than power values but the calculated results were worse.

Figure 61 displays the efficiency of the PCS while it converts power from DC to AC to discharge the battery at various power ratings. Again, the values are unreasonably high with some values exceeding 100% at the lower settings. While the results improve slightly for greater PCS Power settings, some of the values are still larger than expected. A phenomenon that is also apparent in both graphs is that the variance of calculated efficiencies for small and large power levels is larger than those calculated for power settings between 200 kW and 600 kW.




Figure 61: PCS Inverter Efficiency

Xcel Energy discussed these results with the National Renewable Energy Lab (NREL), S&C, and NGK, but unfortunately there was not an explanation either for the invalid results or the variable ranges in efficiencies for the various power levels. NGK has experienced higher than expected PCS efficiency values in Japan as well and suspects it may have something to do with an error in which AC power is measured by the meter due to the presence of harmonic currents. S&C also mentioned that the accuracy and granularity of the meters installed in the PCS may not be sufficient enough for this application.

DESS System Architecture

Introduction

In addition to evaluating the DESS technology, another primary focus of the W2B Project was to design and implement a communication system that enabled an external system aggregator to manage the operation of multiple distributed energy resources (DER) located within the same balancing area. Even though the project had only one DESS, Xcel Energy wanted a communication system that supported the virtual power plant concept, in which multiple DER units are aggregated into one effective resource that a grid operator can call upon to provide grid services. Because a virtual power plant would connect to a utility via a single interface, the company would not have to alter its communication system every time a new DER unit came online. In addition, grid operators could issue commitment and dispatch decisions for the entire DER pool rather than having to individually manage each unit.

Functional Requirements

The principal functional requirement for the W2B communication system was to enable remote control, monitoring, and data acquisition of the DESS. This requirement was driven by two project needs. First, due to the siting location of the battery, company employees based out of Minneapolis or Denver could not physically access the site with ease. Second, Xcel Energy wanted to design the system in a manner that aligned with other smart grid initiatives within the company.

Overview

The W2B Project was the first time Xcel Energy interfaced with an external system aggregator via the NSP EMS. The W2B Communication team, which consisted of individuals from Xcel Energy, S&C, and GridPoint, designed and implemented the communication system from July 2008 to May 2009.

Figure 62 on the next page is an architectural diagram of the system. The team had to create several interfaces for the project that involved multiple communication protocols, transport mechanisms, and source and destination applications. Furthermore, the design implemented the required security and encryption features to prevent any malicious network attacks on the system from outside users⁴⁶.

The W2B communication design utilizes multiple communication circuits. Due to inadequate coverage from DSL, the communication team purchased a full T1 line at the site for internet connectivity. A 56k frame relay circuit over a dedicated leased line runs from Minneapolis, MN to Alexandria, VA to connect EMS MN and GridPoint for the external system aggregator functionality. Finally, another 56k frame relay circuit over a dedicated leased line runs from Sioux Falls, SD to Luverne, MN to provide Xcel Energy's Angus Anson generation facility a SCADA connection to the DESS site for monitoring and system responder purposes.

⁴⁶ Xcel Energy's Enterprise Security department approved the design of the W2B communication system.




Figure 62: W2B Technical Architecture Diagram

GridPoint

GridPoint is a software-development and communications company specializing in the integration of clean energy technologies into the electric power grid and served a primary role in the W2B communication system. GridPoint was contracted to provide the project with its intelligent distributed generation solution, which consists of remote network-based control and data acquisition⁴⁷. In addition to enabling additional modes of operation on top of what the PCS was capable of providing (e.g., Frequency Regulation and Economic Dispatch), GridPoint allowed for DESS operation under a virtual power plant paradigm. GridPoint also provided system monitoring and data acquisition services to the project via two secured websites.

Figure 63 is a screen shot of the GridPoint Administrator web page. This web page allows a remote user to initiate, transition, and terminate modes of operation for the DESS (as long as it is not in a local-only mode). In addition, this web page allows a user to update set-points for the current operating mode and receive real-time status information on the DESS.




Figure 63: GridPoint Administrator Web page

As mentioned earlier, the communication team designed the communication system in such manner so that there was only a single interface between GridPoint and Xcel Energy. There were no technical limitations preventing Xcel Energy from implementing the features GridPoint provided by establishing a direct connection to the DESS similar to what is shown on the left side of Figure 64. However, if another DESS unit were to be installed, Xcel Energy would have

⁴⁷ Originally, Xcel Energy contracted with V2Green for the W2B project. In September 2008, Gridpoint acquired V2Green; however, the service contract was not impacted by this business transaction.

to replicate the entire interface and individually manage and operate each battery. The external system controller functionality provided by GridPoint allows Xcel Energy to avoid implementing changes to its systems as additional DER units come online. As shown on the right side of Figure 64, the external system controller will setup a communication link to the new unit and then report to Xcel Energy the total MW and MWh capacity currently available from the pool of resources it has connectivity to. Depending on the control mode, the external system aggregator can either relay a dispatch command from Xcel Energy to the pool, or it can issue its own command in an automated fashion by embedding logic on a server.




Figure 64: External System Aggregator Concept

As with all designs, the W2B communication system does have some limitations. For this project, GridPoint's intelligent distributed generation solution did not include responsibility for responding to system alarms. GridPoint only reported alarms to the appropriate stakeholders. As a result, the SCADA connection between Angus Anson and the DESS site was required.

Moreover, the DNP3 communication protocol is a sequentially polling protocol. Therefore, it is not possible for GridPoint to provide time-synchronized data from multiple data sources, which can complicate analytical tasks. Another drawback in the communication system is that there is no onsite data caching. Thus, when GridPoint loses communication with any of the devices or the T1 circuit goes down, there is no way to collect and archive data, resulting in incomplete datasets. Each week, project analysts tracked the availability and latency of GridPoint's communication with the PCS in the executive summary reports.

System Context

Figure 65 on the next page is the system context diagram for the entire communication system. This diagram displays the source and destination of all the data flows. For purposes of simplification, a description of the data flows broken down by mode of operation is included on subsequent pages.

Wind2Battery System Context




Figure 65: W2B System Context Diagram

Basic GS

Figure 66 provides a layout of the data flow for the Basic GS (both wind-only and wind and grid charging) mode of operation. A system dispatcher logs in to GridPoint's administrator web page, selects the desired Basic GS mode of operation, and specifies the "Basic GS Parameters". The Basic GS parameters consist of the peak demand hour(s), wind scaling factor, discharge profile, and allowed charging times (including, if applicable, when charging from the grid is permissible)⁴⁸. GridPoint relays the Basic GS parameters to the PCS, which uses the parameters to determine the appropriate magnitude and timing for charging and discharging operation. Xcel Energy's TSO department sends either a kVAR or voltage set-point (depending on the configuration of the PCS) to GridPoint via EMS MN. GridPoint relays this set-point along to the PCS. Revenue grade metering information for both the battery and wind farm are sent to EMS MN by way of the RCY RTU. The RCY RTU also sends the power output of the wind facility to the PCS. GridPoint, TSO, EMS MN, and the system dispatcher all receive status information on the DESS in real-time.




Figure 66: System Context Flow for Basic GS Mode of Operation

⁴⁸ The maximum and minimum allowed SOC values can be specified for each mode of operation; as a result they are not explicitly mentioned when listing the available user-configurable parameters for each mode.

Wind Smoothing

Figure 67 provides a layout of the data flow for the Wind Smoothing mode of operation. A system dispatcher logs in to GridPoint's administrator web page, selects this mode, and specifies the "Wind Smoothing Parameters". The Wind Smoothing parameters consist of the wind scaling factor and the time constant for the 1st order lag function used by the PCS. GridPoint relays the Wind Smoothing parameters to the PCS, which uses the parameters to determine the appropriate magnitude and timing for charging and discharging operation. All other functionality is identical to that discussed in the description of the Basic GS mode of operation.




Figure 67: System Context Flow for Wind Smoothing Mode of Operation

Wind Leveling

Figure 68 provides a layout of the data flow for the Wind Leveling mode of operation. A system dispatcher logs in to GridPoint's administrator web page, selects this mode, and specifies the "Wind Leveling Parameters". The Wind Leveling parameters consist of the wind scaling factor and the desired combined power output of the effective wind farm and the DESS. GridPoint relays these parameters to the PCS, which uses the parameters to determine the appropriate magnitude and timing for charging and discharging operation. All other functionality is identical to that discussed in the description of the Basic GS mode of operation. Unlike the other modes, the user updates the desired power set-point on a high frequency basis (i.e. every 30-60 minutes) relative to the other user-configurable settings.




Figure 68: System Context Flow for Wind Leveling Mode of Operation

Frequency Regulation

Figure 69 provides a layout of the data flow for the Frequency Regulation mode of operation. A system dispatcher logs in to GridPoint's test administrator web page, selects this mode, and specifies the "AGC Parameters". The AGC parameters consist of the ACE scaling factor ("Scaling Factor"), the upper ACE dead-band factor ("AceDb_BatU"), and the lower ACE dead-band factor ("AceDb_BatL"). GridPoint relays this information to EMS MN along with real-time status information on the PCS. In addition to data it receives from GridPoint, EMS MN also receives the real-time ACE values from MISO via its existing Inter-Control Center Communications Protocol (ICCP) connection. EMS MN uses this information to generate a four-second frequency regulation signal within its AGC system for the DESS to follow. EMS MN sends this command to GridPoint who relays it on to the PCS. All other functionality is identical to that discussed in the description of the Basic GS mode of operation.




Figure 69: System Context Flow for Frequency Regulation Mode of Operation

Economic Dispatch

Figure 70 provides a layout of the data flow for the ED mode of operation. A system dispatcher logs in to GridPoint's test administrator web page, selects this mode, and specifies the "Economic Dispatch Parameters". The ED parameters are the most detailed of any of the required inputs from a system dispatcher, consisting of settings charge and discharge settings and rates for various SOC levels and pricing scenarios in the energy markets. In addition to the information GridPoint receives from the system dispatcher, it also receives daily award and pricing information from Xcel Energy's Commercial Operations department via an Xcel Energy-hosted FTP server. GridPoint uses this information to determine the appropriate magnitude and timing of charge and discharge signals when the battery is in the ED mode of operation. All other functionality is identical to that discussed in the description of the Basic GS mode of operation.




Figure 70: System Context Flow for ED Mode of Operation

References

- Denholm, Paul et al. “The Role of Energy Storage With Renewable Electricity Generation”. National Renewable Energy Laboratory. January 2010.
- EPRI-DOE Handbook of Energy Storage for Transmission and Distribution Applications, EPRI, Palo Alto, CA, and the U.S. Department of Energy, Washington DC: 2003
- Kirby, Brendan J. “Frequency Regulation Basics and Trends”. Oak Ridge National Laboratory. December 2004.
- Lutz, Brad et al. Xcel Energy Wind2Battery Project: Data Analysis Report (Draft). National Renewable Energy Laboratory. January 2010.
- Makarov, Y.V., et al. “Assessing the Value of Regulation Resources Based on Their Time Response Characteristics”. Pacific Northwest National Laboratory. June 2008.
- North American Electric Reliability Corporation (NERC). “Accommodating High Levels of High Variable Generation. April 2009.
- Ortech Power. “Wind Power Forecasting Pilot Project Part B: The Quantitative Analysis Final Report”. Submitted to The Alberta Electric System Operator. August 8, 2008.
- Walawalkar, Dr. Rahul. “Market Analysis of Emerging Electric Energy Storage Systems”. National Energy Technology Laboratory. July 31, 2008.
- Tewari, Saurabh and Mohan, Dr. Ned. “The Potential of Sodium Sulfur Battery Energy Storage to Enable Further Integration of Wind”. University of Minnesota. November 21, 2011.

List of Acronyms

Acronym	Definition
ACE	Area Control Error
AGC	Automatic Generation Control
Ah	Ampere-hours
ASM	Ancillary Service Market
BMS	Battery Management System
CAES	Compressed Air Energy Storage
CO ₂	Carbon Dioxide
CPNode	Commercial Price Node
DA	Day-Ahead (a MISO energy market)
DER	Distributed Energy Resource
DESS	Distributed Energy Storage System
DNP3	Distributed Network Protocol 3.0
DOD	Depth of Discharge
DSL	Digital Subscriber Line
ED	Economic Dispatch
EMS	Energy Management System
FERC	Federal Energy Regulatory Commission
FTP	File Transfer Protocol
GPI	Great Plains Institute
GS	Generation Storage
HMI	Human-Machine Interface
ICCP	Inter-Control Center Communications Protocol
IGBT	Insulated Gate Bipolar Transistors
LMP	Locational Marginal Price
MISO	Midwest ISO
MP	Market Participant
MWD	Minwind Energy LLC
NaS	Sodium Sulfur
NERC	North American Electric Reliability Corporation
NGK	NGK Insulators, LTD
NREL	National Renewable Energy Lab
NSP	Northern States Power
OCV	Open Circuit Voltage
PCS	Power conversion system
PLC	Programmable logic controller
RCY	Rock County
RGOS	Regional Generator Outlet Study
RSG	Revenue Sufficiency Guarantee
RT	Real-Time (a MISO energy market)
RTU	Remote Terminal Unit
S&C	S&C Electric
SER	Stored Energy Resource
SOC	State of Charge
TSO	Transmission Systems Operations
V	Volts
W2B	Wind To Battery Project

Table of Figures

Figure 1: Battery Photo	10
Figure 2: Power Generation from the Actual and Effective Wind Farms.....	12
Figure 3: 2009 Daily Average NSP Obligation Load Profile	14
Figure 4: Basic GS, Discharge Profile #1, Fully Charged (12/11)	16
Figure 5: Basic GS, Discharge Profile #1, Partially Charged (12/15)	16
Figure 6: Basic GS Discharge Profile #4, Fully-Charged (1/8)	17
Figure 7: Basic GS, Discharge Profile #1, Actual Wind Farm Output (12/25)	18
Figure 8: Normalized Discharge Energy Based on Change in State of Charge (Profile #1)	19
Figure 9: Normalized Discharge Energy Based on Change in State of Charge (Profile #4)	19
Figure 10: Basic GS: Wind Only Charging Operation (12/24-12/25)	20
Figure 11 Basic GS: Wind-Only Charging Operation (12/11-12/12).....	21
Figure 12: Basic GS: Wind-Grid Charging Operation (12/30-12/31).....	22
Figure 13: Average DESS Charge Energy for Basic GS Mode of Operation.....	22
Figure 14: Normalized Charge Energy Based on Change in State of Charge	23
Figure 15: Maximum Allowed Charge Rate as Function of SOC	23
Figure 16: DESS and Auxiliary Power Output (12/11)	24
Figure 17: Day-Ahead Market Scheduling Process (6/1-6/7).....	32
Figure 18: Day-Ahead Market Revenue (6/1-6/7).....	33
Figure 19: DESS System Performance Data and Requested Set-Point (6/1-6/7)	33
Figure 20: Activity / Obligations in the Real-Time Market (6/1-6/7).....	34
Figure 21: Real-Time Market Revenue (6/1-6/7)	34
Figure 22: Real-Time Market Activity (6/5).....	35
Figure 23: Gross Total Revenue (6/1-6/7)	36
Figure 24: High-Level Summary of ED Results (6/1-6/7).....	36
Figure 25: High-Level Summary of Weekly ED Results (6/1-6/7)	38
Figure 26: MISO ACE (3/4-3/5).....	41
Figure 27: Zoomed-In View of Frequency Regulation Mode of Operation (3/4-3/5)	42
Figure 28: Frequency Regulation Energy Requirements and DESS SOC (3/4-3/5).....	44
Figure 29: Frequency Regulation Energy Requirements and DESS SOC (3/24-3/25).....	45
Figure 30: Maximum Discharge Energy Requirements (3/4-3/5)	45
Figure 31: Accuracy and Responsiveness of DESS to Regulation Dispatch Signal.....	46
Figure 32: Block Diagram of Wind Smoothing Logic.....	48
Figure 33: Time Constant = 20 min; Scaling Factor = 43.3% (2/1)	50
Figure 34: Time Constant = 20 min; Installed Wind Capacity = 1 MW (2/15).....	53
Figure 35: Time Constant = 20 min; Installed Wind Capacity = 10 MW (1/24).....	54
Figure 36: Time Constant = 20 min; Installed Wind Capacity = 10 MW (1/23).....	55
Figure 37: Scheduled vs. Actual Wind Power Output, 1 MW Installed Wind Capacity (3/12)	61
Figure 38: DESS, Effective Wind, and SOC, 1 MW Installed Wind Capacity (3/12).....	62
Figure 39: Scheduled vs. Actual Wind Power Output, 5 MW Installed Wind Capacity (3/9)	62
Figure 40: DESS, Effective Wind, and SOC, 5 MW Installed Wind Capacity (3/9)	63
Figure 41: Scheduled vs. Actual Wind Power Output, 10 MW Installed Wind Capacity (3/11)	64
Figure 42: DESS, Effective Wind, and SOC, 10 MW Installed Wind Capacity (3/11).....	64
Figure 43: Percentage of Deviations within Allowed Range.....	65
Figure 44: NaS Cell Structure [ESA].....	84
Figure 45: Chemical Reaction of NaS Cell [NGK Literature].....	85
Figure 46: Chemistry of NaS Cell during Operation [EPRI].....	85
Figure 47: NaS Two-Phase and Single-Phase Chemistry (NGK Literature).....	86
Figure 48: NaS Battery Module [NGK Literature].....	87
Figure 49: Battery Temperature as a Function of Charging and Discharging	88

Figure 50: Outage Response Time as Function of Depth of Discharge [NaS Instruction Manual]	89
Figure 51: NGK Standard Discharge Profiles.....	91
Figure 52: Example of Standard NGK Battery Operation	91
Figure 53: Example of Non-Standard NGK Battery Operation.....	92
Figure 54: NGK Cycle Counting Logic	92
Figure 55: NaS Cycle Life as a Function of Depth of Discharge [EPRI]	93
Figure 56: NaS Battery Object Hierarchy	94
Figure 57: PCS Enclosures	97
Figure 58: PCS 1 Line Diagram.....	98
Figure 59: Overall System Efficiency.....	102
Figure 60: PCS Rectifier Efficiency	103
Figure 61: PCS Inverter Efficiency.....	104
Figure 62: W2B Technical Architecture Diagram	106
Figure 63: GridPoint Administrator Web page.....	107
Figure 64: External System Aggregator Concept	108
Figure 65: W2B System Context Diagram	109
Figure 66: System Context Flow for Basic GS Mode of Operation	110
Figure 67: System Context Flow for Wind Smoothing Mode of Operation.....	111
Figure 68: System Context Flow for Wind Leveling Mode of Operation	112
Figure 69: System Context Flow for Frequency Regulation Mode of Operation	113
Figure 70: System Context Flow for ED Mode of Operation.....	114

Table of Tables

Table 1: Modes of Operation	11
Table 2: 2009 Monthly Peak Demand Hours.....	13
Table 3: Maximum Allowed Charge Rates.....	15
Table 4: Basic GS System Performance Data Statistics Summary	25
Table 5: Basic GS Selected Discharge Results	26
Table 6: Basic GS: Wind Only Selected Charging Performance Data	26
Table 7: Basic GS: Wind and Utility Selected Charging Performance Data	26
Table 8: Basic GS All Discharge Results	27
Table 9: Basic GS: Wind Only All Charging Performance Data.....	28
Table 10: Basic GS: Wind and Utility All Charging Performance Data	29
Table 11: Economic Dispatch System Performance Data Statistics Summary	37
Table 12: MISO ACE Statistics	42
Table 13: DESS Frequency Regulation Performance Statistics (3/4-3/5)	43
Table 14: Frequency Regulation System Performance Data Statistics Summary	47
Table 15: Effective Wind and Total Ramping Statistics for Selected Ramping Periods	52
Table 16: DESS Ramping Statistics for Selected Ramping Periods.....	52
Table 17: Wind Smoothing System Performance Data Statistics Summary	56
Table 18: Effective Wind and Total Ramping Statistics for all Ramping Periods	57
Table 19: DESS Ramping Statistics for all Ramping Periods	58
Table 20: Relative Allowed Deviations in Scheduled vs. Actual Wind Power as a Function of Wind Capacity	65
Table 21: Wind Leveling System Performance Data Statistics Summary	66
Table 22: NaS Battery Pros and Cons.....	83
Table 23: General 1 MW Battery Specifications	95
Table 24: Nominal Specifications for DESS	96
Table 25: PCS Types of Modes of Operation	100
Table 26: DESS Efficiency Test Data.....	102



UNIVERSITY OF MINNESOTA

FINAL PROJECT REPORT

The Potential of Sodium Sulfur Battery Energy Storage to Enable Further Integration of Wind

Saurabh TEWARI and Prof. Ned MOHAN

Department of Electrical Engineering, University of Minnesota

Minneapolis, MN

November 21, 2011

Preface

The presented report attempts at evaluating the economic and functional feasibility of coupling energy storage with a wind farm in the context of the 1 MW, 7.2 MWh Sodium Sulfur (NAS) battery owned by Xcel Energy and a 11.55 MW wind farm in Luverne, MN owned by Minwind Energy LLC. In addition to evaluating the operation when the battery is directly coupled to the wind farm, additional modes that use the battery independently are also studied in the context of the energy and ancillary services markets managed by the Midwest Independent Transmission System Operator, Inc. (MISO).

The theme across all analyses is to study the ability of NAS battery storage to add flexibility to the power system towards making the system more accommodating to higher penetration of wind generation.

We would like to thank Xcel Energy for the opportunity to work on this project and for providing the necessary data and framework. In particular we would like to thank the following individuals from Xcel Energy for their cooperation and feedback: Frank J. Novachek, Nancy L. Pellowski, Albert S. Choi, Mohit Chhabra, Stephen J. Beuning, Liam D. Noailles, David A. Stevens, Sean E. Gale, and most notably James B. Himelic. We would also like to thank Rao Konidena from MISO, and David Porter and John McBride from S&C Electric Company.

Additional financial support from the Initiative for Renewable Energy and the Environment (IREE), University of Minnesota, is gratefully acknowledged.

Sincerely,
Saurabh Tewari
Prof. Ned Mohan

Contents

Preface	i
1 W2B for optimum benefit to grid operations	1
1.1 Basic generation shifting	1
1.1.1 Wind-grid charging	2
1.1.2 Wind-only charging	5
1.2 Ramp-rate limiting	13
1.2.1 Simulation of ramp rate limiting	14
1.2.2 Results from the actual system operation: Part I	18
1.2.3 Results from the actual system operation: Part II	19
1.2.4 Extended simulation results	21
1.2.5 Ramp rate limiting as a secondary function	23
2 Economic dispatch and commercial location strategy	27
2.1 Economic Dispatch	27
2.2 Commercial Location	27
2.3 Value in the Ancillary Services Market (ASM)	33
2.3.1 Data, resource offer, and key assumptions	33
2.3.2 Mehtodology	34
2.3.3 Monte Carlo simulation	37

List of Tables

1.1	Peak demand hours (Year 2009)	2
1.2	Extended simulation results	22
2.1	Nodes identified for economic dispatch analysis.	29
2.2	Revenue statistics	38
2.3	Revenue/usage statistics	38

List of Figures

1.1	NSP load for different months (Year 2009)	1
1.2	Wind-grid charging	4
1.3	Simulated charging and discharging for wind-only scenario	5
1.4	Distribution of maximum SOC attained for wind only charging	7
1.5	(a) Positive and (b) negative contributors to the value of generation shifting.	11
1.6	Results from wind-only charging	11
1.7	Ramp rate of the wind farm	13
1.8	Block diagram for simulating ramp rate limiting	15
1.9	Ramp rate with $T = 2400$ s	15
1.10	Battery power and SOC with $T = 2400$ s	16
1.11	Ramp rate with $T = 120$ s	16
1.12	Battery power and SOC with $T = 120$ s	17
1.13	Ramp rate from the actual runs of the system with $T = 120$ s	18
1.14	Ramp rate from simulation using data and settings of Fig. 1.13	18
1.15	Battery power during testing the ramp rate limiting (Part I)	19
1.16	Battery power during testing the ramp rate limiting (Part II)	19
1.17	(a) Actual and (b) simulated ramp rates for an effective 5 MW wind scenario with $T = 1200$ s	20
1.18	Ramp rates for the MINWIND wind farm for the year 2007	21
1.19	Ramp rate with $T = 120$ s with basic GS combined. Effective wind farm rating = 5 MW	23
1.20	Battery SOC and power with basic GS and ramp rate limiting combined.	23
1.21	Comparison of ramp rates with and without combining basic GS	25
2.1	Results from location analysis: best nodes	30
2.2	Results from location analysis: poor nodes	31
2.3	Economic dispatch: Per cycle v. per day.	32
2.4	Prices and price sensitive offer	34
2.5	Storage operation in MISO ASM	36
2.6	Results from Monte Carlo method	37
2.7	Distribution of revenue/usage for different values of the scaling factor.	38

Chapter 1

W2B for optimum benefit to grid operations

1.1 Basic generation shifting




Figure 1.1: NSP load for different months (Year 2009). Data source: 2009 peak demand.xls

Fig. 1.1 shows the monthly demand on NSP for the year 2009 and Table 1.1 tabulates the hours arranged

in the order of decreasing demand for each month.

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
19	19	10	11	12	14	15	15	14	19	18	18
18	20	11	12	13	13	14	14	15	11	19	19
20	21	12	10	11	15	16	16	16	10	20	20
21	18	20	13	14	16	13	13	13	18	17	21
11	11	9	9	15	12	17	17	12	12	21	17
12	12	13	14	10	11	12	12	17	13	12	11
10	10	19	20	16	17	11	11	11	9	11	12
13	9	8	15	17	10	18	18	19	20	13	10
9	13	14	8	9	18	10	10	20	14	14	22
17	14	21	16	18	19	19	20	18	17	10	13
14	8	15	17	21	9	20	19	10	8	15	9
8	15	18	21	20	20	21	21	21	15	16	14
22	17	16	19	19	21	9	9	9	16	9	16
15	22	7	18	8	8	8	8	8	7	22	15
16	16	17	7	22	22	22	22	22	21	8	8
7	7	22	22	7	7	7	7	7	6	7	23
23	23	6	6	6	23	23	23	6	22	23	7
24	24	23	23	23	6	6	6	23	23	24	24
6	6	5	5	24	24	24	24	24	5	6	6
1	1	24	24	5	5	1	5	5	24	1	1
2	5	1	1	1	1	5	1	1	1	2	2
5	2	4	4	4	2	2	2	2	4	5	5
3	3	2	2	2	4	4	4	4	2	3	3
4	4	3	3	3	3	3	3	3	3	4	4

Table 1.1: Hours arranged in the order of decreasing demand (Year 2009). Data source: 2009 peak demand.xls

There is value in shifting the generation from the periods of low load (“off-peak”) to the periods of higher load (“on-peak”) to even out the variations in load, and energy storage is the only option towards this task (shifting generation). It is possible to even out the variations in load profile by demand management; however, that is not the scope of current research.

Generation shifting is attractive for wind generation too because wind generation by its very nature does not lend itself to guaranteed on-peak availability. The current mode of operation investigates the ability of the battery to shift generation from off-peak to on-peak. Two modes are tested: (a) Wind-grid charging, in which the battery is allowed to charge from wind and grid, both, during off peak hours and (b) Wind-only charging, in which battery is allowed to charge only from wind generation. The former mode tests the ability of battery to shift the generation while the latter seeks to find the ratio of storage to wind, to shift wind generation successfully.

1.1.1 Wind-grid charging

The purpose of this mode was to validate that the battery can be brought to a 100% SOC with grid support, without exception, to effectively shift the generation. Data for this mode was collected for the week starting May 18, 2011 and ending May 24, 2011.

The designated charging and discharging hours were chosen based on historical demand on NSP for the year 2009. The specified designated charging hours were HE22, HE23, HE24, HE01, HE02, HE03, HE04; and HE05 if needed. The specified designated discharging hours were HE11, HE12, HE10, HE13, HE14, HE09, HE15 (in this priority). The choice of scaling factor does not influence the results for this mode because any

amount of power can be drawn from the grid. Still, for completeness the scaling factor was set to 10/11.55 corresponding to a 10 MW wind farm.

The results from this mode are plotted in Fig. 1.2. The designated charging hours are an hour ahead of the specifications because of daylight savings. The designated discharging hours differ because of the way the DESS works under this mode — the discharge period needs to be centered at the hour of maximum demand.

Even though there is some offset between the specified and actual periods, the conclusions are not affected:

- The battery SOC is successfully brought to 100% before the beginning of every discharge period.
- The battery is able to shift generation from periods of low demand (late night - early morning) to periods of high demand (morning - afternoon). Please note that the periods of high/low demand depend upon the season and the month, and the specific periods in Fig. 1.2 correspond to the month of May. At the same time, it is understood that the system will work in this mode for any month/season upon proper choice of specifications.

Note that in most cases, enough wind generation is available to charge the battery. How often the wind generation falls short is investigated in the next task.




Figure 1.2: Wind-grid charging: The plot titles are the dates for which the data was collected. The green plot is the SOC, the blue plot is the power supplied by the battery ($-ve$ sign implies charging), and the red plot is the power available to the battery from wind generation only. The power available from wind generation is saturated at 1 MW for clarity. Data source: \sim/U of Mn Analysis/u of mn data dump/5_18_pi.xls. Additional files used: W2B_May_18_to_24_extracted.xls, process_May_18_to_24.m

1.1.2 Wind-only charging

In this section the ability of battery to shift the *wind-only* generation from off-peak to on-peak is evaluated. The simulation is carried out at different values of the scaling factor to effectively vary the ratio of storage to wind generation.

Real charging/discharging data for this mode was not available to us; however, as evidenced from Fig. 1.2, the battery characteristics are near ideal since it can operate at its rated power (± 1 MW) for extended periods of time. Following parameters and data were used:

1. 1 MW, 7.2 MWh battery with ideal charging characteristics: the battery can be charged at its rated power continuously.
2. DC efficiency = 85% [1]
3. Wind generation data for the year 2007 from the 11.55 MW MINWIND wind farm. The power generation time series was multiplied by 1, 10/11.55, 5/11.55, 2.5/11.55 and 1/11.55 to simulate wind farm rating ranging from 11.55 MW down to 1 MW for the same 1 MW battery. Data was available for 360 days.
4. 8 designated charging hours and 6 designated discharging hours for each different month were chosen from Table 1.1.
5. Day-Ahead (DA) and Real-Time (RT) Locational Marginal Prices (LMPs) for MINN HUB of Midwest ISO (MISO) for the year 2009.

Although the wind generation data was available for the year 2007, it is treated as though it was from the year 2009. This is not an issue because the wind patterns change over a much slower time scale.

The battery losses were assumed to be geometrically distributed between charging and discharging. Therefore for every MWh drawn from the wind farm, the stored energy was simulated to increase by $\sqrt{0.85}$ MWh while for every MWh supplied, the stored energy was simulated to decrease by $1/\sqrt{0.85}$ MWh, resulting in a net efficiency of 85%. The minimum SOC was set to $\sim 10\%$. Under the assumption made about distributing losses and this setting for minimum SOC, the battery would be able to discharge for about 6 hours during on-peak.





Figure 1.3: Simulated charging and discharging for wind-only scenario

Fig. 1.3 shows the simulated charging/discharging for a day in May 2009. The bold blue plot is the wind generation, the bold green plot is the SOC and the dashed red line is generation = 1 MW. The designated


charging period begins at 2200 hours and ends at 0600 hours. The designated discharging period begins at 0900 hours and ends at 1500 hours.

It is seen that the battery charges at full power up to 100% SOC and discharges down to $\sim 10\%$ SOC at the end of designated discharging period of 6 hours.


The charging was simulated for different scaling factors and the maximum SOC for each day was recorded. The distribution of maximum SOC attained for different scaling factors is plotted in Fig. 1.4.




(a) 11.55 MW wind farm




(b) 10 MW wind farm



(c) 5 MW wind farm



(d) 2.5 MW wind farm



(e) 1 MW wind farm

Figure 1.4: Distribution of maximum SOC attained for wind only charging for different values of the scaling factor. The effective rating of the wind farm after scaling is mentioned under each subfigure. The numbers right of the dashed lines are the % exceedances of the maximum SOC attained at dashed lines. E.g. in (a) the battery attains a SOC higher than 0.9 for 73.61% of days.

Data source: `~/BaicGS/Data.and.Analysis/Wind.only.charging.extended/power1yr.txt` Additional files used: `wind_only.m`, `README.txt` contained in the same folder.

Optimal ratio of storage to wind

If it is desired that the storage be able to supply during 6 hours of highest load everyday, and the battery parameters like efficiency and maximum depth of discharge (DOD) are fixed, then the MWh to MW ratio of the storage gets fixed. In the case of this battery, this ratio is 7.2 MWh per MW. For this ratio, 85% efficiency and 90% DOD, the battery would be able to serve 6 peak load hours.

With the MWh/MW of battery fixed, the optimal ratio of storage to wind is essentially the inverse of installed wind per MW storage. In this analysis this ratio (storage/wind) is varied from 1/11.55, up to 1/1. It is intuitively clear that the optimal ratio would depend upon the value in generation shifting, that can be broken into:

- Revenue from discharging the battery at peak load. The electricity prices tend to follow the load and it is reasonable to expect that prices would be higher at peak load.
- Savings from avoiding costlier peaking generation.
- Inherent value in making wind generation available on peak:
 - Avoided greenhouse emissions from fossil fuel based peaking generators and carbon credits.
 - Maximization of the wind generation value by mitigating the scenarios in which wind generators need to curtail their output in event of low load.
 - Qualification (of wind generators) as a reliable system resource with guaranteed on peak availability and capacity value.
- Inherent value of storage: storage installed primarily to enable guaranteed on peak availability of wind generation can be used as a system resource with, but not limited to the following, secondary benefits:
 - Up/Down regulation capability (please see section 2.3 on page 33).
 - Limiting the ramp rate of wind generation (please see section 1.2.5 on page 23).

It is relatively straight forward to attach a \$ amount to some of the value propositions above (e.g. energy arbitrage) while some are not so easily characterized in terms of dollars (e.g. environmental benefits). For the purpose of this work, the \$ amounts for the following value propositions have been considered:

- Energy arbitrage.
- Avoided cost of peaking generation.
- Value in letting wind generators operate during low load, quantified in terms of the Production Tax Credit (PTC)¹.

The value from other applications of storage is evaluated in other sections of this report.

Procedure

For this analysis, the battery is offered as a 1 MW load in the MISO DA markets for the 8 hour designated charging period and as a generator for the 6 hour designated discharging period.

- The Asset Owner (AO) pays the DALMP for the charging period and receives the DALMP for the discharging period.

¹Per the discussion on 11/10/2011 at Xcel Energy (Minneapolis), it should be noted that only part of this value is realized by the utility under a model in which the utility guarantees the PTC to the wind farm owner regardless of the curtailment. The specific proportion is a function of wind penetration

- It is possible that the battery attains 100% SOC before the end of the charging period in which case the energy bought in the DA market is sold at the RTLMP. In an event of battery not being at 100% SOC at the beginning of discharging period, the energy committed in the DA market is bought from the RT market (true up). Since this mode allows the storage to charge *only* from wind, in an event when enough wind energy is not available to charge the storage at its maximum rate (1 MW), the AO still pays the DALMP but receives the RTLMP multiplied by the MWs the wind generation falls short of 1 MW.
- Further, for every MWh generated that goes towards charging the battery, the total value of Generation Shifting is increased by the Production Tax Credit (PTC) for wind; the value of PTC available from EIA [2] is 19 \$/MWh in 2003 dollars that is adjusted to 22.23 \$/MWh in 2009 dollars using an inflation rate of 1.17 from the Bureau of Labor Statistics [3].
- Finally, it is assumed that the peak generation is served by Combustion turbines in absence of stored energy. Therefore, savings corresponding to the difference between the levelized cost of wind generation (48 \$/MWh) and Combustion turbines based generation (70 \$/MWh) are added for every MWh of peak load served. The data for the levelized cost of generation available from [2] in 2003 dollars and is adjusted for inflation in accordance with [3]. However, the cost of wind generation is assumed without crediting the Production Tax Credits. If the PTC is included, the levelized cost of wind generation would reduce down to 29 \$/MWh.

Define the following:

MWh_WIND	Energy generated by wind during designated charging period
DA_VOL	Volume cleared in DA market
E_WIND	Energy supplied by wind generation, to the battery
E_PEAK	Energy served by storage at peak load
RT_VOL	Adjustments made in RT market
E_PEAK _{max}	Maximum possible energy that could be served by storage at peak load
PTC	Production Tax Credits in 2003 dollars [2]
c_WIND	Levelized cost of wind generation in 2003 dollars [2]
c_COMB	Levelized cost of Combustion turbine generation in 2003 dollars [2]
$k_{2003,2009}$	Inflation rate [3]

Some of the quantities above are taken from the cited sources while others are calculated as

$$\begin{aligned}
DA_VOL &= \begin{cases} -1 & \text{during designated charging period} \\ +1 & \text{during designated discharging period} \end{cases} \\
E_WIND &= \begin{cases} \min(MWh_WIND, 1) & \text{during designated charging period if SOC} < 1 \\ 0 & \text{otherwise} \end{cases} \\
E_PEAK &= \begin{cases} 1 & \text{during designated discharging period if SOC} > 0.1 \\ 0 & \text{otherwise} \end{cases}
\end{aligned}$$

With the definitions above, the RT_VOL can be written as

$$RT_VOL = \begin{cases} -DA_VOL - E_WIND & \text{during designated charging period} \\ -DA_VOL + E_PEAK & \text{during designated discharging period} \\ 0 & \text{otherwise} \end{cases}$$

The maximum possible energy that could be served at peak load (E_PEAK_{max}) is simply 6 MWh energy for every operating day.

The revenue from the perspective of the battery AO can therefore be written as

$$\begin{aligned} \text{REVENUE} = & \sum_{\text{day}=1}^{360} \sum_{\text{hour}=1}^{24} \text{DA_VOL}_{\text{day,hour}} \times \text{DA_LMP}_{\text{day,hour}} + \text{RT_VOL}_{\text{day,hour}} \times \text{RT_LMP}_{\text{day,hour}} \\ & + k_{2003,2009} \times \text{E_WIND}_{\text{day,hour}} \times \text{PTC} \end{aligned} \quad (1.1)$$

The additional savings on the system level by avoiding costlier generation would be

$$\text{SAVINGS} = \sum_{\text{day}=1}^{360} \sum_{\text{hour}=1}^{24} (\text{c_COMB} - \text{c_WIND}) \times \text{E_PEAK}_{\text{day,hour}} \times k_{2003,2009} \quad (1.2)$$

And the total value of generation shifting quantified in this analysis would be the sum of revenue and savings from (1.1) and (1.2). Other quantities of interest are: the ratio of generation shifted – the ratio of energy served on peak against the total wind generation off peak; the ratio of storage utilized – the ratio of energy served on peak against the maximum possible energy that could have been served on peak; and the ratio of revenue against energy served on peak.

For every MWh served on peak, the battery incurs loss in its lifetime and in that sense the ratio of revenue against energy served on peak could be a measure of the return on investment (ROI). The listed quantities can be defined as

$$\begin{aligned} \text{Ratio shifted} &= \frac{\text{E_PEAK}}{\text{MWh_WIND}} \\ \text{Storage utilized} &= \frac{\text{E_PEAK}}{\text{E_PEAK}_{\text{max}}} \\ \$/\text{MWh served} &= \frac{\text{REVENUE} + \text{SAVINGS}}{\text{E_PEAK}} \end{aligned}$$

Results

Fig. 1.5 shows the positive and negative contributions to the value of generation shifting. Positive contributions are from selling the stored energy in DA market during designated discharging, selling excess energy during designated charging in the RT market, PTC, and additional savings realized by avoiding costlier generation.

Negative contributions are from buying the energy to charge the battery in DA market during designated charging, and from having to buy energy during designated discharging in event of deficient SOC.

The net value is the difference between the aggregated positive contribution and aggregated negative contribution. The net value along with the \$/MWh served is plotted in Fig. 1.6(a). The ratio of generation shifted, and the ratio of storage utilized are also plotted alongside in Fig. 1.6(b).




Figure 1.5: (a) Positive and (b) negative contributors to the value of generation shifting.




Figure 1.6: Results from wind-only charging: (a) Net value and the \$/MWh served, and (b) ratio of generation shifted and the ratio of storage utilized against installed wind

Discussion

Although the objective is to find the optimal ratio of storage to wind, in this analysis the storage is considered fixed and installed wind is simulated to increase from 1 MW to 11.55 MW. The battery is offered in the DA market as a generator or load without regard to the installed wind. Therefore the positive and negative contribution to the value from DA market is fixed as seen in Fig. 1.5. When the installed wind is low, E_WIND, the energy supplied by wind to charge the battery is also low and therefore the RT_VOL during designated charging period is high. However, with low installed wind it also more likely that the SOC would be deficient (Fig. 1.4(e)) and therefore RT_VOL during designated discharging period is also high — the positive and negative contribution of RT market towards the value of generation shifting is high with low installed wind, most prominently so in the 1:1 storage to wind scenario (Fig. 1.5). It is not desirable to expose the asset to the RT market because of the volatility, and high exposure to RT market is a drawback for low installed wind scenarios.

Furthermore, because of low production owing to lower installed capacity, the PTC is naturally lower. So are the additional savings because less on peak energy is displaced by stored wind energy (Fig. 1.5). Consequently, the value of generation shifting is low with lower installed wind as seen in Fig. 1.6(a).

Therefore, on the basis of net value addition and exposure to RT market it seems that a lower storage to wind ratio is favorable.

However, the ratio of shifted generation is significantly better at lower installed wind (Fig. 1.6(b)). This is important because the objective is to enhance the on peak availability of wind. Larger ratio of shifted generation means higher contributions from the value propositions not considered, e.g. reduced greenhouse emissions and qualification of wind as a reliable resource.

Finally, the value addition per MWh served (\$/MWh served) seems to be fairly similar for all scenarios except the 1:1 case in Fig. 1.6(a). If the 1:1 case is not considered any further because of significantly lower value addition in the absolute terms and in terms of per MWh served, the comparison is between the other four scenarios.

Concluding remarks

The 5 MWh installed wind scenario is comparable to even higher wind scenarios in its exposure to RT market and \$/MWh served, with only slightly lower net value addition and approximately double the generation shifting. It seems to be a balanced choice with attractive features of both, higher and lower wind scenarios.

The 2.5 MW scenario shifts significantly higher proportion of wind than the 5 MW scenario at similar \$/MWh served but at slightly higher exposure to RT market and somewhat lower net value addition. However, it could easily compete if the value from other propositions is included. Therefore the truly optimal scenario would be somewhere in the range of 2.5 MW – 5 MW installed wind per MW storage. Alternatively, the optimal ratio of storage to wind for the sole purpose of shifting wind-only generation is 200 – 400 kW storage per MW installed wind, under the obligation that storage should be offered as a generating resource for 6 peak load hours everyday.

1.2 Ramp-rate limiting

The objective of this mode was to evaluate the ability of the 1 MW, 7.2 MWh sodium sulfur (NAS) battery to limit the ramp rate of the power output of the 11.55 MW MINWIND wind farm. It is desirable for the system operation that the changes in electric power generation be slow and smooth; however, the output of an individual wind farm could vary quite fast as seen in Fig. 1.7.




Figure 1.7: Ramp rate of the wind farm. Data corresponds to 12/10/2009 – 12/15/2009 at an approximate resolution of one sample per minute.

One of the techniques to limit the ramp rate is to pass the wind generation time series through a low pass filter and compensate for the difference between the low pass filter's output and actual wind generation using storage. This amounts to injecting the low pass filter's output into the grid, assuming that the battery can compensate for the difference at all times. It is first shown how the low pass filter's output would have a smaller ramp rate and an upper bound on its ramp rate is established. Later the system is simulated for the verification of this technique.

Low pass filter to limit the ramp rate

Let us represent the per-unit wind generation by w : $w(t) \in [0, 1]$, and the ramp rate of filtered wind generation by r . Let the time constant of the low pass filter be called T ; the low pass filter can be written as,

$$\begin{aligned} H(s) &= \frac{1}{sT + 1} \\ h(t) &= \frac{e^{-t/T}}{T} u_s(t), \quad u_s(t) \text{ is unit-step} \end{aligned} \tag{1.3}$$

Also,

$$\mathcal{L}\{w(t)\} = W(s)$$

The “filtered” wind power output is $H(s)W(s)$. Ramp rate of the filtered output, $r(t)$, is the derivative of $h(t) * w(t)$, or equivalently $R(s) = sH(s)W(s)$ (in frequency domain). ‘ $*$ ’ denotes the convolution operation.

$$\begin{aligned}
R(s) &= sW(s)H(s) \\
&= \frac{sW(s)}{sT + 1} \\
&\equiv \underbrace{\frac{s}{sT + 1}}_{:=G(s)} \times W(s)
\end{aligned} \tag{1.4}$$

Unfiltered wind generation w is the input to the system G defined in (1.4), and the output of this system is the ramp-rate, r .

$$\begin{aligned}
G(s) &= \frac{s}{(sT + 1)} \\
&= 1/T \left(1 - \frac{1}{sT + 1} \right) \\
\Rightarrow g(t) &= \mathcal{L}^{-1}\{G(s)\} \\
&= \frac{1}{T} \left(\delta(t) - \frac{1}{T} e^{-t/T} u_s(t) \right)
\end{aligned} \tag{1.5}$$

$$\begin{aligned}
R(s) &= G(s)W(s) \xrightarrow{\mathcal{L}^{-1}} g(t) * w(t) \\
&= \int_{-\infty}^{\infty} g(t - \tau) w(\tau) d\tau \\
&= \frac{1}{T} \int_{-\infty}^{\infty} \left(\delta(t - \tau) - \frac{1}{T} e^{-(t-\tau)/T} u_s(t - \tau) \right) w(\tau) d\tau \\
&= \frac{1}{T} \left(\int_{-\infty}^{\infty} \delta(t - \tau) w(\tau) d\tau - \int_{-\infty}^{\infty} \frac{1}{T} e^{-(t-\tau)/T} u_s(t - \tau) w(\tau) d\tau \right) \\
&= \frac{1}{T} (w(t) - h(t) * w(t)), \quad \text{where } h \text{ is the system in (1.3)}
\end{aligned} \tag{1.6}$$

From the theory of linear systems,

$$\begin{aligned}
|r(t)| &\leq \frac{1}{T} \left(\|w\|_{\infty} + \|w\|_{\infty} \int_{-\infty}^{\infty} |h(t)| dt \right) \\
&= \frac{2}{T} \|w\|_{\infty}
\end{aligned} \tag{1.7}$$

Since $\|w\|_{\infty} = 1\text{pu}$, the absolute ramp rate of the output is bounded by $2/T$ where T is the chosen time constant.

1.2.1 Simulation of ramp rate limiting

Fig. 1.8 shows the block diagram of the system. In addition to the ramp rate limiting section, there is a proportional controller to keep the SOC at the desired setpoint. The controller constant must keep the SOC close to the setpoint but at the same time it must not result in excessive control effort. Minimizing the disturbances in SOC is advantageous because it leaves the energy stored in the battery available for other applications as described later. The sub-unity battery efficiency is not considered in this analysis because the closed loop SOC controller can compensate for it.




Figure 1.8: Block diagram for simulating ramp rate limiting

Simulations indicate that the upper bound on the ramp rate obtained from the preceding analysis might be too high for practical purposes. While a time constant chosen according to this upper bound should theoretically work, the control effort requested would be too high, at times violating the ± 1 MW limit on the battery output. Fig. 1.9 shows the ramp rate of the unfiltered wind farm generation, theoretical ramp rate of the low pass filtered output, and the ramp rate of the simulated output of the system with power and energy constraints applied when the time constant was chosen to limit the ramp rate to 0.05 pu/minute.




Figure 1.9: Ramp rate with $T = 2400$ s

It is seen that while the ramp rate of the ideal output is well below the desired limit, the ramp rate of the actual output occasionally exceeds the limit. Fig. 1.10 shows the plot of battery power output and SOC for this case, and it is clear that the violations in the ramp rate are not because of the battery reaching its energy limit, but because of the high control effort (power) requested.

To alleviate this problem, it is necessary to reduce the time constant below the theoretically obtained number and simulate with different values to achieve an acceptable limit. For a limit of 0.05 pu/minute, the




Figure 1.10: Battery power and SOC with $T = 2400$ s

simulations indicate that a time constant of 120 (2 minutes) keeps the system ramp rate under limit most of the times. Fig. 1.11 shows the ramp rates of the generation, ideal output and actual output for this time constant. It is seen that the performance is in fact slightly better than the $T = 2400$ case. Also, as seen from Fig. 1.12, the control effort rarely exceeds the ± 1 MW limit. Finally, with the lower time constant, the SOC is confined to a much tighter band (compare Figs. 1.10 and 1.12)




Figure 1.11: Ramp rate with $T = 120$ s




Figure 1.12: Battery power and SOC with $T = 120$ s

1.2.2 Results from the actual system operation: Part I

Simulation results presented above indicate that a time constant of 120 seconds keeps the violations of the 0.05 pu/minute ramp rate limit reasonably low. The system was run with this time constant and data was collected at a resolution of 1 minute for one week beginning 05/29/2011. The ramp rates are plotted in Fig. 1.13




Figure 1.13: Ramp rate from the actual runs of the system with $T = 120$ s

The ramp rate of the system output is no better than the ramp rate of unfiltered generation; this is in stark contrast against the simulation results using the same data and time constant setting plotted in Fig. 1.14. It is clear that the system operation does not correspond to the block diagram of Fig. 1.8, which it




Figure 1.14: Ramp rate from simulation using data and settings of Fig. 1.13

ideally should. This is also evidenced from the plot of battery power (Fig. 1.15) during the period of study.

More data was collected at a larger time constant and finer resolution (10 s). However, there was no improvement in the output ramp rate and the battery displayed exhibited periods of inactivity similar to Fig 1.15. The block diagram simulated was verified to be correct by S&C and we believe that the problem lies with its implementation. The issue stands unresolved as of now.




Figure 1.15: Battery power during testing the ramp rate limiting (Part I)

1.2.3 Results from the actual system operation: Part II

Although the assertion that a time constant much smaller than the one theoretically obtained would suffice could not be verified because of unresolved issues, other experimentally obtained data sets exist that establish the validity of simulation results.

The information from one of such data sets corresponding to an approximately 16 hour long interval during 01/31/2010 – 02/01/2010 is now presented. The scaling factor was set to 0.433 to emulate a 5 MW installed wind scenario; a time constant of 1200 s (20 minutes) was used. Theoretically the ramp rate would always be bound by 0.1 pu/minute with this time constant, provided that the battery can always source/sink the requested power. The unfiltered generation, compensation from storage and the total system output is plotted in Fig. 1.16. The total output is visibly smooth. The ramp rates of the unfiltered generation and the total system output are shown in Fig. 1.17(a). The ramp rates obtained from simulation using the same generation data under the same settings are shown in Fig. 1.17(b).






Figure 1.16: Unfiltered generation, compensation from the battery, and the total power output with 5 MW installed wind scenario and $T = 1200$ s



(a) Actual ramp rates of the system with $T = 1200$ s



(b) Ramp rate from simulation using data and settings of Fig. 1.17(a)

Figure 1.17: (a) Actual and (b) simulated ramp rates for an effective 5 MW wind scenario with $T = 1200$ s

Key observations

- The battery is able to limit the ramp rate effectively.
- The total ramp rate is restricted to a value significantly smaller than the analytical upper bound.
- There is very good correspondence between the simulated and actual results.
- The slight differences between the actual results and the simulation are attributed to the simulation program used: MATLAB/Simulink chooses the time step automatically and uses interpolation that might result in slight softening of the ramp rates.

1.2.4 Extended simulation results

With confidence in the simulation model, different scenarios were simulated using generation data from the MINWIND wind farm for the year 2007 at a resolution of 1 minute. The unfiltered ramp rates for this data are plotted in Fig. 1.18. A total of 30 cases were simulated with the time constants (minute) varying in $\{2, 5, 10, 20, 40, 80\}$, and the installed wind (MW) varying in $\{1, 2.5, 5, 10, 11.55\}$ for a period spanning an year, totaling a simulated time of 30 years. It is expected that the year long simulations would average out the seasonal variations in the wind.




Figure 1.18: Ramp rates for the MINWIND wind farm for the year 2007

The results from simulations are tabulated in Table 1.2. It is seen that storage succeeds in mitigating the ramp rates of Fig. 1.18 in all cases. However, the effectiveness of storage depends upon the time constant and the installed wind — with higher installed wind and at higher time constants, the violations in the ramp rates at all limits (0.01, 0.5, and 0.1 pu/minute) tend to increase. Even though the results are always better than the unfiltered generation, it is not hard to see that increasing the time constant beyond a limit is contrary to its intended purpose.

The explanation for this unintended behavior is the limited MW capability of the storage, as discussed earlier in the context of Figs. 1.9 and 1.10. It was also seen that the performance is independent of the battery MWh capacity, provided the MWh capacity is sufficiently large, as is the case for the NAS battery in question.

Therefore the optimal storage MW/wind MW ratio for ramp rate limiting would depend upon the time constant chosen. Alternatively, the ratio could be picked from Table 1.2 once the specifications on the allowable ramp rates are set.

Installed wind (MW)	Time constant (min)	% exceedance at		
		0.01 (pu/min)	0.05 (pu/min)	0.1 (pu/min)
11.55	2	25.37	0.63	0.23
	5	15.88	0.95	0.26
	10	10.03	1.22	0.29
	20	7.72	1.46	0.31
	40	8.71	1.68	0.33
	80	10.05	1.85	0.35
10	2	25.41	0.6	0.16
	5	16.1	0.7	0.21
	10	10.28	0.93	0.24
	20	6.8	1.14	0.25
	40	6.72	1.33	0.27
	80	7.72	1.48	0.29
5	2	25.46	0.76	0.04
	5	16.43	0.14	0.05
	10	11	0.17	0.07
	20	6.94	0.23	0.08
	40	4.31	0.29	0.09
	80	2.85	0.33	0.09
2.5	2	25.46	0.77	0.05
	5	16.45	0.19	0.01
	10	11.08	0.06	0.01
	20	7.11	0.03	0.01
	40	4.55	0.03	0.02
	80	3.12	0.04	0.02
1	2	25.48	0.79	0.07
	5	16.49	0.21	0.02
	10	11.13	0.09	0
	20	7.17	0.03	0
	40	4.62	0.01	0
	80	3.19	0	0




Table 1.2: Extended simulation results in tabular and graphical format. The effect of insufficient storage MWs is seen at higher time constants and higher installed wind cases: the entries in red correspond to the cases when violations in the ramp rate start to increase upon increasing the time constant.

1.2.5 Ramp rate limiting as a secondary function

It is seen from Fig. 1.12 that the battery SOC is confined to a tight band. If the SOC setpoint in the block diagram of Fig. 1.8 is replaced by an appropriate time varying SOC profile, it should be possible to have the battery shift the wind generation while limiting the ramp rate.

We carried out a simulation with the SOC setpoint replaced by an appropriate SOC profile and recorded the ramp rates. The results are plotted in Fig. 1.19. The battery SOC is plotted in Fig. 1.20(a) and the battery power output is plotted in Fig. 1.20(b).






Figure 1.19: Ramp rate with $T = 120$ s with basic GS combined. Effective wind farm rating = 5 MW



(a) SOC with $T = 120$ s with basic GS and ramp rate limiting combined.



(b) Battery power output with $T = 120$ s with basic GS and ramp rate limiting combined.

Figure 1.20: (a) The battery SOC (red) and the basic GS reference (black), and (b) the battery power output plotted against time.


The time constant was set to 120 (2 minutes), and the scaling factor was set to $5/11.55$ to simulate an effective 5 MW installed wind scenario. The efficiency of the battery was set to 85% and was assumed to be

distributed geometrically between charging and discharging similar to Section 1.1.2. The wind generation data was from the month of December and the designated charging and discharging periods were chosen from Table 1.1.


It is seen that the battery is able to perform both functions simultaneously. For the case presented, the SOC is varied between 0.1 and 0.9. It is possible to go further up (and down). However, to combine the two modes it is important leave some margin (dependent upon the time constant) at the limits so that the battery can sink/source energy when requested to do so by the ramp rate limiting part of the system. It should be noted that when the battery is charging and discharging under basic GS, there would be competition between the two objectives and the performance could suffer. Fig. 1.21 shows the results with and without combining the two objectives at different time constants for a 5 MW installed wind scenario.

For all the time constants combining the two modes results in some loss in performance. The loss in performance is more severe at higher time constants. The loss is insignificant at higher limits (0.05 pu/min, 0.1 pu/min) but is noticeable at lower limits (0.01 pu/min). Therefore, if it is desired to keep the ramp rates under 0.05 pu/min most of the time, then the two functions can be easily integrated. However, if the limit on the ramp rate is tighter, then the basic GS specifications need to be relaxed by lengthening the designated charging and discharging periods: for a longer designated charging, the power requirement *only* to charge the battery would be lower leaving more room for ramp rate limiting. Because of the presence of a nonlinear saturation element and because of the fact that wind is stochastic as opposed to deterministic, the optimal solution can be more easily determined by simulation with the following parameters available for tuning:


1. The time constant T ,
2. The length of the designated charging/discharging period, and
3. The gain of the proportional controller.




(a) Ramp rates with basic GS combined. $T = 120$




(b) Ramp rates without basic GS combined. $T = 120$




(c) Ramp rates with basic GS combined. $T = 600$



(d) Ramp rates without basic GS combined. $T = 600$



(e) Ramp rates with basic GS combined. $T = 3000$



(f) Ramp rates without basic GS combined. $T = 3000$

Figure 1.21: Ramp rates with and without combining basic GS with ramp rate limiting, at different time constants for an effective 5 MW installed wind scenario and the battery round trip efficiency equal to 85%

Concluding remarks

The battery's ability to limit the ramp rate of wind generation effectively has been verified in practice. Furthermore, the validity of simulation model to study the ramp rates has been established by the experimental results.

Analytical justification for the low pass filter based technique for ramp rate limiting has been provided. At the same time it is shown that the recommended time constant from the analytical bound could be excessive and even impractical.

It is also shown that multiple modes of operation could be combined to enhance the value from the battery storage. Furthermore, the limiting factor in the 11.55 MW scenario was the MW rating of the battery (Fig. 1.10). From the results of the previous section (Basic Generation Shifting: wind-only charging), it was concluded that the storage to wind ratio should be in the 20% – 40% range (MW/MW). For this ratio, more storage MWs would be available and the battery would be able to control the ramp rate more effectively. This is also seen in Fig. 1.17 (20% storage MW/wind MW) where the ramp rates of the ideal output and the system output are very close, and in Table 1.2 where increasing the storage/wind ratio beyond 20% – 40% (MW/MW) results in only insignificant increase in performance.

Therefore the optimal storage to wind ratio for generation shifting would also be suitable for limiting the ramp rate of wind generation. Moreover, these two tasks could be combined for maximum benefit to the system.

Data and files used

Fig. 1.7	<code>~/RRLim/XcelMeterDataDESS.csv</code> <code>~/RRLim/Relevant_data_only.xls</code> <code>~/RRLim/Info.Extraction_for_deciding_RRLim_specs.m</code>
Figs. 1.9 – Figs. 1.12	All the above files and, <code>~/RRLim/Info.Extraction_for_deciding_RRLim_specs_Simulink_model.m</code> <code>~/RRLim/RRLim_complete_system.mdl</code>
Figs. 1.13 – Figs. 1.15	Following files in <code>~/RRLim/Data_and_analysis/First_set_beginning_5_29:</code> <code>W2B_Dashboard_5_29_pi.xls</code> <code>Real_data_analysis.m</code> <code>RRLim_complete_system.mdl</code>
Figs. 1.16 – Figs. 1.17	Following files in <code>~/RRLim/Existing_data:</code> <code>wind_smoothing_1.31_to_2.2_v2.xls</code> <code>Real_data_analysis.m</code> <code>RRLim_complete_system.mdl</code>
Fig. 1.18, Table 1.2	<code>~/RRLim/With_one_yr_data/power1yr.txt</code> <code>~/RRLim/With_one_yr_data/RRLim_complete_system.mdl</code>
Figs. 1.19 – Figs. 1.21	<code>~/RRLim/Relevant_data_only.xls</code> <code>~/RRLim/w_Baisc_GS/Comparison/RRLim_complete_system.mdl</code>

Chapter 2

Economic dispatch and commercial location strategy

2.1 Economic Dispatch

This mode seeks to maximize the revenue generated from Energy Arbitrage by offering the battery in the MISO DA and RT markets. The basic sketch of the algorithm was given by Steve Beuning and was modified to dispatch the battery in the DA-RT markets by Jim Himelic. The brief description here is based on Jim's presentation titled "W2B Preliminary Storage Analysis" dated 05/27/2009. The features and configurable parameters include, but are not limited to:

- Day-ahead (DA) must run (MR) hours selected on the basis of past day's DALMPs.
- Hours not included under MR fall under Economic Dispatch (ED):
 - DA ED charge/discharge rates decided on the basis of time of the day and deviation from the mean DALMP.
 - RT ED charge/discharge rates decided on the basis of time of the day and deviation from the mean DALMP.
- Also takes the SOC into account.
- Charge/discharge rates variable in $\{-100\%, -50\%, -25\%, 0\%, 25\%, 50\%, 100\%\}$
- Further optimization using Oracle Crystal Ball.

We implemented a crude version of the above algorithm in MATLAB that does not account for the intra-hour movement of RTLMPs and does not optimize the configurable parameters. Furthermore, our implementation does not differentiate between weekdays and weekends. The results from our program were consistent with an earlier version of Jim's spreadsheet program with the same limitations as our version. Our implementation in its current form was used to simulate the Economic Dispatch for location analysis. Clearly, our version underestimates the revenue. However, because the flaws are uniform across all nodes, the results of location analysis presented in the next section should still hold.

2.2 Commercial Location

This analysis seeks to find the best location to place the battery (within NSP) to maximize the revenue from Economic Dispatch. To this end we analyzed the DA and RT LMP data at 213 nodes under the NSP territory. The data was taken from MISO's website and corresponds to the period of 10/1/2010 – 12/31/2010

(92 days). There could be more nodes but we considered only those nodes for which we had a minimum of 30 days of data.

The natural methodology would be to apply the strategy of Section 2.1 to all the nodes. However, this would not provide any insight into the problem. An alternative is to screen the nodes on the basis of some explanatory criteria and study the effect of these criteria on the revenue at the screened nodes.

It is intuitively clear that a higher spread in the prices would mean higher revenue for the battery. Variance (standard deviation) is a commonly used measure of spread. Range is another such measure. Although we did find a monotonic trend between the 90% range¹ and the variance, we believe that the trend is not strong enough to use only one of the two measures².

Another somewhat related measure is the mean absolute error of the prices about the median price. While impossible to realize in practice, the absolute error about the median price of a market is the upper bound on the revenue earned by the battery in that market. Considering that the strategy of Section 2.1 offers the battery in both DA and RT markets, following criteria were used to screen the nodes:

1. Variance of the DA and RT LMPs.
2. 90% range of the DA and RT LMPs.
3. Absolute error in the DA and RT LMPs about their median values.

For each of the above criteria, 10 top and bottom nodes were identified. While identifying the bottom nodes is not of direct interest to this analysis, we expected it to validate the choice of criteria itself, and to help identify the most influential criteria. Because of significant overlap, the list of identified nodes is much shorter than 120 nodes; the nodes are listed in Table 2.1.

Economic dispatch of the battery using the strategy of Section 2.1 was simulated at all the nodes for the period of 10/1/2010 – 12/31/2010. The mean daily revenue across all nodes was \$120.06 with a standard deviation of \$23.10. The median revenue was \$117.99. The results are plotted in Figs. 2.1 and 2.2.

¹90% range is the range after discarding 5% of the highest and lowest values. Discarding the extreme values tends to improve the robustness of the measure.

²In an earlier document we had reported that the relationship was quite strong. However, the relationship seems to break down depending upon the percentage of data considered for calculating the range and is therefore not robust, but only incidental.

(a) List of top nodes

Node name	Node type
NSP.VELVAVELV	Gennode
NSP.WHEATO5	Gennode
NSP.WHEATO6	Gennode
NSP.WHEATO3	Gennode
NSP.WHEATO4	Gennode
NSP.WHEATO2	Gennode
NSP.WHEATO1	Gennode
NSP.CHPFAL1	Gennode
NSP.CHPFAL2	Gennode
NSP.CHPFAL4	Gennode
NSP.BE	Loadzone
NSP.BELW_1.AZ	Hub
NSP.HCPD.MAD	Loadzone
NSP.UPLS_3.AZ	Hub
NSP.HCPD.LKCR	Loadzone
NSP.HATFIHAT1	Gennode
NSP.MENOMOA	Gennode
NSP.EWINGTON1	Gennode
NSP.CISCO1	Gennode
NSP.GARWIN1	Gennode
NSP.MOWERCO1	Gennode
NSP.RAPIDA1	Gennode
NSP.GDMEADOW	Gennode

(b) List of bottom nodes

Node name	Node type
NSP.OTP	Loadzone
NSP.OTPW_1.AZ	Hub
NSP.CMMPA.GF	Loadzone
NSP.GFLS	Loadzone
NSP.UPLS_2.AZ	Hub
NSP.FIBROMIN1	Gennode
NSP.BUFFR_TR1	Gennode
NSP.BUFFR_TR2	Gennode
NSP.OAKLKE_IBR	Gennode
NSP.NIPS.YANKE	Gennode
NSP.SHERCO2	Gennode
NSP.SHERC3	Gennode
NSP.SMP.S3	Gennode
NSP.SHERCO1	Gennode
NSP.WESTSID1	Gennode
NSP.GRANCT1	Gennode
NSP.ADAMSWD1	Gennode
NSP.DANIELSN1	Gennode
NSP.RWF__1_QS	Gennode
NSP.RWF__2	Gennode
NSP.HIBRDG9_1	Gennode
NSP.HIBRDG9_2	Gennode
NSP.CC.HIBRDG1	Gennode
NSP.CC.HIBRDG2	Gennode
NSP.HIBRDG.7	Gennode
NSP.HIBRDG.8	Gennode
NSP.SPGSPG1	Gennode
NSP.YANKE_TR1	Gennode

Table 2.1: The list of (a) top and (b) bottom nodes identified for detailed economic dispatch analysis.




Figure 2.1: Revenue at each of the 213 NSP nodes plotted against node number (chosen alphabetically). Each grey dot represents the average daily revenue at a NSP node; the grey bar chart is the histogram of the average daily revenue across all nodes. The nodes at which the revenue was expected to be high are represented by \bigcirc , $+$, \times and \circ , $+$, \times . The color black represents the nodes chosen on the basis of the statistics of the RT prices and the color red represents the nodes chosen on the basis of the statistics of the DA prices. E.g. the node NSP.UPLS.3.AZ has been chosen on the basis of the range of the DA ($+$) and RT ($+$) prices and on the basis of the absolute error (about the median) in the DA prices (\times). It is seen that the variance, range and absolute error of the RT prices, and the variance of the DA prices are good predictors of the total revenue — they succeed in exhaustively identifying the nodes with revenue greater than \$160/day without identifying any node with revenue less than \$140/day. On the other hand, the prediction performance of the range and absolute error of the DA prices is poor and they identify some nodes with revenue close to or lower than the mean revenue.




Figure 2.2: In this plot the nodes expected to have the lowest revenue have been marked. None of the criteria is able to identify the nodes with lowest revenues, but all criteria successfully avoid identifying any node with revenue higher than the mean revenue. Most of the nodes with higher revenues among the identified nodes are predicted by the DA range, establishing it as a poor predictor.

Concluding remarks

From the results of Fig. 2.1, the best nodes for locating the battery are NSP.BE, NSP.BELW_1.AZ and NSP.VELVAVELV. The best predictors of the revenue from the strategy considered are the variance of DA and RT LMPs, and the range and mean absolute error (about the median) of RTLMPs.




Figure 2.3: Per cycle revenue plotted against per day revenue.

Fig. 2.3 shows the revenue per cycle plotted against the revenue per day, and the relationship is certainly monotonic. Therefore the nodes with high revenue per day will also have high revenue per cycle, meaning highest return over the lifetime of the battery. Furthermore, the relationship in the Fig. 2.3 is not linear and the nodes with the highest revenue fall on the right of the best fit line: these nodes will exhaust higher number of cycles per day, with a higher revenue per cycle. This implies not only the highest, but also the fastest return on investment at the selected nodes (NSP.BE, NSP.BELW_1.AZ (overlapping) and NSP.VELVAVELV).

Without adjusting for inflation, the best case offers returns at \$221.66/day and \$352.87/cycle. For a cycle life of 4,500 cycles this translates to a lifetime return of about \$1,600,000 realized over almost 20 years. According to [1], the lifetime of the battery is 4,500 cycles and 15 years. Therefore other functions (sections 1.2, 2.3) need to be integrated with Energy Arbitrage to realize the returns faster, especially during the float period.

Data and files used

In addition to the data from MISO, following files were used:

```
Data extraction  ~/Analysis_of_prices/2010_Winter/load_2010_Winter_DART.m
                  ~/Analysis_of_prices/2010_Winter/process_2010_Winter_DART.m
                  ~/Analysis_of_prices/2010_Winter/get_all_nodes_data.m
Economic dispatch ~/Analysis_of_prices/2010_Winter/EconomicDispatch/edopt1.m
Further analysis  ~/Analysis_of_prices/2010_Winter/EconomicDispatch/analyze_all_results.m
```

2.3 Value in the Ancillary Services Market (ASM)

2.3.1 Data, resource offer, and key assumptions

Data used

The time period considered in this study is 8/18/2011 – 9/17/2011. The following prices available on the Midwest ISO (MISO) website are used for this study:

- SERREGMCP (referred to as MCP for the rest of this document).
- DEMREGMCP (found to be equal to the above for the duration considered).
- GENREGMCP (found to be equal to the above for the duration considered).
- Real-Time LMP.

All of the above are systemwide prices. The MCPs used are the Day-Ahead MCPs from files bearing the name “ASM Day-Ahead Market MCP” and the scope of this study is limited to DA Regulation Market (ASM).

Throughout this analysis the terms Energy Storage and battery are used interchangeably to refer to the 1 MW, 7.2 MWh battery owned by Xcel Energy. Further, for the purpose of the presented analysis, the battery is assumed to be ideal:

- The battery can act infinitely fast.
- The efficiency is 100%: Since the revenue earned by the battery does not depend upon the actual MWh sourced/sunk (Section 2.3.2), the revenue would not be affected by efficiency. However, the revenue/usage in Fig. 2.7 and Table 2.3 would be slightly lower.

Price sensitive offer

Under the framework of MISO ASM, Energy Storage could only be offered as a Regulating Reserve. See Exhibit 4-9: Resource Eligibility Summary for Provision of Operating Reserve in [4]. The prices for Stored Energy resources offered towards Regulation Reserve requirement in the DA ASM market are called SER-REGMCP and would be referred to as MCP hereafter.

Figure 2.4(a) shows the histogram of MCPs for the duration of this study. It is seen that the highest prices have the lowest probability of occurrence. MISO accepts up to ten MW-price pairs for the resource offer [4]. It makes most sense to offer the entire MW capability of the resource when the prices are high and to be more conservative at lower prices. This strategy is expected to balance the revenue against the battery usage (and hence lifetime).

For this study, a resource offer linearly dependent upon the price has been used: the offer goes up by 0.1 MW when prices increase by 10% of their range. Fig. 2.4(b) shows the price sensitive resource offer. Other non-linear offers similar to [5] are possible.

Key assumptions

In addition to the assumptions about the battery, following additional assumptions are made:

1. **The offer is always accepted:** It is not possible to simulate the precise market behavior without modeling the entire system using a tool like PROMOD. However, if the MCP can indeed be considered a measure of regulation resources’ availability on the system, then an offer based on historical prices should not be far off from what would actually clear.

The resource offer, as seen from Fig. 2.4, is seldom asking for extreme prices; and the offer is generally close to the median price. Furthermore, in absence of the entire system model, historical prices and their distribution should be the best indicators of what could be considered a fair offer.




Figure 2.4: Prices and price sensitive offer

2. **The regulation requirement is random:** It is our understanding that the MCP is set by demand bids and resource offers, not by the actual regulation requirement because that would be impossible to predict; if at all it was possible to predict the regulation requirement, there wouldn't be any need for a regulation market.

The actual regulation requirement would be the energy deficit or excess that wasn't met by the DA and RT markets. This requirement is unpredictable and could be positive or negative. Under the assumption that it is indeed random and uncorrelated with LMPs and MCPs, it has been modeled as a zero mean Normally distributed random variable with standard deviation chosen such that it lies within ± 400 MW 99% of the time. The number 400 (MW) was advised by domain expert, Mr. Rao Konidena.

2.3.2 Methodology

Under the above assumptions, following methodology is adopted to establish the value of battery in ASM:

1. Generate random time series for the actual regulation requirement. The resolution is one hour but it is possible to make it finer.
2. The setpoint for the battery would be based on the cleared MWs and the regulation requirement. For instance, if the regulation requirement is +300 MWs and the battery is cleared for 0.5 MW, the setpoint would be +0.375 MW.

$$\text{SETPOINT} = \text{DA_ASM_VOL} \times \frac{\text{REG_REQ}}{\min(400, |\text{REG_REQ}|)} \quad (2.1)$$

Here SETPOINT is the MW setpoint, DA-ASM-VOL is the hourly DA cleared regulation volume and REG.REQ is the current regulation requirement on the system.

3. However, if the battery is nearing the limits of its State of Charge (SOC), the SETPOINT is forced to 0 and the battery is charged/discharged at its maximum capability. The Asset Owner (AO) incurs the costs in proportion to the volume charged/discharged and the RTLMP.

4. The revenue is then calculated as [6]

$$\text{REVENUE} = \sum_{\text{hours}} (\text{DA_ASM_VOL}_{\text{hour}} \times \text{DA_REG_MCP}_{\text{hour}} - \text{RT_VOL}_{\text{hour}} \times \text{RT_LMP}_{\text{hour}}) \quad (2.2)$$

Here DA_REG_MCP is the MCP, RT_VOL is the MWh *drawn* from the system in real time and RT_LMP is the Real-Time LMP.

5. Becuase it is not possible to count charging/discharging cycles in this application, the cycles are substituted by “usage” which is defined as the absolute integral of battery MWs.

$$\text{USAGE} = \sum_{\text{hours}} (|\text{SETPOINT}_{\text{hour}}| + |\text{RT_VOL}_{\text{hour}}|) \quad (2.3)$$

Fig. 2.5 illustrates the procedure above. It is seen in the figure that cleared volume follows the MCP closely (although in discrete steps) while the actual MW setpoint is also dependent upon the regulation requirement. The regulation requirement is independent of the MCP and is random.

It is also seen that the battery needs to charge during HE233 because of low SOC and the revenue falls because of RTLMP paid during that hour. If the maximum volume offered is kept below the physical MW capacity of the battery by introducing a scaling factor $k < 1$, it might be possible to minimize the exposure of the battery to RT market. This could also be thought as a lower slope of the offer-MW plot in Fig. 2.4(b). Such a constant scaling factor would mean lower revenue, but also lower usage. Whether it is beneficial or not is explored in the next section.




Figure 2.5: Storage operation from top — The system regulation requirement; MCP; The cleared volume, actual MW setpoint in accordance with (2.1) and RT volume; MWh; and bottom, revenue. Energy storage operates normally during all hours except HE233 during which emergency charging is necessary.

2.3.3 Monte Carlo simulation

Monte Carlo method involves simulation with random input for a sufficiently large number of times to obtain the distribution of the output. Following procedure was adopted:

1. Set scaling factor to 100%.
2. Generate regulation requirement (a random sequence).
3. Follow the steps in the last section to compute the revenue and usage and save their values.
4. Repeat the above three steps such that the simulation is run 100,000 times.
5. Repeat the above four steps at scaling factors 75%, 50% and 25%.

The results are presented in Figs. 2.6(a) and 2.6(b).




Figure 2.6: Results from Monte Carlo method

As expected, when the entire MW capability of battery is utilized, the revenue is high and so is the usage. In fact, the two quantities appear to be in direct proportion to the scaling factor in the average sense. It is also noteworthy that the spread increases as the scaling factor is increased. Another quantity worth analysis is the revenue per MWh used because it could be an estimate of the revenue from the battery over the battery's lifetime (measured in cycles). Fig. 2.7 shows the distribution revenue/usage for different scaling factors.

The significant difference in spread of the revenue plots in Fig. 2.6(a) is evened out to a certain extent. Tables 2.2 and 2.3 tabulate the statistics from Figs. 2.6(a) and 2.7.




Figure 2.7: Distribution of revenue/usage for different values of the scaling factor.

Scaling	median (\$)	mean(\$)	sd(\$)	95% C.I.
100%	3076.80	3057.70	121.75	2771.10 – 3257.30
75%	2307.60	2301.30	69.79	2148.60 – 2412.80
50%	1538.40	1537.60	26.26	1483.70 – 1577.40
25%	769.21	769.20	1.16	769.21 – 769.21

Table 2.2: Revenue statistics

Scaling	median (\$/MWh)	mean(\$/MWh)	sd(\$/MWh)	95% C.I.
100%	41.4378	41.1619	2.27	35.6698 – 44.8891
75%	41.7776	41.5904	1.9766	36.8953 – 44.8290
50%	42.0764	42.0217	1.5716	38.8208 – 44.8199
25%	42.1742	42.2044	1.2985	39.7489 – 44.8258

Table 2.3: Revenue/usage statistics

Concluding remarks

As prefaced, this analysis considers a 1 MW, 7.2 MWh battery. If only 90% depth of discharge (DOD) is permitted, then a usage of $7.2 \times 2 \times 90/100$ equals 12.96 MWh. This usage also corresponds to one charge-discharge cycle. From Tables 2.2 and 2.3, the highest revenue scenario has a median revenue/usage of 41.4378 \$/MWh. This will translate to a revenue of \$537.03/cycle. The battery lifetime for 90% DOD is 4,500 cycles [1], meaning a lifetime revenue of \$2,416,652.50 under the fastest return on investment scenario. While these numbers have to be considered in the light of the assumptions made, it could still be said that offering the battery in MISO ASM has the potential to make money for the investor and while providing meaningful service to the system.

Files used

In addition to the data listed earlier, the file `~/ASM/methodology_v2.m` was used.

Bibliography

- [1] “The NAS battery system for utility-scale energy storage (catalog),” NGK Insulators.
- [2] Production Tax Credit for Renewable Electricity Generation. U.S. Energy Information Administration. [Online]. Available: <http://www.eia.gov/oiaf/aeo/otheranalysis/aeo.2005analysispapers/prcreg.html>
- [3] CPI Inflation Calculator. U.S. Department of Labor, Bureau of Labor Statistics. [Online]. Available: http://www.bls.gov/data/inflation_calculator.htm
- [4] Energy and Operating Reserve Markets Business Practices Manual. Midwest ISO. [Online]. Available: <https://www.midwestiso.org/Library/Pages/Library.aspx>
- [5] S. Tewari and N. Mohan, “Optimal strategy to dispatch storage in real-time markets,” in *Summer Simulation Multiconference*, 2011.
- [6] Market Settlements Business Practices Manual. Midwest ISO. [Online]. Available: <https://www.midwestiso.org/Library/Pages/Library.aspx>