

McCarter, Jennifer

From: McCarter, Jennifer
Sent: Friday, October 7, 2022 3:27 PM
To: Jacobson, Linda
Cc: Kilty, Quinn V
Subject: Comanche Groundwater Notification of Concentration Exceedances August 2022 sample event

Hi Linda, we have received the results of the August sampling event for Comanche and HDR has completed their data validation. This email serves as our notification under Par. 95(d)(i) of the Consent Agreement, that concentrations of cadmium and cobalt exceeded standards in the August sample results as summarized below, including the first result from replacement well W-6B1. The analytical results for the August will be included in the Monthly Progress Report, unless requested by EPA to be delivered more quickly.

Comanche Station CCR Impoundment August 22-25, 2022 Groundwater Sampling Event Wells with Concentrations over Groundwater Protection Standards		
Appendix IV Parameters with Concentration Exceedances	Cadmium (mg/L)	Cobalt (mg/L)
GPS (Based on Well W-2A)	0.00588	0.0102
Monitoring Wells with GPS Concentration Exceedances		
W-3B	0.017	0.11
W-6B1	0.024	0.11
W-14	No exceedance	0.012
W-16	Not analyzed	0.016

Jennifer McCarter, R.E.M.

Xcel Energy

Environmental Analyst

Environmental Services Department

1800 Larimer St., Suite 1300, Denver, CO 80202-1414

P: 303-294-2228 C: 720-810-1220 F: 303-294-2328

E: jennifer.mccarter@xcelenergy.com

XCELENERGY.COM

Please consider the environment before printing this email

I am working remotely. Please contact me through email or cell (720) 810-1220