

# RENEWABLE BATTERY CONNECT

## ELIGIBLE BATTERY EQUIPMENT



Eligible battery equipment includes Tesla Powerwall's and Powerwall+, SolarEdge Home Battery with a SolarEdge Home Hub Inverter.

Interconnection application requests for Renewable Battery Connect must include approved equipment from the table below. Applications will not be approved for alternative batteries and inverters.



### RENEWABLE BATTERY CONNECT ELIGIBLE BATTERY EQUIPMENT

Storage Manufacturer	Storage Model	Charge Rate, Max Continuous (kW)	Storage Guidance Configuration
SolarEdge Technologies, Inc. Home Battery	BAT-10K1P	5.0	DC, Net Metered, 100% Renewable Export 3B/3BM
Tesla Inc. (Powerwall+)	1850000-xx-y	5.0 (battery inverter)	AC, Net Metered, Non-Export 2C
Tesla Inc. (AC Powerwall)	1092170-xx-y	5.0	AC, Net Metered, Non-Export 2C
Tesla Inc. (AC Powerwall)	2012170-xx-y	5.0	AC, Net Metered, Non-Export 2C
Tesla Inc. (AC Powerwall)	3012170-xx-y	5.0	AC, Net Metered, Non-Export 2C
Tesla Inc. (Powerwall 3)	1707000-xx-y	11.5	DC, Net Metered, 100% Renewable Export 3B/3BM



### COMPATIBLE INVERTERS FOR ELIGIBLE BATTERY EQUIPMENT

Inverter Manufacturer	Inverter Model
SolarEdge Technologies, Inc. Home Hub Inverter	SE3800H-US-XXXXXX
	SE6000H-US-XXXXXX
	SE7600H-US-XXXXXX
	SE10000H-US-XXXXXX
	SE11400H-US-XXXXXX
Tesla Inc. (Powerwall+)	1538000-xx-y [208V]
	1538000-xx-y [240V]