

Measure M1: Reduce supply air pressure setpoint for VAV system

Inputs

Orig. SP	1.5 in w.g.
New SP	1.00 in w.g.
ΔP :	0.50 in w.g.
η_{fan}	0.6
η_{motor}	0.95

Demand and Energy Savings

OA Temp Bin	AHU Run Hours ^[1]	[A]		[B]		[C]		[D]		Equation Key
		CFM	Delta BHP	CFM	Delta BHP	kW	kWh	kW	kWh	
22.5	157	42,781	4.7			3.7	574			
27.5	190	44,841	4.9			3.8	728			
32.5	302	46,901	5.1			4.0	1,210			
37.5	372	48,961	5.3			4.2	1,556			
42.5	375	51,021	5.6			4.4	1,635			
47.5	344	53,081	5.8			4.5	1,560			
52.5	304	55,141	6.0			4.7	1,432			
57.5	320	57,201	6.2			4.9	1,564			
62.5	392	59,261	6.4			5.1	1,985			
67.5	330	61,321	6.7			5.2	1,729			
72.5	233	63,381	6.9			5.4	1,262			
77.5	375	65,441	7.1			5.6	2,097			
82.5	384	67,501	7.3			5.8	2,215			
87.5	154	69,561	7.6			5.9	915			
92.5	82	71,621	7.8			6.1	502			
97.5	7	73,681	8.0			6.3	44			
Total	4321						21,010			

[1] AHU run hours from TMY weather data

Peak demand savings:

Equations:


[A] CFM = $412 \times \text{OAT} + 33,511$ (See trended data below)

[B] Delta BHP = $\text{CFM} \times (\rho/\rho_{std}) \times (\text{SP}_{original} - \text{SP}_{new}) / 6356 / \eta_{fan}$
 $(\rho/\rho_{std} = 0.83 \text{ in Denver})$

[C] $\text{kW}_{save} = (\text{Delta BHP}) \times 0.746 / \eta_{motor}$

[D] $\text{kWh}_{save} = (\text{kW}_{save} \times \text{hours})_{bin}$

[F] Peak kW savings = kW savings at 97 F OAT



M2 - Reduce Minimum Outside Air & Add Economizer Controls (sensible control only)

Inputs

60,000 cfm - Constant Volume Supply fan flow
210 Max # occupants
45% Existing Outside Air (OA) fraction - Fixed
100% Maximum possible Outside Air (OA) fraction
7% New Proposed Minimum OA fraction = ((20 cfm x 210 occ.) / 60,000 cfm)
0.6 kW/Ton - Existing chiller efficiency
80% Boiler efficiency
71 F - Average return air temperature (RAT)
52 F - Average supply air temperature (SAT)

Demand and Energy Savings

		[A]	[B]			[C]	[D]	[E]	
Temp Bin	Annual Hours ^[1]	Existing OA Flow cfm	New OA Flow %	New OA Flow cfm	Change in OA Flow cfm	Savings			
						kW	Annual kWh	Annual Therms	
22.5	157	27,000	39%	23,505	-3,495	0.0	0	298	
27.5	190	27,000	44%	26,207	-793	0.0	0	73	
32.5	302	27,000	49%	29,610	2,610	4.5	1,360	0	
37.5	372	27,000	57%	34,030	7,030	10.6	3,927	0	
42.5	375	27,000	67%	40,000	13,000	16.6	6,227	0	
47.5	344	27,000	81%	48,511	21,511	22.7	7,794	0	
52.5	304	27,000	100%	60,000	33,000	27.4	8,318	0	
57.5	320	27,000	100%	60,000	33,000	20.0	6,390	0	
62.5	392	27,000	100%	60,000	33,000	12.6	4,928	0	
67.5	330	27,000	100%	60,000	33,000	5.2	1,708	0	
72.5	233	27,000	7%	4,200	-22,800	1.5	357	0	
77.5	375	27,000	7%	4,200	-22,800	6.6	2,491	0	
82.5	384	27,000	7%	4,200	-22,800	11.8	4,513	0	
87.5	154	27,000	7%	4,200	-22,800	16.9	2,597	0	
92.5	82	27,000	7%	4,200	-22,800	22.0	1,802	0	
97.5	7	27,000	7%	4,200	-22,800	27.1	190	0	[F]
									27.1 kW
Total	4321						52,601	372	↑

Equation Key

Peak demand savings: 27.1 kW

Notes:

[1] TMY2 hours (Boulder) May-Sep, M-F, 9AM-9PM [AHU & Chiller run hours]

Equations:

[A] Existing OA CFM = Design Supply CFM x %OA

[B] If [OAT > RAT, then New % OA = Minimum]; If [SAT < OAT < RAT, the New % OA = Maximum]; If [OAT < SAT then New % OA = (SAT-RAT)/(OAT - RAT)]

[C] If [OAT < RAT and OA CFM New > OA CFM Original] OR if [OAT>RAT and OA CFM new< OA CFM old] then: kW savings = 1.08 x 0.83 x (OA CFM Reduction) x (RAT - OAT)_{bin} x 1/12,000 x Chlr kW/Ton
(p/p_{std} = 0.83 in Denver)

[D] kWh = kW * hours_{bin}

[E] If [OAT<SAT and new % OA< original %OA] then: Therm savings = operating hours *{1.08 x 0.83 x (OA CFM Reduction) x (RAT - OAT)_{bin}} / {Boiler Efficiency * 100,000btu/therm}

[F] Peak kW savings = kW savings at 97 F OAT