


Customer (owners) Name  
 Address (including unit #'s)  
 City


**NOTE: Make sure the address matches exactly what's on the Xcel Energy Bill**

DATE  
 APPLICATION NUMBER

Solar Panels  
 Number of PV Modules make & Model - PV System size with DC and AC ratings




Inverter  
 Make, Model and Power Rating.  
 UL 1741 Compliance



Indicate size of wires connecting components along with approximate distance and directions

Utility Accessible AC Disconnect  
 Lockable, with visible open (i.e. Knife Blade)  
 Labeled "PV AC Disconnect"  
 Clearly visible, accessible, and within 10' of billing meter



Utility Grid

Utility PV Production Meter  
 Amp rating of customer provided meter socket.




Utility Meter  
 Labeled "Photovoltaic System Connected"  
 service voltage, amperage



----- DC conductor  
 ——— AC conductor

Service Panel  
 (Include info such as the Service panelboard voltage, amperage rating and main disconnect(s) size i.e. 120/240V, 200A, 60A)



- PV Production Meter notes:**
1. The self-contained metering will be in compliance with the current revision of the Xcel Energy Standard; specifically Section 4.11, or as may be amended.
  2. The PV production meter will be required to have the PV generation wired to the line side terminals (top of meter block).
  3. The meter socket for the PV production meter shall be marked with a stamped brass, aluminum, or stainless steel tag, indicating the address including the unit, typically "PV PROD" in accordance with the requirements for "Meter Identification" in Section 4.14.4 of the Xcel Energy Standard, or as may be amended.
  4. The PV production meter shall be located within ten (10) feet of the existing utility meter. If there is any reason this cannot be accomplished, the approval of the proposed PV production metering will need to be obtained by the local electric meter shop
- One-lines that do not include all of these statements will be denied.**

Meter – If the service needs to be upgraded, the one-line shall note that an upgrade will take place, and reference what will be installed for the upgrade.

NOTE: If the PV system's point of Interconnection is within a self-contained meter socket or CT enclosure/compartments, be advised that the use of piercing tap connectors is strictly prohibited by Xcel Energy. This equipment is dedicated for the sole use of the utility and Xcel Energy will not permit the use of the meter socket or CT enclosure/compartments as a junction box unless it is used in accordance with its listing and labeling.

Drawing Revised  
 2/16/17