

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 1 of 109

Approval: _____

INFORMATION USE

- Procedure should be available, but NOT necessarily at the work location.
- Procedure may be performed from memory.
- User remains responsible for procedure adherence.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 2 of 109

Notice to Users

This document has been prepared for the Monticello Nuclear Generating Plant (MNGP). Its purpose is to provide general information about Emergency Action Levels (EALs) to off-site authorities who are involved in planning for and responding to emergencies at the MNGP. This document is to be used for information only and is not to be used in place of existing procedures. While this manual provides descriptions of the various plant conditions which require emergency classification, the MNGP and the Nuclear Regulatory Commission (NRC) remain the sole source of accurate information regarding plant conditions during a real emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 3 of 109

Table of Contents

How to Use This EAL Reference Manual	6
Purpose of the EAL Reference Manual	6
What is an Emergency Action Level (EAL)?	6
How an Emergency is Classified –	6
General Emergency (GE)	6
Site Area Emergency (SAE)	6
Alert	6
Notification of Unusual Event (NUE)	7
Instructions for Using This Manual	7
Recognition Category ‘R’ Initiating Condition Matrix	10
RG1	11
RG2	12
RS1	13
RS2	14
RA1	15
RA2	17
RA3	18
RU1	19
RU2	20
Recognition Category ‘C’ Initiating Condition Matrix	22
CG1	23
CS1	25
CA1	27
CA2	29
CA3	30
CA6	32
CU1	34
CU2	36
CU3	37
CU4	39
CU5	40

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 4 of 109

Table of Contents (Cont'd)

Recognition Category 'E' Initiating Condition Matrix	42
EU1	43
Recognition Category 'F' Initiating Condition Matrix	45
FG1.....	46
FS1	48
FA1	50
Recognition Category 'H' Initiating Condition Matrix	53
HG1	54
HG7	56
HS1	57
HS6	58
HS7	59
HA1	60
HA5	62
HA6	63
HA7	64
HU1	65
HU2	66
HU3	67
HU4	69
HU7	71
Recognition Category 'S' Initiating Condition Matrix	73
SG1	74
SG8	75
SS1.....	76
SS5.....	77
SS8.....	78
SA1.....	79
SA2.....	80
SA5.....	81
SA9.....	82

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 5 of 109

Table of Contents (Cont'd)

SU1 83

SU2 84

SU3 85

SU4 86

SU5 87

SU6 88

GLOSSARY AND ACRONYMS..... 89

Glossary 90

Acronyms..... 102

PLANT INFORMATION 105

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 6 of 109

How to Use This EAL Reference Manual

Purpose of the EAL Reference Manual

This manual provides information that describes the various conditions that might require the Monticello Nuclear Generating Plant (MNGP) to declare an emergency at the site, what these conditions are, what they mean, and what impact each is likely to have on plant and public safety. With an understanding of what a particular condition or event means, emergency workers at the various off-site agencies should be able to relate their emergency plan response actions to the declared event. In addition, use of this manual will provide a picture of what is happening at the station during a drill or emergency event.

What is an Emergency Action Level (EAL)?

The specific events or symptoms that would signal to MNGP personnel that an emergency event is taking place are called Emergency Action Levels (EALs). In order to use an EAL, two conditions must be met; the EAL *Initiating Condition* must exist and the EAL *Threshold (Value)* must be reached. The applicable EAL is then used to classify an emergency event, initiate the Emergency Plan and related procedures which detail necessary response actions. The level of this response is based on how seriously the condition threatens plant and public safety, resulting in a graded response to the event by site personnel and off-site authorities.

How an Emergency is Classified –

There are four classifications of emergencies, each having a matching level of response. The classifications are based on how seriously the event threatens the public or MNGP equipment. The emergency classifications, listed from the most serious to the least serious are as follows:

General Emergency (GE) –

Conditions have degraded to a point **threatening public safety** and requiring **some form of protective actions for the general public** and certain plant personnel.

Site Area Emergency (SAE) –

At this level, conditions have degraded to a point warranting the **full activation of response functions**. Precautionary **protective actions for high risk portions of the general public** may be recommended.

Alert –

A low level condition which **poses no threat to public safety, but for which precautionary mobilization of certain response functions** is appropriate in case conditions degrade.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 7 of 109

Notification of Unusual Event (NUE) –

A low level condition which **poses no threat to public safety** but which **warrants an increased awareness** on the part of plant and off-site agency personnel.

Instructions for Using This Manual

Off-site agencies are promptly notified at each of the four emergency levels, even though only the last one, General Emergency, actually poses a threat to public safety and warrants an action like evacuation to protect the public. Notifications are done so the agencies **can prepare** to respond appropriately.

If an emergency event is declared at MNGP, within 15 minutes the plant will place a phone call and communicate required information from the Emergency Notification Report Form. This notification process contains the information needed by off-site agencies to determine the appropriate response actions to take. This manual provides supplemental information to help interpret the plant conditions more easily. The notification will contain the appropriate emergency classification and other information regarding the event, including the EAL number.

HA6.1 is an example of an EAL number.

To determine more information about this or any EAL, follow these directions:

1. Find the EAL number provided with official notification that an emergency has been declared at MNGP (Block 5A on the Monticello Emergency Notification Report Form).
EAL# - **HA6.1**

- The first letter of the EAL number (**H**) is the Recognition Category and represents the type of problem and where it is discussed in this manual. There are six recognition categories for identified conditions:

- R = Abnormal Radiation Levels / Radiological Effluent
- C = Cold Shutdown / Refueling System Malfunction
- E = Independent Spent Fuel Storage Installation
- F = Fission Product Barrier
- H = Hazards and Other Conditions Affecting Plant Safety
- S = System Malfunction

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 8 of 109

- The second letter of the EAL number (**A**) represents the emergency classification. The four emergency classifications are designated as follows:

G = General Emergency
S = Site Area Emergency
A = Alert
U = Unusual Event

Each series of EALs are listed in order of most to least severe. For example HA1, (Alert EALs) would be listed before HU1, (Unusual Event EALs) in the Hazards recognition category.

- The first digit of the EAL number (**6**) represents the sequential listing of Initiating Conditions within each recognition category. **Do not** confuse this number with the severity of the event. The second digit (**1**) represents the EAL Threshold that was met for the identified Initiating Condition.
2. Let's put it all together using **HA6.1** as an example. Turn to the appropriate section of this manual and review the descriptions given for the event. In this case, **HA6**, Control Room evacuation:

H – Indicates that it is a **Hazard** Recognition Category

A – Indicates the event is classified as an **Alert**

6 – Indicates that the 6th Initiating Condition in the Hazard Recognition Category has been met

1 – Indicates that the 1st EAL Threshold of the Initiating Condition HA6 has been met. In this case, an event has resulted in plant control being transferred from the Control Room to an alternate location.

Note:

Some of the terms used in the detailed descriptions have special meaning. These terms have been identified by *italic typeface* and are defined within the glossary at the end of this manual. These terms are highlighted as they appear in the detailed description.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 9 of 109

SECTION R

ABNORMAL RADIATION LEVELS/ RADIOLOGICAL EFFLUENT

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 10 of 109

Recognition Category 'R' Initiating Condition Matrix

GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
RG1 Off-site Dose.	RS1 Off-site Dose.	RA1 Off-site Dose.	RU1 Off-site Dose.
RG2 Uncontrolled Loss of Storage Pool Water.	RS2 Uncontrolled Loss of Storage Pool Water.	RA2 Damage to Irradiated Fuel.	RU2 Unplanned Loss of Water above Irradiated Fuel.
		RA3 In-plant Radiation Levels.	

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 11 of 109



Brief Description:

Radiation doses exceeding federal guidelines that specify protective measures be taken have been measured in or projected for areas beyond the immediate station area. Protective actions will be recommended for the public.

Detailed Description:

The thresholds specified in EALs RG1.1, RG1.2, and RG1.3 represent releases off-site that can reasonably be expected to exceed the Environmental Protection Agency's *Protective Action Guideline* values. In other words, they are the levels at which federal guidelines would recommend protective actions like sheltering, evacuation, and/or issuance of potassium iodide (KI).

RG1.1 requires a General Emergency to be declared if specific radiation monitors monitoring gaseous releases reach values equivalent to greater than 1000 mRem (1 Rem) *TEDE (total effective dose equivalent)* or 5000 mRem (5 Rem) thyroid *CDE (committed dose equivalent)* at or beyond the immediate station area (*Site Boundary*).

RG1.2 requires a General Emergency to be declared if the projected dose from the release (for the duration of the event) at or beyond the immediate station area (*Site Boundary*) is determined to be greater than 1000 mRem (1 Rem) *TEDE* or 5000 mRem (5 Rem) thyroid *CDE*.

RG1.3 requires a General Emergency to be declared if field survey results at or beyond the immediate station area (*Site Boundary*) indicate dose rates greater than 1000 mRem/hr that are expected to continue for one hour or longer or analyses of field survey samples indicate thyroid *CDE* greater than 5000 mRem (5 Rem) for one hour of inhalation.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 12 of 109

Abnormal Radiation Levels/Radiological Effluent		
RG2	GENERAL EMERGENCY	RG2
Uncontrolled Loss of Storage Pool Water		

Brief Description:

Plant operators are unable to maintain water level in the storage pool (Spent Fuel Pool) for used reactor fuel resulting in possible damage to the used reactor fuel. Protective actions will be recommended for the public.

Detailed Description:

Once the *fuel* in the *reactor* has been depleted, it is removed and stored in the *Spent Fuel Pool* where water is used to shield plant workers from radiation still being given off by the *fuel* as well as serve as a means of cooling the *fuel*.

In this case, a loss of the water from the *Spent Fuel Pool* has occurred and for the last 60 minutes or more plant operators have been unable to restore the water level high enough to adequately protect the used *reactor fuel assemblies*. Increases in radiation levels within plant buildings are occurring. The continued loss of water will result in additional damage to the used *reactor fuel assemblies* and a release of radioactive material to the environment.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 13 of 109

Abnormal Radiation Levels/Radiological Effluent		
RS1	SITE AREA EMERGENCY	RS1
Off-Site Dose		

Brief Description:

Low level radiation doses have been measured at or projected for areas beyond the immediate station area.

Detailed Description:

The thresholds specified in EALs RS1.1, RS1.2, and RS1.3 represent releases off-site which are expected to exceed a fraction (10%) of the Environmental Protection Agency's *Protective Action Guideline* values. In other words, they are much lower than levels at which federal guidelines recommend protective actions like sheltering, evacuation, and/or issuance of potassium iodide (KI).

RS1.1 requires a Site Area Emergency to be declared if specific radiation monitors monitoring gaseous releases reach values equivalent to greater than 100 mRem (0.1 Rem) *TEDE (total effective dose equivalent)* or 500 mRem (0.5 Rem) thyroid *CDE (committed dose equivalent)* at or beyond the immediate station area (*Site Boundary*).

RS1.2 requires a Site Area Emergency to be declared if the projected dose from the release (for the duration of the event) at or beyond the immediate station area (*Site Boundary*) is determined to be greater than 100 mRem (0.1 Rem) *TEDE* or 500 mRem (0.5 Rem) thyroid *CDE*.

RS1.3 requires a Site Area Emergency to be declared if field survey results at or beyond the immediate station area (*Site Boundary*) indicate dose rates greater than 100 mRem/hr that are expected to continue for one hour or longer or analyses of field survey samples indicate thyroid *CDE* greater than 500 mRem (0.5 Rem) for one hour of inhalation.

If levels continue to increase, a higher level of emergency might be declared.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 14 of 109

Abnormal Radiation Levels/Radiological Effluent		
RS2	SITE AREA EMERGENCY	RS2
Unplanned Loss of Storage Pool Water		

Brief Description:

The water level in the storage pool (Spent Fuel Pool) for used reactor fuel has reached a level requiring plant operator action to prevent further inventory loss and possible fuel damage.

Detailed Description:

Once the *fuel* in the *reactor* has been depleted, it is removed and stored in the *Spent Fuel Pool* where water is used to shield plant workers from radiation still being given off by the *fuel* as well as serve as a means of cooling the *fuel*.

In this case, a loss of the water from the *Spent Fuel Pool* has occurred and plant operators need to take action to restore the water level high enough to adequately protect the used *reactor fuel assemblies*. Increases in radiation levels within plant buildings are occurring. The continued loss of water without operator action may result in damage to the used *reactor fuel assemblies* and a possible release of radioactive material to the environment.

Since these conditions are recoverable, they don't pose an immediate threat to the public and protective actions are not required.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 15 of 109

Abnormal Radiation Levels/Radiological Effluent		
RA1	ALERT	RA1
Off-Site Dose		

Brief Description:

Low level radiation doses have been measured at or projected for areas beyond the immediate station area. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The plant's vent system directs the gaseous output of various plant systems to the atmosphere. Gaseous and liquid releases from the plant are carefully monitored to alert operators to the presence of, and any increase in, radioactivity.

The system monitors are set to alarm at extremely low levels of radioactivity. In fact, the alarm points are set well below the radioactivity emission rates allowed (*Technical Specifications*) as calculated from the *Off-Site Dose Calculation Manual (ODCM)*. Should there be indication of a release, the plant operators act immediately to locate and isolate its source.

The thresholds specified in EALs RA1.1, RA1.2, RA1.3, and RA1.4 represent releases off-site which are expected to exceed a fraction (1%) of the Environmental Protection Agency's *Protective Action Guideline* values. In other words, they are much lower than levels at which federal guidelines recommend protective actions.

RA1.1 requires an Alert to be declared if specific radiation monitors monitoring gaseous releases reach values equivalent to greater than 10 mRem (0.01 Rem) *TEDE (total effective dose equivalent)* or 50 mRem (0.05 Rem) thyroid *CDE (committed dose equivalent)* at or beyond the immediate station area (*Site Boundary*).

RA1.2 requires an Alert to be declared if the projected dose from the release (for the duration of the event) at or beyond the immediate station area (*Site Boundary*) is determined to be greater than 10 mRem (0.01 Rem) *TEDE* or 50 mRem (0.05 Rem) thyroid *CDE*.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 16 of 109

RA1.3 requires an Alert to be declared if analyzed sample results of releases at or beyond the immediate station area (*Site Boundary*) indicate dose rates greater than 10 mRem *TEDE* or 50 mRem (0.05 Rem) thyroid *CDE* for one hour of exposure.

RA1.4 requires an Alert to be declared if field survey results at or beyond the immediate station area (*Site Boundary*) indicate dose rates greater than 10 mRem/hr that are expected to continue for one hour or longer or analyses of field survey samples indicate thyroid *CDE* greater than 50 mRem (0.05 Rem) for one hour of inhalation.

If levels continue to increase, a higher level of emergency might be declared.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 17 of 109

Abnormal Radiation Levels/Radiological Effluent		
RA2	ALERT	RA2
Damage to Irradiated Fuel		

Brief Description:

Plant operators have indications of possible damage to or uncovering of reactor fuel outside the reactor pressure vessel. Current plant conditions DO NOT threaten public safety.

Detailed Description:

When new *fuel assemblies* are placed in the *reactor* and used to generate energy they become *irradiated*. Once all of the useful energy has been taken from the fuel it is called *spent fuel*. *Spent fuel* is removed from the *reactor pressure vessel* during plant *refueling* and stored in the *Spent Fuel Pool*. Even though the *spent fuel* does not provide enough energy to produce electricity it does generate heat for some time after being removed from the *reactor*.

The water in the *Spent Fuel Pool* serves two functions:

- 1) It shields station workers from radiation given off by the *fuel assemblies*.
- and**
- 2) It cools the *fuel assemblies* by removing the *decay heat* the *fission products* are still producing.

The *Spent Fuel Pool* is also used to store partially used *fuel assemblies* removed from the *reactor pressure vessel* during plant maintenance.

The thresholds specified in EALs RA2.1 and RA2.2 represent conditions indicating that some *irradiated fuel* outside the *reactor pressure vessel* has become damaged or may be uncovered.

The threshold specified in EAL RA2.3 represents a condition indicating a decreasing water level in the *Spent Fuel Pool*.

The conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 18 of 109

Abnormal Radiation Levels/Radiological Effluent		
RA3	ALERT	RA3
In-plant Radiation Levels		

Brief Description:

Radiation levels in one or more area(s) of the plant are high, limiting operator's ability to safely operate plant equipment. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Control areas contain equipment necessary for the safe operation or safe *shutdown* of the plant. Operators must have continuous access to these areas. Examples of control areas are:

- 1) Control Room (Main)
- 2) Central Alarm Station
- 3) Secondary Alarm Station

Other areas of the plant which require infrequent access, such as general *Reactor Building* areas, areas of the *Turbine Building*, areas containing control cables, etc., are also entered to allow for safe plant operations.

The thresholds specified in EALs RA3.1 and RA3.2 represent radiation exposure levels in one or more control areas are higher than normal or radiation levels in areas requiring infrequent access to maintain plant safety functions are much higher than normal. This could limit access to operating areas that are required for safe operation or *shutdown* of the plant.

High radiation levels inside the plant do not mean that any radioactivity has been released off-site.

The conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 19 of 109

Abnormal Radiation Levels/Radiological Effluent		
RU1	UNUSUAL EVENT	RU1
Off-Site Dose		

Brief Description:

Radioactive gases or liquids are being released at rates at least two times (2x) those allowed by the plant's operating license limits (Off-site Dose Calculation Manual) over a designated period of time. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The plant's vent system directs the gaseous output of various plant systems to the atmosphere. Under normal plant conditions Monticello does not discharge any radioactive liquids to the river. The plant's radwaste systems remove harmful levels of radiation from any gases or liquids being released. Gaseous and liquid releases from the plant are carefully monitored to alert operators to the presence of, and any increase in, radioactivity.

The system monitors are set to alarm at extremely low levels of radioactivity. Should there be indication of a release, the plant operators act immediately to locate and isolate its source.

The thresholds specified in EALs RU1.1, RU1.2 and RU1.3 represent levels of radioactivity being released at two times (2x) the rates allowed during normal plant operations (*Off-site Dose Calculation Manual*) for more than 60 minutes. Therefore, the EALs call for an Unusual Event to be declared. Although such release rates are above that allowed for normal operations, they are a small fraction of that which could cause measurable radiation beyond the immediate station area (*Site Boundary*).

The conditions pose no threat to the safety of the general public.

If radiation levels continue to rise, a higher level of emergency might be declared.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 20 of 109

Abnormal Radiation Levels/Radiological Effluent		
RU2	UNUSUAL EVENT	RU2
Unplanned Loss of Water above Irradiated Fuel		

Brief Description:

Plant Operators have observed an unexpected decrease in water level in components covering reactor fuel that has resulted in an increase in plant radiation monitors. Current plant conditions DO NOT threaten public safety.

Detailed Description:

When new *fuel assemblies* are placed in the *reactor* and used to generate energy they become *irradiated*. Once all of the useful energy has been taken from the fuel it is called *spent fuel*. *Spent fuel* is removed from the *reactor pressure vessel* during plant *refueling* and stored in the *Spent Fuel Pool*. The *Spent Fuel Pool* is also used to store partially used *fuel assemblies* removed from the *reactor pressure vessel* during plant maintenance. Even though the *spent fuel* does not provide enough energy to produce electricity it does generate heat for some time after being removed from the *reactor*. Once the *decay heat* of the *spent fuel* has cooled to a low level, the *spent fuel* is transferred to another on-site facility for interim storage.

The water in the *Spent Fuel Pool* and other components containing the *spent fuel* serves two functions:

- 1) It shields station workers from radiation given off by the *fuel assemblies*.
- and**
- 2) It cools the fuel assemblies by removing the *decay heat* the *fission products* are still producing.

This condition does not pose a threat to the safety of the general public.

If radiation levels continue to rise, a higher level of emergency might be declared.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 21 of 109

SECTION C


COLD SHUTDOWN/REFUELING SYSTEM MALFUNCTION

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 22 of 109

Recognition Category 'C' Initiating Condition Matrix

GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
CG1 Loss of Reactor Water Level.	CS1 Loss of Reactor Water Level.	CA1 Loss of Reactor Water inventory.	CU1 Reactor Water Level.
		CA2 Loss of all AC power.	CU2 Loss of AC power.
		CA3 Loss of Decay Heat Removal Capability.	CU3 Loss of Decay Heat Removal Capability.
			CU4 Loss of DC power.
			CU5 Loss of communications capabilities.
		CA6 Hazardous event affecting the site.	

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 23 of 109



Brief Description:

While in the cold shutdown or refueling mode, plant operators have indications that a large amount of water has been lost from the reactor pressure vessel which may affect the ability to cool the reactor fuel. The ability of the plant's containment system to function properly is also challenged. Protective actions will be recommended for the public.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components.

When the operators prepare to remove the *spent fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 24 of 109

The water in the *refueling cavity* serves two functions:

- 1) It shields station workers from radiation given off by the *fuel assemblies*.
- and**
- 2) It cools the *fuel assemblies* by removing the *decay heat* the *fission products* are still producing.

Water level and radiation monitors provide indications to the operators if the water level in the *reactor pressure vessel* falls.

The threshold specified in EAL CG1.1 represents a condition during *cold shutdown* or *refueling* mode where the amount of water that has been lost from the *reactor pressure vessel* for 30 minutes or longer affects the ability to properly cool the reactor *fuel assemblies* and the *Containment*, which is the third fission product barrier, is challenged (either not intact or may fail). Therefore, this EAL requires that the plant declare a General Emergency.

The threshold specified in EAL CG1.2 represents a condition during *cold shutdown* or *refueling* mode where plant operators are unable to monitor the level in the *reactor pressure vessel* for 30 minutes or longer and an *unplanned* increase in radiation monitor readings or an unplanned level rise has been seen in plant components that indicate a *reactor pressure vessel* water level that is unable to properly cool the *reactor fuel assemblies* and the *Containment*, which is the third *fission product barrier*, is challenged (either not intact or may fail). Therefore, this EAL requires that the plant declare a General Emergency.

Since the conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 25 of 109

Cold Shutdown/Refueling System Malfunction		
CS1	SITE AREA EMERGENCY	CS1
Loss of Reactor Water Level		

Brief Description:

While in the cold shutdown or refueling mode, plant operators have indications that a large amount of water has been lost from the reactor pressure vessel which may affect the ability to cool the reactor fuel.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components. When the operators prepare to remove the *spent fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water.

The water in the *refueling cavity* serves two functions:

- 1) It shields station workers from radiation given off by the *fuel assemblies*.
and
- 2) It cools the *fuel assemblies* by removing the *decay heat* the *fission products* are still producing.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 26 of 109

Water level and radiation monitors provide indications to the operators if the water level in the *reactor pressure vessel* falls.

The threshold specified in EAL CS1.1 represents a condition during *cold shutdown* or *refueling* mode where the amount of water in the *reactor pressure vessel* has reached a level that could affect the ability to properly cool the *reactor fuel assemblies* and the *Secondary Containment*, which is a part of the third *fission product barrier*, is not intact. Therefore, this EAL requires that the plant declare a Site Area Emergency.

The threshold specified in EAL CS1.2 represents a condition during *cold shutdown* or *refueling* mode where the amount of water in the *reactor pressure vessel* has reached a level that could affect the ability to properly cool the *reactor fuel assemblies* and the *Secondary Containment*, which is a part of the third *fission product barrier*, is intact. Therefore, this EAL requires that the plant declare a Site Area Emergency.

The threshold specified in EAL CS1.3 represents a condition during *cold shutdown* or *refueling* mode where plant operators are unable to monitor the level in the *reactor pressure vessel* for 30 minutes or longer and an *unplanned* increase in radiation monitor readings or an unplanned level rise has been seen in plant components that indicate a *reactor pressure vessel* water level that is unable to properly cool the *reactor fuel assemblies*. Therefore, this EAL requires that the plant declare a Site Area Emergency.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 27 of 109

Cold Shutdown/Refueling System Malfunction		
CA1	ALERT	CA1
Loss of Reactor Water Inventory		

Brief Description:

While in the cold shutdown or refueling mode, plant operators have indications that a large amount of water has leaked from the reactor pressure vessel or plant operators are unable to monitor the systems water level. Current plant conditions DO NOT threaten public safety.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components. When the operators prepare to remove the *spent fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water.

The water in the *refueling cavity* serves two functions:

- 1) It shields station workers from radiation given off by the *fuel assemblies*.
and
- 2) It cools the *fuel assemblies* by removing the *decay heat* the *fission products* are still producing.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 28 of 109

Normally a small amount of monitored water (*reactor coolant*) is expected to leak from the components which make up the *reactor coolant system*. Plant operators continuously monitor the amount of this leakage in two ways, by measuring:

- 1) The rate at which water collection tanks (*drywell* or *equipment drain sumps*) that collect the leakage fill up.
- and**
- 2) The rate at which water must be added to the *reactor coolant system*.

The threshold specified in EAL CA1.1 represents a condition during *cold shutdown* or *refueling* mode where the amount of water in the *reactor pressure vessel* has reached a level that could affect the ability to properly cool the reactor *fuel assemblies*. Therefore, this EAL requires that the plant declare an Alert.

The threshold specified in EAL CA1.2 represents a condition during *cold shutdown* or *refueling* mode where plant operators are unable to monitor the level in the *reactor pressure vessel* for 15 minutes or longer and an *unplanned* level rise has been seen in plant components (*drywell* or *equipment drain sumps*) that indicate a loss of water from the *reactor pressure vessel* or *refueling cavity*. Therefore, this EAL requires that the plant declare an Alert.

These conditions pose no threat to the safety of the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 29 of 109

Cold Shutdown/Refueling System Malfunction		
CA2	ALERT	CA2
Loss of AC Power		

Brief Description:

All alternating current (AC) electrical power from off-site and on-site sources has been lost for more than 15 minutes with the plant in cold shutdown mode, refueling mode, or defueled. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Much of the equipment in the plant, including important pumps and valves in safety systems, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

The threshold specified in EAL CA2.1 represents a condition during *cold shutdown mode*, *refueling mode*, or *defueled* where all the off-site AC power and all the on-site AC power sources are unavailable to operate *vital equipment* for more than 15 minutes. Because the plant is in either *cold shutdown mode*, *refueling mode*, or *defueled* the operators have additional time available to restore power before any plant damage occurs.

This EAL threshold poses no threat to the safety of plant personnel or the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 30 of 109

Cold Shutdown/Refueling System Malfunction		
CA3	ALERT	CA3
Loss of Decay Heat Removal Capability		

Brief Description:

Equipment needed to maintain the reactor water temperature below the boiling point has been lost for an extended period of time. Current plant conditions DO NOT threaten public safety.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

During *cold shutdown* conditions, the reactor *core* is cooled by water in the *Reactor Pressure Vessel*. This water is pumped through the piping and *reactor pressure vessel*. This water keeps the *core* completely covered and removes heat at all times.

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components. When the operators prepare to remove the spent *fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water. Water in the *refueling cavity* is pumped through the piping and *reactor pressure vessel* which keeps the core completely covered while removing *decay heat* at all times.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 31 of 109

The threshold specified in EAL CA3.1 represents conditions during *cold shutdown* and *refueling* where plant operators are unable to maintain the *reactor coolant temperature* below 212°F due to an *unplanned* event. Unless the plant operators take further action, this condition could lead to overheating of the reactor *fuel assemblies* and damage to the reactor *core*. These conditions indicate a loss of the ability to remove *decay heat* and keep the *core* covered with water. Therefore, this EAL threshold requires the plant to declare an Alert.

The threshold specified in EAL CA3.2 represents a condition during *cold shutdown* where plant operators are unable to maintain the *reactor coolant temperature* below 212°F due to an *unplanned* event as indicated by an increase in *reactor coolant system* pressure. Unless the plant operators take further action, this condition could lead to overheating of the reactor *fuel assemblies* and damage to the reactor *core*. This condition indicates a loss of the ability to remove *decay heat* and keep the *core* covered with water. Therefore, this EAL threshold requires the plant to declare an Alert.

These EAL thresholds pose no threat to the safety of plant personnel or the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 32 of 109

Cold Shutdown/Refueling System Malfunction		
CA6	ALERT	CA6
Hazardous Event Affecting the Site		

Brief Description:

A hazardous event, natural or destructive, has occurred that threatens vital equipment required for the safe operation of the plant during cold shutdown or refueling modes. Current plant conditions DO NOT threaten public safety.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components. When the operators prepare to remove the *spent fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water.

The plant and its equipment are designed to withstand most natural events (earthquakes, floods, high winds, tornados, etc.) or any damage that may occur from various other destructive events (fire, explosion, etc.).

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 33 of 109

The EAL threshold for CA6.1 addresses one of the following events that has occurred resulting in either degraded performance of a *safety system* OR visible damage to a *safety system*, component or structure needed during *cold shutdown* or *refueling*:

- An earthquake more intense than the plant was designed to withstand for continued plant operations.
- Internal or external plant flooding which is affecting the operation or performance of *vital plant equipment*.
- High winds or a tornado strike, the result of which, is affecting the operation or performance of *vital plant equipment*.
- A fire or explosion which is affecting the operation or performance of *vital plant equipment*.
- High or low river levels which affect the operation or performance of *vital plant equipment*.
- Other events with similar hazard characteristics as determined by the *Shift Manager*.

Due to the actual or potential substantial degradation of the level of safety of the plant resulting from any of these conditions, plant personnel will declare an Alert.

These conditions pose no threat to the safety of the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 34 of 109

Cold Shutdown/Refueling System Malfunction		
CU1	UNUSUAL EVENT	CU1
Reactor Water Level		

Brief Description:

While in the cold shutdown or refueling mode, the operators have observed an unplanned loss of water level in the reactor pressure vessel or refueling cavity. Current plant conditions DO NOT threaten public safety.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components. When the operators prepare to remove the *spent fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water.

The water in the *refueling cavity* serves two functions:

- 1) It shields station workers from radiation given off by the *fuel assemblies*.
and
- 2) It cools the *fuel assemblies* by removing the *decay heat* the *fission products* are still producing.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 35 of 109

Normally a small amount of monitored water (*reactor coolant*) is expected to leak from the components which make up the *Reactor Coolant System*. Plant operators continuously monitor the amount of this leakage in two ways, by measuring:

- 1) The rate at which water collection tanks (*drywell* or *equipment drain sumps*) that collect the leakage fill up.
- and**
- 2) The rate at which water must be added to the *reactor coolant system*.

The threshold specified in EAL CU1.1 represents a condition during *cold shutdown* or *refueling* mode where the amount of water in the *reactor pressure vessel* has reached a specific level for 15 minutes or longer due to an *unplanned* event. Therefore, this EAL requires that the plant declare an Unusual Event.

The threshold specified in EAL CU1.2 represents a condition during *cold shutdown* or *refueling* mode where plant operators are unable to monitor the level in the *reactor pressure vessel* and an *unplanned* level rise has been seen in plant components (*drywell* or *equipment drain sumps*) that indicate a lowering in *reactor pressure vessel* or *refueling cavity* water level. Therefore, this EAL requires that the plant declare an Unusual Event.

These conditions pose no threat to the safety of the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 36 of 109

Cold Shutdown/Refueling System Malfunction		
CU2	UNUSUAL EVENT	CU2
Loss of AC Power		

Brief Description:

All alternating current (AC) electrical power sources except for one, either on-site or off-site, have been lost for more than 15 minutes with the plant in cold shutdown mode, refueling mode, or defueled. Power is still available from a single source. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The *reactor coolant temperature* is below a temperature near the boiling point, approximately 212°F.

Much of the equipment in the plant, including important pumps and valves in safety systems, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

The threshold specified in EAL CU2.1 represents a condition during *cold shutdown mode*, *refueling mode*, or *defueled* where only one AC power source is available for more than 15 minutes. The plant is relying on this single AC power source to run *vital equipment* needed to cool the plant.

This EAL threshold poses no threat to the safety of plant personnel or the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 37 of 109

Cold Shutdown/Refueling System Malfunction		
CU3	UNUSUAL EVENT	CU3
Loss of Decay Heat Removal Capability		

Brief Description:

Equipment needed to maintain the reactor water temperature below the boiling point has been lost with the plant in cold shutdown or refueling mode. Current plant conditions DO NOT threaten public safety.

Detailed Description:

There are five defined plant operational conditions (modes) and *cold shutdown* is one of them. *Cold shutdown* refers to a plant condition where:

- 1) The *reactor* is *shutdown*; that is, the nuclear chain reaction has stopped.
and
- 2) The *Reactor Coolant Temperature* is below a temperature near the boiling point, approximately 212°F.
and
- 3) The *Reactor Pressure Vessel* is closed (the same condition it would be in if the temperature was above 212°F).

During *cold shutdown* conditions, the reactor core is cooled by water in the *Reactor Pressure Vessel*. This water is pumped through the piping and *reactor pressure vessel*. This water keeps the core completely covered and removes heat at all times.

Refueling is a condition where, while in *cold shutdown*, the *Reactor Pressure Vessel* is opened up to allow the movement of *fuel assemblies* in and out of the *reactor pressure vessel* or maintenance to system components. When the operators prepare to remove the *spent fuel assemblies*, the top of the *reactor pressure vessel* (*reactor vessel head*) is removed and the *refueling cavity* is filled with water. Water in the *refueling cavity* is pumped through the piping and *reactor pressure vessel* which keeps the core completely covered while removing *decay heat* at all times.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 38 of 109

The threshold specified in EAL CU3.1 represents conditions during *cold shutdown* and *refueling* where plant operators are unable to maintain the *reactor coolant temperature* below 212°F due to an *unplanned* event. These conditions indicate a loss of the ability to remove *decay heat*. Therefore, this EAL threshold requires the plant to declare an Unusual Event.

The threshold specified in EAL CU3.2 represents a condition during *cold shutdown* or *refueling* where plant operators are unable to monitor the *reactor coolant temperature* and *reactor pressure vessel* level for 15 minutes or more due to a loss of temperature and level indications. Therefore, this EAL threshold requires the plant to declare an Unusual Event.

These EAL thresholds pose no threat to the safety of plant personnel or the general public.

Escalation to a higher emergency level may be required if plant operators observe additional indications of significant water loss or temperature increases.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 39 of 109

Cold Shutdown/Refueling System Malfunction		
CU4	UNUSUAL EVENT	CU4
Loss of DC Power		

Brief Description:

All sources of direct current (DC) electrical power are degraded while the plant is in cold shutdown or refueling mode. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Certain components and control devices – including many essential to controlling the *reactor safety systems* – are powered by DC electrical power. This DC electrical power is usually obtained from redundant sets of reliable power supplies and batteries, then distributed to the components and controls through conductors (*buses*). If the voltage from all of these redundant supplies and batteries becomes low or is lost altogether, the safety systems would be less likely to perform as they should.

The threshold specified in EAL CU4.1 represents a condition during *cold shutdown* or *refueling* mode where all of the DC power supplies are degraded for 15 minutes or longer. Because the plant was in *cold shutdown* or *refueling* mode, plant operators have additional time to restore power before any serious plant damage would occur.

Although DC power is degraded, AC (alternating current) power is still available. Even though the degraded DC power system affects the ability to control many plant components, not all electrically operated equipment has been lost. Therefore, this EAL threshold requires the plant to declare an Unusual Event.

This EAL threshold poses no threat to the safety of plant personnel or the general public.

Further degradation of plant conditions may result in an escalation in the emergency level.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 40 of 109

Cold Shutdown/Refueling System Malfunction		
CU5	UNUSUAL EVENT	CU5
Loss of Communications Capability		

Brief Description:

On-site or off-site communications equipment has been lost. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Plant personnel must be able to communicate throughout the station to safely operate the plant. Many communications systems are available on-site to perform required routine tasks (telephones, plant page system, or radios).

Plant personnel must also be able to communicate problems to off-site authorities and request assistance if needed. Many systems are also available to perform these communications as required (normal telephones, dedicated telephones/lines, and radios).

The threshold specified in EAL CU5.1 represents a condition during *cold shutdown* mode, *refueling* mode, or *defueled* where all on-site communications systems are unavailable. Since this condition may affect the ability of plant personnel to perform routine tasks, plant personnel will declare an Unusual Event.

The threshold specified in EAL CU5.2 represents a condition during *cold shutdown* mode, *refueling* mode, or *defueled* where all off-site communications systems used to notify local and state response organizations are unavailable. Since this condition may affect the ability of plant personnel to notify response organizations of an event or request support, plant personnel will declare an Unusual Event.

The threshold specified in EAL CU5.3 represents a condition during *cold shutdown* mode, *refueling* mode, or *defueled* where all off-site communications systems used to notify the Nuclear Regulatory Commission (NRC) are unavailable. Since this condition may affect the ability of plant personnel to notify the NRC of an event or request support, plant personnel will declare an Unusual Event.

These EAL thresholds pose no threat to the safety of plant personnel or the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 41 of 109

SECTION E

INDEPENDENT SPENT FUEL STORAGE INSTALLATION (ISFSI)

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 42 of 109

Recognition Category 'E' Initiating Condition Matrix

GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
			EU1 Damage To Loaded Cask Confinement Boundary.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 43 of 109

Independent Spent Fuel Storage Installation		
EU1	UNUSUAL EVENT	EU1
Damage to Loaded Cask Confinement Boundary		

Brief Description:

Damage to a loaded spent fuel storage cask has occurred as indicated by increased radiation levels. Current plant conditions DO NOT threaten public safety.

Detailed Description:

After *reactor fuel assemblies* are no longer used for the fission process they are removed from the *reactor pressure vessel* and stored in the *Spent Fuel Pool*. The used reactor fuel assemblies (*spent fuel*) remain in the *Spent Fuel Pool* for a period of time that allows the by-products of the fission process (*fission products*) to decay, minimizing the heat produced by the *spent fuel assemblies* (at least five years).

Once the *spent fuel assemblies* have been sufficiently cooled, they are transferred to a storage cask that allows for long term dry storage outside of the *Spent Fuel Pool*. Monticello Nuclear Generating Plant (MNGP) is licensed to operate an *Independent Spent Fuel Storage Installation (ISFSI)* within the owner controlled area of the plant for temporary storage of the used reactor *fuel*. The used reactor *fuel* is loaded into a robust storage cask and transported to the *ISFSI* for long term temporary safe storage or until it can be transferred to a permanent storage facility.

The threshold specified in EAL EU1 represents a condition where an event has occurred that has damaged the *confinement boundary* of the storage cask as indicated by increased radiation levels. Therefore, this EAL threshold requires plant personnel to declare an Unusual Event.

This EAL threshold poses no threat to the safety of plant personnel or the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 44 of 109

SECTION F

FISSION PRODUCT BARRIER DEGRADATION

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 45 of 109

Recognition Category 'F' Initiating Condition Matrix

GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
FG1 Loss of any two barriers and Loss or Potential Loss of the third barrier.	FS1 Loss or Potential Loss of two barriers.	FA1 Any Loss or any Potential Loss of either the Fuel Clad or RCS barrier.	

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 46 of 109



Brief Description:

Loss of two of three fission product barriers with actual or potential loss of the third barrier. Protective actions will be recommended for the public.

Detailed Description:

Fission product barriers are plant structures specifically designed to hold in (contain) and prevent the spread of radioactive materials (*fission products*) created during the nuclear reaction. For the purpose of the MNGP Emergency Plan, there are three *fission product barriers*, one inside the other:

- 1) *Fuel Cladding*
- 2) *Reactor Coolant System*
- 3) *Primary Containment*

As long as any one of these barriers stays intact, significant amounts of radioactive *fission products* **cannot** be released outside of the plant. However, if it is determined that two of the three barriers have failed and a third is potentially or actually failed, a General Emergency will be declared.

There are certain conditions under which each of these *fission product barriers* could fail:

Fuel Cladding: The *fuel cladding* forms the first *fission product barrier*. The sealed metal tubes surrounding the fuel pellets would fail to contain radioactive material (*fission products*) if the *core* is not cooled enough. This could happen if there is not enough water circulating around the metal tubes to cool them, or if a loose part hits and damages the *fuel cladding*.

Normally the reactor *core* is kept covered with water to remove the heat. Even when the reactor is *shutdown*, the nuclear *fuel* produces a significant amount of *decay heat* which must be removed. Without cooling water to remove this heat, the *fuel cladding* could overheat and crack.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 47 of 109

In the worst case, a loss of cooling water (*loss of coolant accident*) could be combined with a failure of the back-up systems (*emergency core cooling systems*) that pump additional water to the *reactor pressure vessel* cooling the *reactor fuel assemblies*. This would lead to the *reactor fuel assemblies* becoming uncovered and inadequately cooled. Inadequate cooling would result in the *fuel cladding* becoming damaged.

Reactor Coolant System: The *reactor coolant system* could fail to hold in radioactive materials if radioactive water or steam leaks from it. The *reactor coolant system* forms the second *fission product barrier*. To function as an effective barrier against the release of radioactive materials it must remain intact, withstanding the pressure and temperature created by the water as it boils into steam. If the pressure within the *reactor pressure vessel* becomes too high, or if a mechanical failure occurs, the vessel or piping could fail, allowing steam and water to escape into the layer of protection which lies outside it (*primary containment*).

Primary Containment: The third *fission product barrier*, *primary containment*, is specifically designed to hold in energy from the steam and prevent the release of radioactive materials if the first and second *fission product barriers* fail. Certain unlikely conditions might threaten the integrity of the *primary containment*. They are:

- 1) Too high a temperature in the containment
- 2) Too high a pressure in the containment
- 3) Combustible gas mixtures in containment (hydrogen and oxygen)
- 4) Mechanical failure of a containment isolation system

Even if all three fission product barriers are lost – an unlikely event – the *secondary containment*, which surrounds the *primary containment*, provides another barrier to limit the release of radioactive materials.

The threshold specified in EAL FG1 identifies conditions where the potential exists for a significant release of radioactive fission products outside of the plant. This condition warrants declaration of a General Emergency.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 48 of 109

Fission Product Barrier Degradation		
FS1	SITE AREA EMERGENCY	FS1
Loss or Potential Loss of any Two Fission Product Barriers		

Brief Description:

Loss or potential loss of two of three fission product barriers.

Detailed Description:

Fission product barriers are plant structures specifically designed to hold in (contain) and prevent the spread of radioactive materials (*fission products*) created during the nuclear reaction. For the purpose of the MNGP Emergency Plan, there are three *fission product barriers*, one inside the other:

- 1) *Fuel Cladding*
- 2) *Reactor Coolant System*
- 3) *Primary Containment*

As long as any one of these barriers stays intact, significant amounts of radioactive *fission products* **cannot** be released outside of the plant. However, if it is determined that two of the three barriers have failed or potentially failed, a Site Area Emergency will be declared.

There are certain conditions under which each of these *fission product barriers* could fail:

Fuel Cladding: The *fuel cladding* forms the first *fission product barrier*. The sealed metal tubes surrounding the fuel pellets would fail to contain radioactive material (*fission products*) if the *core* is not cooled enough. This could happen if there is not enough water circulating around the metal tubes to cool them, or if a loose part hits and damages the *fuel cladding*.

Normally the reactor *core* is kept covered with water to remove the heat. Even when the reactor is *shutdown*, the nuclear fuel produces a significant amount of *decay heat* which must be removed. Without cooling water to remove this heat, the *fuel cladding* could overheat and crack.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 49 of 109

In the worst case, a loss of cooling water (*loss of coolant accident*) could be combined with a failure of the back-up systems (*emergency core cooling systems*) that pump additional water to the *reactor pressure vessel* cooling the *reactor fuel assemblies*. This would lead to the *reactor fuel assemblies* becoming uncovered and inadequately cooled. Inadequate cooling would result in the *fuel cladding* becoming damaged.

Reactor Coolant System: The *reactor coolant system* could fail to hold in radioactive materials if radioactive water or steam leaks from it. The *reactor coolant system* forms the second *fission product barrier*. To function as an effective barrier against the release of radioactive materials it must remain intact, withstanding the pressure and temperature created by the water as it boils into steam. If the pressure within the *reactor pressure vessel* becomes too high, or if a mechanical failure occurs, the vessel or piping could fail, allowing steam and water to escape into the layer of protection which lies outside it (*primary containment*).

Primary Containment: The third *fission product barrier*, *primary containment*, is specifically designed to hold in energy from the steam and prevent the release of radioactive materials if the first and second *fission product barriers* fail. Certain unlikely conditions might threaten the integrity of the *primary containment*. They are:

- 1) Too high a temperature in the containment
- 2) Too high a pressure in the containment
- 3) Combustible gas mixtures in containment (hydrogen and oxygen)
- 4) Mechanical failure of a containment isolation system

Even if all three fission product barriers are lost – an unlikely event – the *secondary containment*, which surrounds the *primary containment*, provides another barrier to limit the release of radioactive materials.

The threshold specified in EAL FS1 identifies a condition where the plant operators have determined that two of the three fission product barriers have failed or potentially failed. This condition warrants declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 50 of 109

Fission Product Barrier Degradation		
FA1	ALERT	FA1
Loss/Potential Loss of the Fuel Cladding or Reactor Coolant System		

Brief Description:

There are indications of a loss or potential loss of either the Fuel Cladding or Reactor Coolant System barrier. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Fission product barriers are plant structures specifically designed to hold in (contain) and prevent the spread of radioactive materials (*fission products*) created during the nuclear reaction. For the purpose of the MNGP Emergency Plan, there are three *fission product barriers*, one inside the other:

- 1) *Fuel Cladding*
- 2) *Reactor Coolant System*
- 3) *Primary Containment*

As long as any one of these barriers stays intact, significant amounts of radioactive *fission products* **cannot** be released outside of the plant. However, if it is determined that any loss or any potential loss of either the Fuel Cladding or Reactor Coolant System *fission product barrier* has or will potentially occur, an Alert will be declared.

There are certain conditions under which either the Fuel Cladding or Reactor Coolant System *fission product barrier* could fail:

Fuel Cladding: The *fuel cladding* forms the first *fission product barrier*. The sealed metal tubes surrounding the fuel pellets would fail to contain radioactive material (*fission products*) if the core is not cooled enough. This could happen if there is not enough water circulating around the metal tubes to cool them, or if a loose part hits and damages the *fuel cladding*.

Normally the reactor *core* is kept covered with water to remove the heat. Even when the *reactor* is *shutdown*, the nuclear fuel produces a significant amount of *decay heat* which must be removed. Without cooling water to remove this heat, the *fuel cladding* could overheat and crack.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 51 of 109

In the worst case, a loss of cooling water (*loss of coolant accident*) could be combined with a failure of the back-up systems (*emergency core cooling systems*) that pump additional water to the *reactor pressure vessel* cooling the *reactor fuel assemblies*. This would lead to the *reactor fuel assemblies* becoming uncovered and inadequately cooled. Inadequate cooling would result in the *fuel cladding* becoming damaged.

Reactor Coolant System: The *reactor coolant system* could fail to hold in radioactive materials if radioactive water or steam leaks from it. The *reactor coolant system* forms the second *fission product barrier*. To function as an effective barrier against the release of radioactive materials it must remain intact, withstanding the pressure and temperature created by the water as it boils into steam. If the pressure within the *reactor pressure vessel* becomes too high, or if a mechanical failure occurs, the vessel or piping could fail, allowing steam and water to escape into the layer of protection which lies outside it (*primary containment*).

The threshold specified in EAL FA1 identifies a condition where the plant operators have determined that there is a loss or potential loss of the Fuel Cladding or Reactor Coolant System *fission product barriers*. This condition warrants declaration of an Alert.

This EAL threshold poses no threat to the safety of the general public.

<i>MONTICELLO NUCLEAR GENERATING PLANT</i>		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 52 of 109

SECTION H

HAZARDS AND OTHER CONDITIONS

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 53 of 109

Recognition Category 'H' Initiating Condition Matrix

GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
HG1 Security.	HS1 Security.	HA1 Security.	HU1 Security.
			HU2 Earthquake.
			HU3 Hazardous event affecting the site.
			HU4 Fire.
		HA5 Gaseous release.	
	HS6 Control Room Evacuation.	HA6 Control Room Evacuation.	
HG7 Miscellaneous Events.	HS7 Miscellaneous Events.	HA7 Miscellaneous Events.	HU7 Miscellaneous Events.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 54 of 109

Hazards and Other Conditions		
HG1	GENERAL EMERGENCY	HG1
Security		

Brief Description:

Station security has been compromised in a way that has caused a loss of physical control of the plant or caused the loss of the ability to maintain cooling of the fuel assemblies stored in the Spent Fuel Pool such that fuel damage is likely. Protective actions will be recommended for the public.

Detailed Description:

Property surrounding and controlled by plant personnel is contained within two distinct boundaries, the *Owner Controlled Area* and the *Protected Area*.

The Owner Controlled Area (OCA) boundary is the outermost zone and lies outside the Protected Area (PA) boundary. The OCA consists of the property surrounding the station. This area is bounded by the outermost fence and controlled for security purposes.

The *Protected Area (PA)* boundary is the innermost zone and includes plant vital structures and is surrounded by a security fence. Access to this area is restricted to authorized personnel and controlled by the station's Security Force. There are two separate protected areas within the Monticello Nuclear Generating Plant (MNGP) *Owner Controlled Area* - the *Independent Spent Fuel Storage Installation (ISFSI) PA* and the *Plant PA*. All MNGP *vital areas* are contained inside the *Plant PA*.

The threshold specified in EAL HG1.1 identifies one of two security conditions:

- 1) A security condition that exists due to a *hostile force* intrusion which has resulted in the loss of physical control of equipment required to maintain safety functions and control of that equipment **cannot** be transferred to and operated from another location. These safety functions are reactivity control (ability to *shutdown* the *reactor* and keep it *shutdown*), *reactor pressure vessel* water level (ability to cool the *fuel assemblies* in the *reactor core*), and *decay heat* removal (ability to maintain a *heat sink*).

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 55 of 109

- 2) A security condition that exists due to a *hostile force* intrusion which has resulted in the failure of the *spent fuel pool* or *spent fuel pool* cooling systems and damage to the *spent fuel assemblies* in the *spent fuel pool* is *imminent*.

If either of these security conditions exist, then station personnel would be required to declare a General Emergency. Station personnel would inform appropriate law enforcement agencies as well as those agencies normally notified during a General Emergency.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 56 of 109

Hazards and Other Conditions		
HG7	GENERAL EMERGENCY	HG7
Micellaneous Events		

Brief Description:

A condition exists which indicates an actual or imminent release of radioactivity as large as that associated with a General Emergency. Protective actions will be recommended for the public.

Detailed Description:

The threshold specified in EAL HG7.1 provides the *Emergency Director* with the latitude to declare a General Emergency based on his or her own experience and judgment. It applies to any condition (not already described by another specific EAL threshold), including an actual loss of physical control of the plant due to *hostile action*, which involves the actual or potential release of radioactive material in amounts requiring protective actions for the public. Any releases of radioactive material can be reasonably expected to exceed *EPA Protective Action Guideline (PAG)* exposure levels off-site for more than the immediate site area.

This EAL threshold requires declaration of a General Emergency.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 57 of 109

Hazards and Other Conditions		
HS1	SITE AREA EMERGENCY	HS1
Security		

Brief Description:

The site has come under a dedicated attack by a hostile force that has penetrated the plant Protected Area (PA). This condition, by itself, poses no immediate threat to public safety.

Detailed Description:

Property surrounding and controlled by plant personnel is contained within two distinct boundaries, the *Owner Controlled Area* and the *Protected Area*.

The *Owner Controlled Area (OCA)* boundary is the outermost zone and lies outside the *Protected Area (PA)* boundary. The OCA consists of the property surrounding the station. This area is bounded by the outermost fence and controlled for security purposes.

The *Protected Area (PA)* boundary is the innermost zone and includes plant *vital structures* and is surrounded by a security fence. Access to this area is restricted to authorized personnel and controlled by the station's Security Force. There are two separate protected areas within the Monticello Nuclear Generating Plant (MNGP) *Owner Controlled Area* - the *Independent Spent Fuel Storage Installation (ISFSI) PA* and the *Plant PA*. All MNGP *vital areas* are contained inside the *Plant PA*.

The threshold specified in EAL HS1.1 identifies a security condition in which a *hostile action* is occurring or has occurred within the MNGP Plant PA. A *hostile action* is an act directed toward MNGP or its personnel that includes the use of violent force to destroy equipment, take hostages, and/or intimidate utility personnel to achieve an end. This includes attack by air, land, or water using guns, explosives, projectiles, vehicles, or other devices to deliver destructive force. It does not include acts of civil disobedience, criminal acts, or accidental events that are not part of a concerted attack on MNGP which are addressed by other EAL thresholds. This EAL threshold is not based solely on the potential for a radiological release. Rather, the condition includes the need for off-site assistance due to the possibility for significant and indeterminate damage from additional *hostile action*. Therefore, this security condition warrants declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 58 of 109

Hazards and Other Conditions		
HS6	SITE AREA EMERGENCY	HS6
Control Room Evacuation		

Brief Description:

The Control Room has been evacuated and plant operators have been unable to establish control of plant systems from remote locations within 10 minutes.

Detailed Description:

Normally the plant is operated, monitored, and controlled from the *Control Room*. If fire, smoke, radiological hazards, or other events were to force plant operators from the *Control Room*, they would still be able to take control of the plant from another location (*alternate shutdown panel*). From this panel plant operators can perform critical safety functions normally performed from the *Control Room*.

The thresholds specified in EAL HS6.1 represent conditions in which plant operators have evacuated the *Control Room* but have been unable to gain control of critical plant safety functions from the *alternate shutdown panel* within a reasonable amount of time (10 minutes). These safety functions are reactivity control (ability to *shutdown* the *reactor* and keep it *shutdown*), *reactor pressure vessel* water level (ability to cool the *fuel assemblies* in the reactor core), and *decay heat* removal (ability to maintain a *heat sink*). If control of these safety functions cannot be established in a reasonable amount of time, the ability to maintain the *reactor* in a safe and stable condition is degraded. Therefore, this conditions warrants declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 59 of 109

Hazards and Other Conditions		
HS7	SITE AREA EMERGENCY	HS7
Miscellaneous Events		

Brief Description:

Conditions in the plant exist which call for the kind of response associated with a Site Area Emergency classification.

Detailed Description:

The threshold specified in EAL HS7.1 provides the *Emergency Director* with the latitude to declare a Site Area Emergency based on his or her own experience and judgment. It applies to any condition (not already described by another specific EAL threshold), including the results of a *hostile action*, which involves the actual or potential failures of plant *safety systems* needed to maintain the *reactor* in a safe condition and to protect the public. Therefore, this condition warrants a declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 60 of 109

Hazards and Other Conditions		
HA1	ALERT	HA1
	Security	

Brief Description:

*The site has come under a dedicated attack by a hostile force within the Owner Controlled Area; **OR**, the site has been informed by the NRC of a credible threat of an aircraft attack within 30 minutes. Current plant conditions DO NOT threaten public safety.*

Detailed Description:

Property surrounding and controlled by plant personnel is contained within two distinct boundaries, the *Owner Controlled Area* and the *Protected Area*.

The *Owner Controlled Area (OCA)* boundary is the outermost zone and lies outside the *Protected Area (PA)* boundary. The OCA consists of the property surrounding the station. This area is bounded by the outermost fence and controlled for security purposes.

The *Protected Area (PA)* boundary is the innermost zone and includes plant *vital structures* and is surrounded by a security fence. Access to this area is restricted to authorized personnel and controlled by the station's Security Force. There are two separate protected areas within the Monticello Nuclear Generating Plant (MNGP) *Owner Controlled Area* - the *Independent Spent Fuel Storage Installation (ISFSI) PA* and the *Plant PA*. All MNGP *vital areas* are contained inside the *Plant PA*.

The threshold specified in EAL HA1.1 identifies a security condition in which a *hostile action* is occurring or has occurred within the MNGP OCA, which includes the *ISFSI PA*. A *hostile action* is an act directed toward MNGP or its personnel that includes the use of violent force to destroy equipment, take hostages, and/or intimidate utility personnel to achieve an end. This includes attack by air, land, or water using guns, explosives, projectiles, vehicles, or other devices to deliver destructive force. It does not include acts of civil disobedience, criminal acts, or accidental events that are not part of a concerted attack on MNGP which are addressed by other EAL thresholds.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 61 of 109

The threshold specified in EAL HA1.2 identifies a security condition in a very rapid progression of events due to an airborne terrorist attack, such as that experienced on September 11, 2001, is occurring. If such an attack is directed against MNGP, plant personnel would be notified by the NRC or military personnel if the threat is estimated to be within 30 minutes of the site.

These EAL thresholds are not based solely on the potential for a radiological release. Rather the conditions include the need for off-site assistance due to the possibility for significant and indeterminate damage from a *hostile action*. Therefore, these security conditions warrant a declaration of an Alert.

These conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 62 of 109

Hazards and Other Conditions		
HA5	ALERT	HA5
Gaseous Release		

Brief Description:

Access to rooms or plant areas containing plant equipment used for normal plant operations or normal shutdown and cooldown is prohibited or impeded due to the release of a toxic, corrosive, asphyxiant, or flammable gas. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Various rooms and areas contain plant equipment that is used during normal plant operations or whenever the plant is being *shutdown*. Access to these rooms/areas is required to operate equipment during these time frames. A release of potentially harmful quantities of hazardous gases into these rooms/areas that prohibits or impedes access for normal plant operations or *shutdown* could affect the safe operation of the plant.

The threshold for EAL HA5.1 identifies specific rooms/areas requiring access by plant operators. If access to these rooms/areas is prohibited or impeded due to a release of a hazardous gas, then plant personnel will declare an Alert.

This EAL threshold poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 63 of 109

Hazards and Other Conditions		
HA6	ALERT	HA6
Control Room Evacuation		

Brief Description:

The Control Room is being evacuated. Control of plant systems is being established from another location within the plant. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Normally the plant is operated, monitored, and controlled from the *Control Room*. If fire, smoke, radiological hazards, or other events were to force plant operators from the *Control Room*, they would still be able to take control of the plant from another location (*alternate shutdown panel*). From this panel plant operators can perform critical safety functions normally performed from the *Control Room*.

The threshold specified in EAL HS6.1 represents a condition in which plant operators have started an evacuation of the *Control Room* to gain control of critical plant safety functions from the *alternate shutdown panel*. These safety functions are reactivity control (ability to *shutdown* the *reactor* and keep it *shutdown*), *reactor pressure vessel* water level (ability to cool the *fuel assemblies* in the *reactor core*), and *decay heat* removal (ability to maintain a *heat sink*). This condition warrants declaration of an Alert. If control of the safety functions cannot be established in a reasonable amount of time after evacuating the *Control Room*, a higher level of emergency would likely be declared.

This EAL threshold poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 64 of 109

Hazards and Other Conditions		
HA7	ALERT	HA7
Miscellaneous Events		

Brief Description:

Conditions in the plant exist which call for the kind of response associated with an Alert classification. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The threshold specified in EAL HA7.1 provides the *Emergency Director* with the latitude to declare an Alert based on his or her own experience and judgment. It applies to any condition (not already described by another specific EAL threshold), including the results of a *hostile action*, which involves the actual or potential substantial decrease in the level of safety of the plant. Therefore, this condition warrants a declaration of an Alert.

This condition poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 65 of 109

Hazards and Other Conditions		
HU1	UNUSUAL EVENT	HU1
Security		

Brief Description:

A credible threat to the physical security of the plant has been received. Current plant conditions DO NOT threaten public safety.

Detailed Description:

EAL threshold HU1.1 addresses security events that constitute a threat/compromise to site security, a threat/risk to site personnel, or a potential degradation to the level of safety of the plant. These events do not include *hostile actions*; that is, they do not include the use of violent force to destroy equipment, take hostages, and/or intimidate the plant staff to achieve an end. Therefore, this condition warrants an Unusual Event declaration.

EAL threshold HU1.2 addresses credible threat notifications received by Monticello Nuclear Generating Plant (MNGP) personnel. The intent of this threshold is to ensure that notifications of the security threat are made in a timely manner so that emergency response personnel are at a state of heightened awareness regarding the threat. Therefore, this condition warrants an Unusual Event declaration.

EAL threshold HU1.3 is met whenever MNGP personnel receive information regarding an aircraft threat from the NRC. The intent of this threshold is to ensure that notifications of the security threat are made in a timely manner so that emergency response personnel are at a state of heightened awareness regarding the threat. Therefore, this condition warrants an Unusual Event declaration.

These EAL thresholds pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 66 of 109

Hazards and Other Conditions		
HU2	UNUSUAL EVENT	HU2
Earthquake		

Brief Description:

An earthquake (seismic event), affecting the site, has occurred. Current plant conditions DO NOT threaten public safety.

Detailed Description:

EAL threshold HU2.1 addresses a seismic event (earthquake) that results in ground motion detected at the plant site that may affect the operation of the plant (*Operating Basis Earthquake - OBE*). An earthquake greater than an *OBE* should have no significant impact on plant systems, structures and components required to protect public health and safety; however, some time may be required for the plant staff to determine the actual post-event condition of the plant (e.g., perform plant walk-downs and post-event inspections). Given the time necessary to perform these walk-downs and inspections, and to fully understand any impact, this event represents a potential degradation to the level of safety of the plant. Therefore, plant personnel will declare an Unusual Event.

This condition poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 67 of 109

Hazards and Other Conditions		
HU3	UNUSUAL EVENT	HU3
Hazardous Event Affecting the Site		

Brief Description:

A hazardous event, natural or destructive, has occurred within the plant protected area of the station. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Property surrounding and controlled by plant personnel is contained within two distinct boundaries, the *Owner Controlled Area* and the *Protected Area*.

The *Owner Controlled Area (OCA)* boundary is the outermost zone and lies outside the *Protected Area (PA)* boundary. The OCA consists of the property surrounding the station. This area is bounded by the outermost fence and controlled for security purposes.

The *Protected Area (PA)* boundary is the innermost zone and includes plant *vital structures* and is surrounded by a security fence. Access to this area is restricted to authorized personnel and controlled by the station's Security Force. There are two separate protected areas within the Monticello Nuclear Generating Plant (MNGP) *Owner Controlled Area* - the *Independent Spent Fuel Storage Installation (ISFSI) PA* and the *Plant PA*. All MNGP *vital areas* are contained inside the *Plant PA*.

The plant and its equipment are designed to withstand most natural events (floods, tornados, etc.) or any hazardous conditions which may occur from other destructive events (offsite chemical spills or toxic gas release, impeded plant access, etc.).

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 68 of 109

EAL thresholds HU3.1, HU3.2, HU3.3, HU3.4, HU3.5, and HU3.6 address one of the following events that has occurred:

- A tornado striking within the plant PA (HU3.1)
- Uncontrolled flooding in areas of the plant which may affect a *safety system* component (HU3.2)
- An offsite event involving hazardous materials impeding the movement of personnel within the *Plant PA* (HU3.3)
- Access to the site by plant personnel traveling in personal vehicles is prohibited due to hazardous event conditions on-site (HU3.4)
- High river level which may affect the performance of plant systems (HU3.5)
- Low river level which may affect the performance of plant systems (HU3.6)

These EAL thresholds require that an Unusual Event be declared.

These conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 69 of 109

Hazards and Other Conditions		
HU4	UNUSUAL EVENT	HU4
Fire		

Brief Description:

A fire with the potential to degrade the safety of the plant has occurred. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Property surrounding and controlled by plant personnel is contained within two distinct boundaries, the *Owner Controlled Area* and the *Protected Area*.

The *Owner Controlled Area (OCA)* boundary is the outermost zone and lies outside the *Protected Area (PA)* boundary. The OCA consists of the property surrounding the station. This area is bounded by the outermost fence and controlled for security purposes.

The *Protected Area (PA)* boundary is the innermost zone and includes plant *vital structures* and is surrounded by a security fence. Access to this area is restricted to authorized personnel and controlled by the station's Security Force. There are two separate protected areas within the Monticello Nuclear Generating Plant (MNGP) *Owner Controlled Area* - the *Independent Spent Fuel Storage Installation (ISFSI) PA* and the *Plant PA*. All MNGP *vital areas* are contained inside the *Plant PA*.

A fire may be detected by visual observation (report from the field), multiple fire alarms or indications, or verification of a single fire alarm. Any significant fire that occurs within *Plant PA* or *ISFSI PA* potentially threatens plant safety. Those large enough to require *fire brigade* activation might both endanger personnel and cause significant property damage. In addition, the *Fire Brigade Leader* shall evaluate the need for off-site firefighting assistance and request these resources if needed.

EAL threshold HU4.1 applies to fires within a specific plant room or area containing *safety system* equipment that are not extinguished within 15 minutes of detection.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 70 of 109

EAL threshold HU4.2 applies to receipt of a single fire alarm for a specific plant room or area containing *safety system* equipment that cannot be confirmed within 30 minutes of the alarm receipt.

EAL threshold HU4.3 applies to fires within the *Plant* or *ISFSI PA*, outside of specific plant rooms or areas containing *safety system* equipment, which are not extinguished within 60 minutes of the initial fire report, alarm, or indication.

EAL threshold HU4.4 applies to fires within the *Plant* or *ISFSI PA* that requires the firefighting support of off-site fire response agencies to extinguish.

These EAL thresholds require that an Unusual Event be declared.

These conditions pose no threat to the safety of the general public.

Depending on how severe the fire is and its impact on the plant, a higher level of emergency might be declared.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 71 of 109

Hazards and Other Conditions		
HU7	UNUSUAL EVENT	HU7
Miscellaneous Events		

Brief Description:

Conditions in the plant exist which call for the heightened awareness and notifications associated with an Unusual Event Classification. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The threshold specified in EAL HU7.1 provides the *Emergency Director* with the latitude to declare an Unusual Event based on his or her own experience and judgment. It applies to any condition (not already described by another specific EAL), including a security threat, which potentially threatens the safety of the plant. Therefore, this condition warrants an Unusual Event declaration.

This condition poses no threat to the safety of the general public.

<i>MONTICELLO NUCLEAR GENERATING PLANT</i>		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 72 of 109

SECTION S

SYSTEM MALFUNCTION

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 73 of 109

Recognition Category 'S' Initiating Condition Matrix

GENERAL EMERGENCY	SITE AREA EMERGENCY	ALERT	UNUSUAL EVENT
SG1 Loss of AC power.	SS1 Loss of AC power.	SA1 Loss of AC power.	SU1 Loss of AC power.
		SA2 Loss of Assessment Capability.	SU2 Loss of Assessment Capability.
			SU3 Reactor Coolant System Activity.
			SU4 Reactor Coolant System Leakage.
	SS5 Reactor Power.	SA5 Reactor Power.	SU5 Reactor Power.
			SU6 Loss of Communications Capabilities.
SG8 Loss of AC and DC power.	SS8 Loss of DC power.		
		SA9 Hazardous event affecting the site.	

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 74 of 109

System Malfunction		
SG1	GENERAL EMERGENCY	SG1
Loss of AC Power		

Brief Description:

All alternating current (AC) electrical power from off-site and on-site electrical power sources has been lost and it is not expected to be restored for a prolonged period of time. Protective actions will be recommended for the public.

Detailed Description:

Much of the equipment in the plant, including important pumps and valves in *safety systems*, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

The thresholds specified in EAL SG1.1 represents a condition where all the off-site AC power and all the on-site AC power sources are unavailable to operate *vital equipment*. If all AC power is lost for a prolonged period of time (longer than 4 hours), the ability to cool the *reactor fuel assemblies* could be lost.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 75 of 109

System Malfunction		
SG8	GENERAL EMERGENCY	SG8
Loss of AC and DC Power		

Brief Description:

All alternating current (AC) electrical power from off-site and on-site electrical power sources has been lost concurrent with the loss of direct current (DC) electrical power for 15 minutes or longer. Protective actions will be recommended for the public.

Detailed Description:

Much of the equipment in the plant, including important pumps and valves in *safety systems*, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

Certain components and control devices – including many essential to controlling and monitoring the reactor *safety systems* – are powered by DC electrical power. This DC electrical power is usually obtained from redundant sets of reliable power supplies and batteries, then distributed to the components and controls through conductors (*buses*). If the voltage from all of these redundant supplies and batteries becomes low or is lost altogether, the *reactor safety systems* would be unable to perform as they should.

The thresholds specified in EAL SG8.1 represents a condition where all the off-site AC power and all the on-site AC power sources are unavailable to operate *vital equipment* and all DC power is unavailable to control and monitor reactor *safety systems* for 15 minutes or longer. With a concurrent and sustained loss of all AC and DC power, multiple challenges to the *fission product barriers* exists.

Since these conditions could pose a threat to the public, utility personnel will recommend that the state and local authorities consider appropriate protective actions.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 76 of 109

System Malfunction		
SS1	SITE AREA EMERGENCY	SS1
Loss of AC Power		

Brief Description:

All alternating current (AC) electrical power from off-site and on-site power sources has been lost for 15 minutes or longer.

Detailed Description:

Much of the equipment in the plant, including important pumps and valves in *safety systems*, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

The threshold for EAL SS1.1 represents a condition where all off-site and on-site AC electrical power supplies to the reactor *safety systems* required to support cooling of the *reactor fuel assemblies* has been lost for 15 minutes or longer. Therefore, this condition warrants declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 77 of 109

System Malfunction		
SS5	SITE AREA EMERGENCY	SS5
Reactor Power		

Brief Description:

The reactor control rods have failed to shutdown the reactor resulting in a challenge to reactor water level or heat removal capability.

Detailed Description:

A reactor SCRAM is a way to rapidly *shutdown* the reactor (stop the *fission process* and bring the reactor *sub-critical*) by quickly inserting all *control rods* into the reactor *core*. Reactor SCRAMs can be initiated either automatically, by the *Reactor Protection System*, or manually, by the operators.

However, if a reactor SCRAM is started and the *control rods* do not insert, the *reactor* may not *shutdown* fully. *Emergency Operating Procedures* provide direction to the operators on alternate ways to *shutdown* the *reactor*. If the *reactor* does not fully *shutdown* and alternate ways to shut it down fail, the *reactor* will continue to produce heat.

The threshold specified in EAL SS5.1 represents a condition where both automatic and manual signals to *shutdown* the *reactor* failed and the *reactor* is still generating power and heat. Therefore, this condition warrants declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 78 of 109

System Malfunction		
SS8	SITE AREA EMERGENCY	SS8
Loss of DC Power		

Brief Description:

DC (Direct Current) electrical power to vital equipment is degraded.

Detailed Description:

Certain components and control devices – including many essential to controlling and monitoring the reactor *safety systems* – are powered by DC electrical power. This DC electrical power is usually obtained from redundant sets of reliable power supplies and batteries, then distributed to the components and controls through conductors (*buses*). If the voltage from all of these redundant supplies and batteries becomes low or is lost altogether, the reactor *safety systems* would be unable to perform as they should.

The threshold specified in EAL SS8.1 represents a condition where all the DC power sources that supply equipment needed to safely *shutdown*, cooldown, and monitor reactor *safety systems* are degraded for 15 minutes or longer.

Although all vital DC power is degraded, AC (alternating current) power is still available. Therefore, while a degraded DC power system affects the ability to control and monitor many plant components, not all electrically operated equipment is lost. This condition warrants declaration of a Site Area Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 79 of 109

System Malfunction		
SA1	ALERT	SA1
Loss of AC Power		

Brief Description:

Many sources of AC (Alternating Current) electrical power have been lost. Only one source of AC power to safety systems has been available for 15 minutes or longer. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Much of the equipment in the plant, including important pumps and valves in *safety systems*, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

The threshold for EAL SA1.1 represents a condition where only one source of AC power has been available to run the equipment needed to safely *shutdown* and cool the plant (*vital equipment*) for 15 minutes or longer. This condition warrants an Alert declaration. If the remaining source of power is lost, a higher level of emergency would be declared.

These conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 80 of 109

System Malfunction		
SA2	ALERT	SA2
Loss of Assessment Capability		

Brief Description:

The capability to monitor alarms or indicators in the control room has been lost for 15 minutes or longer in combination with another plant operating problem. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Plant operators continually monitor the status of the *reactor* and its associated safety and support systems. They rely on meters, gauges, *annunciators*, indicating lights, computer displays, and printouts to assess reactor and equipment performance. These components are also used to identify problems in a timely manner enabling timely response actions to be taken. In most cases, the operator has more than one instrument or alarm that would indicate problems in a specific area.

The *Control Room annunciators*, meters, and gauges are most crucial to the operator to help ensure that the reactor is operating safely. Key *safety system* parameters that are routinely monitored by plant operators are:

- *Reactor Power*
- *Reactor Pressure Vessel (RPV) Water Level*
- *RPV Pressure*
- *Primary Containment Pressure*
- *Suppression Pool Level*
- *Suppression Pool Temperature*

If an *unplanned* event occurs resulting in a significant loss of these indicators and a significant change in plant operating conditions occurs, the ability to adequately monitor and maintain the *reactor* in a safe condition is challenged.

The threshold for EAL SA2.1 represents this condition, which is indicative of degradation of the level of safety of the plant. Therefore, plant personnel will declare an Alert.

This EAL threshold poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 81 of 109

System Malfunction		
SA5	ALERT	SA5
Reactor Power		

Brief Description:

Automatic or manual actions to insert the reactor control rods from the main reactor control panels have been unsuccessful. Other actions taken by the plant operators have successfully inserted the reactor control rods and the reactor is shutdown. Current plant conditions DO NOT threaten public safety.

Detailed Description:

A reactor *SCRAM* is a way to rapidly *shutdown* the *reactor* (stop the *fission process* and bring the reactor *sub-critical*) by quickly inserting all *control rods* into the reactor core. Reactor *SCRAMs* can be initiated either automatically, by the *Reactor Protection System*, or manually, by the operators.

However, if a reactor *SCRAM* is started and the *control rods* do not insert, the reactor may not *shutdown* fully. *Emergency Operating Procedures* provide direction to the operators on alternate ways to *shutdown* the *reactor*, including actions away from the main *reactor control panels*.

The threshold specified in EAL SA5.1 represents a condition where both automatic signals and manual actions to *shutdown* the *reactor* from the main *reactor control panels* failed. This condition requires plant personnel to declare an Alert.

This EAL threshold poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 82 of 109

System Malfunction		
SA9	ALERT	SA9
Hazardous Event Affecting the Site		

Brief Description:

A hazardous event, natural or destructive, has occurred that threatens vital equipment required for the safe operation of the plant. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The plant and its equipment are designed to withstand most natural events (earthquakes, floods, high winds, tornados, etc.) or any damage that may occur from various other destructive events (fire, explosion, etc.).

The EAL threshold for SA9.1 addresses one of the following events that has occurred resulting in either degraded performance of a *safety system* OR visible damage to a *safety system*, component or structure needed to support plant operation:

- An earthquake more intense than the plant was designed to withstand for continued plant operations.
- Internal or external plant flooding which is affecting the operation or performance of *vital plant equipment*.
- High winds or a tornado strike, the result of which, is affecting the operation or performance of *vital plant equipment*.
- A fire or explosion which is affecting the operation or performance of *vital plant equipment*.
- High or low river levels which affect the operation or performance of *vital plant equipment*.
- Other events with similar hazard characteristics as determined by the *Shift Manager*.

Due to the actual or potential substantial degradation of the level of safety of the plant resulting from any of these conditions, plant personnel will declare an Alert.

These conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 83 of 109

System Malfunction		
SU1	UNUSUAL EVENT	SU1
Loss of AC Power		

Brief Description:

All off-site AC (alternating current) electrical power has been lost for 15 minutes or longer. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Much of the equipment in the plant, including important pumps and valves in safety systems, is powered by AC electrical power. There are a number of main sources and backup sources for this type of power, including:

- 1) Off-site AC power, which is supplied from outside the station through electric power transmission lines, passes through *transformers*, then is distributed on-site by networks called *buses*.
- 2) On-site AC power, which is produced by the plant or by *diesel-driven electric generators*. This power supply is totally independent of the off-site electric transmission lines.

The threshold for EAL SU1.1 represents a condition where all of the off-site AC power has been unavailable for 15 minutes or longer. The plant is relying totally on on-site AC power to run the equipment needed to operate the plant or safely *shutdown* and cool the plant (*vital equipment*). This condition warrants an Unusual Event declaration.

This condition poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 84 of 109

System Malfunction		
SU2	UNUSUAL EVENT	SU2
Loss of Assessment Capability		

Brief Description:

The capability to monitor alarms or indicators in the control room has been lost for 15 minutes or longer. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Plant operators continually monitor the status of the *reactor* and its associated safety and support systems. They rely on meters, gauges, *annunciators*, indicating lights, computer displays, and printouts to assess reactor and equipment performance. These components are also used to identify problems in a timely manner enabling timely response actions to be taken. In most cases, the operator has more than one instrument or alarm that would indicate problems in a specific area.

The *Control Room annunciators*, meters, and gauges are most crucial to the operator to help ensure that the *reactor* is operating safely. Key *safety system* parameters that are routinely monitored by plant operators are:

- *Reactor Power*
- *Reactor Pressure Vessel (RPV) Water Level*
- *RPV Pressure*
- *Primary Containment Pressure*
- *Suppression Pool Level*
- *Suppression Pool Temperature*

If an *unplanned* event occurs resulting in a significant loss of these indicators the ability to adequately monitor and maintain the *reactor* in a safe condition may be hampered.

The threshold for EAL SU2.1 represents this condition which is indicative of a potential degradation of the level of safety of the plant. Therefore, plant personnel will declare an Unusual Event.

This EAL threshold poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 85 of 109

System Malfunction		
SU3	UNUSUAL EVENT	SU3
Reactor Coolant System Activity		

Brief Description:

Minor damage has occurred to the metal tubes that hold uranium fuel pellets (reactor fuel assemblies) resulting in an increase in reactor coolant system activity above allowable limits. Current plant conditions DO NOT threaten public safety.

Detailed Description:

The radioactive uranium pellets that are used for *fuel* are contained in sealed metal tubes, called *reactor fuel assemblies*. These *fuel assemblies* provide the first of the *fission product barriers*, the *fuel cladding*. These metal tubes contain the radioactive substances (*fission products*) produced when the uranium atoms split. If any of the metal tubes become damaged, some of these *fission products*, usually in the form of gases, would leak out into the *reactor coolant system*. As these radioactive gases leak from the *fuel cladding*, they mix with the surrounding water used to the cool the *reactor fuel assemblies* (*reactor coolant*). *Reactor coolant activity* refers to the amount of radioactive material in this water. Some of these radioactive gases can then be carried out with the steam from the *reactor pressure vessel* to the main *turbine*. These gases collect in the main *condenser* where they are removed by the *offgas system*. The *offgas* radiation monitor continuously monitors the *offgas system*, so that operators will know if and when radioactivity levels increase. Plant personnel also routinely sample the *reactor coolant system* and analyze the water for specific parameters, including radioactivity levels. An increase in radioactivity levels may also be identified through this analysis.

The thresholds specified in EALs SU3.1 and SU3.2 represent conditions where the *offgas* radiation monitor has alarmed or a *reactor coolant activity* sample shows radioactivity above normal values. The *offgas* radiation monitor detects radiation levels in the *offgas system* before it is filtered and exhausted to the atmosphere. Although the alarm or *reactor coolant activity* sample results do not indicate any threat to the public, they do indicate possible *fuel cladding* damage and a potential degradation in the level of safety of the plant. Therefore, these conditions require that an Unusual Event be declared.

It is important to note that the amount of *fuel cladding* damage indicated by these thresholds is very small. That is, the radioactive *fission products* being released from the *fuel cladding* to the water around it (*reactor coolant*) is being contained within plant cleanup systems. Therefore, this condition poses no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 86 of 109

System Malfunction		
SU4	UNUSUAL EVENT	SU4
Reactor Coolant System Leakage		

Brief Description:

Water is leaking from the Reactor Coolant System in excess of identified limits. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Pipes and components used to carry water for cooling the *reactor fuel assemblies (core)* are called the *Reactor Coolant System*. They are connected to the *reactor pressure vessel* where the *fuel assemblies* are located. Normally a small amount of monitored water (*reactor coolant*) is expected to leak from the components which make up the *Reactor Coolant System*. Plant operators continuously monitor the amount of this leakage in two ways, by measuring:

- 1) The rate at which water collection tanks (*drywell* or *equipment drain sumps*) that collect the leakage fill up.
- and**
- 2) The rate at which water must be added to the *reactor coolant system*.

The thresholds specified in EAL SU4.1 and SU4.2 represent a condition where the amount of water leaking from the *reactor coolant system* is higher than the plant's *Technical Specifications* allow. These limits are very low and do not threaten the plant's ability to cool the *reactor fuel assemblies*. Therefore, these conditions require that the plant declare an Unusual Event.

The threshold specified in EAL SU4.3 represents a condition where water is leaking from the *reactor coolant system* outside of primary containment due to an *unisolable* leak. This leakage is very low and does not threaten the plant's ability to cool the *reactor fuel assemblies*. Therefore, this EAL requires that the plant declare an Unusual Event.

These conditions pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 87 of 109

System Malfunction		
SU5	UNUSUAL EVENT	SU5
Reactor Power		

Brief Description:

The reactor control rods failed to automatically or manually shut down the reactor when initially required. Current plant conditions DO NOT threaten public safety.

Detailed Description:

A reactor *SCRAM* is a way to rapidly *shutdown* the *reactor* (stop the *fission process* and bring the reactor *sub-critical*) by quickly inserting all control rods into the reactor *core*. Reactor *SCRAMs* can be initiated either automatically, by the *Reactor Protection System*, or manually, by the operators.

However, if a reactor *SCRAM* is started and the *control rods* do not insert, the reactor may not *shutdown* fully. *Emergency Operating Procedures* provide direction to the operators to manually initiate a reactor *SCRAM*.

The threshold specified in EAL SU5.1 represents a condition where the failure of the *Reactor Protection System* to automatically *shutdown* the reactor has occurred when required to do so. In this case, the reactor was manually *shutdown* by plant operators since the *reactor* did not *shutdown* after an automatic signal to do so was sent, **OR** the reactor was automatically *shutdown* by a subsequent/different reactor *SCRAM* signal. This condition requires plant personnel to declare an Unusual Event.

These EAL thresholds pose no threat to the safety of the general public.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 88 of 109

System Malfunction		
SU6	UNUSUAL EVENT	SU6
Loss of Communications Capabilities		

Brief Description:

On-site or off-site communications equipment has been lost. Current plant conditions DO NOT threaten public safety.

Detailed Description:

Plant personnel must be able to communicate throughout the station to safely operate the plant. Many communications systems are available on-site to perform required routine tasks (telephones, plant page system, or radios).

Plant personnel must also be able to communicate problems to off-site authorities and request assistance if needed. Many systems are also available to perform these communications as required (normal telephones, dedicated telephones/lines, and radios).

The threshold specified in EAL SU6.1 represents a condition where all on-site communications systems are unavailable. Since this condition may affect the ability of plant personnel to perform routine tasks, plant personnel will declare an Unusual Event.

The threshold specified in EAL SU6.2 represents a condition where all off-site communications systems used to notify local and state response organizations are unavailable. Since this condition may affect the ability of plant personnel to notify response organizations of an event or request support, plant personnel will declare an Unusual Event.

The threshold specified in EAL SU6.3 represents a condition where all off-site communications systems used to notify the Nuclear Regulatory Commission (NRC) are unavailable. Since this condition may affect the ability of plant personnel to notify the NRC of an event or request support, plant personnel will declare an Unusual Event.

These EAL thresholds pose no threat to the safety of plant personnel or the general public.

<i>MONTICELLO NUCLEAR GENERATING PLANT</i>		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 89 of 109

GLOSSARY AND ACRONYMS

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 90 of 109

Glossary

The terms found in this glossary are defined in the context of their relationship to Emergency Action Levels.

Activity: With respect to radiation, the number of nuclear disintegrations occurring in a radioactive material per unit of time. Activity is directly related to the strength of a radiation source. The more nuclear disintegrations that occur, the more radiation that a radioactive substance emits.

Adequate Core Cooling: The removal of heat energy from the reactor *fuel* sufficient to prevent rupturing (breaking apart) the *fuel cladding*.

Air Ejector: A device which removes air and other *non-condensable gases* (some of which might be radioactive) from the main *condenser*. The gases which are removed by the air ejectors are called *off-gas* and are processed by the Off-gas System.

Alternate Shutdown Panel: Facility outside the control room that is designed to allow the plant to be *shut down* safely should the main control room become uninhabitable.

Annunciator: A device which provides plant operators with both a visible and audible alarm of a significant plant condition.

Automatic Depressurization System: An *emergency core cooling system* which automatically depressurizes the *reactor pressure vessel* (reduces reactor pressure) by directing steam into the *Torus (Suppression Pool)*. The reduction in reactor pressure then allows the low pressure *emergency core cooling systems* to inject water into the reactor pressure vessel.

Boron: A substance which is capable of efficiently absorbing neutrons and stopping the nuclear chain reaction. Used in the *control rods* and as an alternate method of shutting down the *reactor* by injection into the cooling water in the reactor *core*.

Bus: A rigid electrical conductor (normally a metal bar) used to connect multiple circuits. Provides a means of supplying electrical power to electric equipment.

Child Thyroid Exposure: A calculated radiation dose received by a child as a result of inhalation or ingestion of radioactive iodine. Radioactive iodine in the body collects and concentrates in the thyroid creating a concentrated source of radiation in that area. The thyroid exposure (dose) received is higher for children than that for adults due to the higher metabolism rate of children and the smaller size of the thyroid.

Circulating Water System: A cooling water system that removes excess heat from the *main condenser* by continuously supplying cooled water from the cooling tower or river to the main condenser and returning the heated water to the cooling tower or river.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 91 of 109

Glossary (cont.)

Cold Shutdown: A plant condition in which the *reactor* is shut down (*sub-critical*) and the *reactor* coolant temperature is less than 212 degrees Fahrenheit.

Committed Dose Equivalent (CDE): Dose to a specific organ or tissue that will be received from an intake of radioactive material by an individual over a 50 year period following the intake of the radioactive material.

Condenser: A component which serves to condense steam back into water so that the water can be reused. The main condenser serves to condense the steam exhausted from the main turbine so that it can be pumped back to the *reactor* for reheating and conversion back to steam.

Confinement Boundary: The barrier(s) between areas containing radioactive substances and the environment.

Containment: A gas-tight shell or other enclosure around a nuclear *reactor* used to contain *fission products* that otherwise might be released in the event of an accident.

Containment Vent: A system used to assist in the reduction of either *primary containment* pressure or concentrations of undesirable gases. In all cases, the containment is vented through the *standby gas treatment system*.

Control Rod: A cross-shaped rod which can be withdrawn from or inserted into the *reactor core* to absorb neutrons and thus control *reactor* power. There are 121 control rods in the MNGP *reactor*.

Control Room: The central location from which the plant is operated, monitored and controlled. The control room is equipped with the instrumentation and alarms necessary to continually assess the status of the *reactor* plant.

Core: The central portion of a nuclear *reactor* which is comprised of the *fuel assemblies* and the structural materials which together serve to promote the fission process.

Core Damage: Damage to the components which comprise the reactor *core*. Core damage typically refers to the failure of *fuel cladding* and/or *fuel* melting as a result of overheating the fuel.

Core Spray System: A low pressure *emergency core cooling system*. The core spray system is capable of spraying water from the *torus* directly onto the *core*.

Credible Threat: A threat that is real and immediate as determined by federal, state, or local government agencies (e.g., NRC, FBI, DHS, State Police, etc.).

Critical: In reference to the *reactor*, a self-sustaining nuclear chain reaction that releases energy. During normal plant operations the *reactor* is 'critical'.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 92 of 109

Glossary (cont.)

Decay Heat: The heat energy which results from the decay of radioactive *fission products*. Even after the *reactor* is shut down the *reactor* fuel will continue to produce significant amounts of *decay heat*. The longer the *reactor* has been shut down the less *decay heat* is produced.

Defense-In-Depth: The philosophy of plant design and operation which provides many lines of defense against accidents. Nuclear power plants incorporate this philosophy by having backup systems that are capable of working if the primary system or piece of equipment fails.

Defueled: A condition where all the reactor *fuel assemblies* have been removed from the *reactor pressure vessel* and are stored in the *Spent Fuel Pool* to allow for maintenance on plant systems and components.

Design Basis Earthquake: An earthquake of an intensity greater than the plant was designed to withstand and still be able to safely *shut down* the reactor.

Diesel-driven Electric Generators: An alternate on-site power source, that uses large diesel engines attached to electric generators, designed to provide the necessary electrical power to safely shut down the *reactor* during a total loss of off-site electrical power.

Dose Projection: The calculation of individual radiation exposure at a given location at some time in the future. Dose projections are performed in response to an actual or anticipated release of radioactive material to the environment.

Drywell: That portion of the *primary containment* structure which houses the *reactor pressure vessel* and associated piping systems.

Drywell Sump: A tank located in the floor of the drywell that collects any leakage from the *reactor coolant system*.

Emergency Action Level (EAL): Plant-specific indications, conditions or instrument readings which are used to classify an emergency as an Unusual Event, Alert, Site Area Emergency or General Emergency.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 93 of 109

Glossary (cont.)

Emergency Core Cooling System (ECCS): Those systems which are designed to provide *adequate core cooling* under abnormal and accident conditions. The emergency core cooling systems consist of:

- *High Pressure Coolant Injection (HPCI) System*
- *Automatic Depressurization System (ADS)*
- *Core Spray System*
- *Low-Pressure Coolant Injection (LPCI) System*

Although not considered an *ECCS*, the *Reactor Core Isolation Cooling (RCIC)* System also serves to assist in the maintenance of adequate core cooling.

Emergency Diesel Generator: Diesel-driven electrical *generator* designed to provide the necessary electrical power to safely shut down the *reactor* during a total loss of off-site electrical power.

Emergency Director: The individual with overall command and control of the on-site MNGP Emergency Response Organization. The Emergency Director has the ultimate responsibility for emergency classification and providing protective action recommendations to off-site authorities.

Emergency Operating Procedure (EOP): Procedures utilized by the plant operators during emergencies which provide appropriate guidance to put the *reactor* in a safe and stable condition.

Emergency Plan Implementing Procedures (EPIPs): Procedures implemented by the plant's Emergency Response Organization members (during all classified emergencies) which provide appropriate guidance to assure the protection of the health and safety of plant personnel and the general public.

Engineered Safety Features (ESF): Those systems and components which are specifically designed to ensure the *reactor* can be shut down, cooled down and placed in a safe and stable condition.

Equipment Drain Sumps: Tanks located beneath various plant equipment that collects any leakage from the *reactor coolant system*.

Fire Brigade: An on-shift group of individuals, at least five, trained and qualified in firefighting techniques that responds to reports of fires and initiates actions to extinguish them and protect other plant components/equipment.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 94 of 109

Glossary (cont.)

Fire Brigade Leader: The lead person on the fire brigade that acts as the on-scene commander providing direction to the fire brigade.

Fission Process: The splitting of an atom, which releases a considerable amount of energy (usually in the form of heat) that can be used to produce electricity. In addition to energy, this process usually releases gamma radiation and two or more neutrons.

Fission Product: Elements or compounds (radionuclides) which result from the *fission process* (splitting of uranium atoms). Most *fission products* are highly radioactive.

Fission Product Barrier: Those physical structures which are specifically designed to contain and preclude the release or spread of fission products. For the purpose of the MNGP Emergency Plan there are three fission product barriers: *fuel cladding*, *reactor pressure vessel* and *primary containment*.

Fuel: The uranium oxide pellets stacked inside the *fuel cladding* which make up a fuel rod.

Fuel Assembly: An array of fuel rods held together by tie plates. There are 484 *fuel assemblies* in the *reactor core* at MNGP. Also referred to as a 'fuel bundle'.

Fuel Cladding: The long zirconium metal tubes in which the fuel pellets are stacked. The fuel cladding along with the fuel pellets are referred to as 'fuel rods'. The fuel cladding serves as the primary *fission product barrier*.

Generator: A device which converts mechanical energy into electrical energy (i.e. main turbine generator, emergency diesel generator).

Heat Sink: The medium which absorbs and dissipates waste heat energy. The circulating water, which passes through the main *condenser* and *cooling towers*, serves as the plants primary heat sink. The water in the *torus* serves as a back-up heat sink for the *reactor*.

High Pressure Coolant Injection (HPCI) System: An emergency core cooling system which utilizes a steam turbine-driven pump to inject water into the *reactor pressure vessel* while the vessel is at a high pressure.

Hostile Action: An act toward MNGP or its personnel that includes the use of violent force to destroy equipment, take hostages, and/or intimidate the site to achieve an end. This includes attack by air, land, or water using guns, explosives, projectiles, vehicles, or other devices used to deliver destructive force.

Hostile Force: One or more individuals who are engaged in a determined assault, overtly or by stealth and deception, equipped with suitable weapons capable of killing, maiming, or causing destruction.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 95 of 109

Glossary (cont.)

Imminent: The sequence of events or conditions is such that an *EAL* will be met within a relatively short period of time regardless of mitigation or corrective actions.

Independent Spent Fuel Storage Installation (ISFSI): A complex designed and constructed for the interim (temporary) storage of *spent fuel*. MNGP uses an ISFSI to store *spent fuel assemblies* on-site.

ISFSI Protected Area (PA): A security zone located within the *Owner Controlled Area (OCA)* that surrounds the *ISFSI*. Access to this area is restricted to authorized personnel and controlled by the station's security force.

Irradiated Fuel: A *fuel assembly* which has been involved in the fission process (any *fuel assembly* which has been in the *reactor pressure vessel* during plant operation). An irradiated *fuel assembly* has *fission products* inside the fuel rods and is highly radioactive.

Loss of Coolant Accident (LOCA): A rapid loss of the water used to cool the *core*, associated with a break in a *reactor coolant system* pipe or component.

Low-Pressure Coolant Injection (LPCI) System: An emergency core cooling system capable of injecting large amounts of water from the *torus (suppression pool)* into the *reactor pressure vessel* while the vessel is at low pressure.

Main Steam Isolation Valves (MSIVs): Valves located in the *main steam lines* designed to rapidly stop the flow of steam from the *reactor pressure vessel*. When closed, they compose a portion of the *primary containment* boundary.

Main Steam Line: A pipe which transfers the steam generated in the *reactor pressure vessel* to the main turbine. There are four main steam lines connected to the reactor pressure vessel.

Millirem: One one-thousandth of a rem. The rem is a unit of measure which defines the extent of biological injury that results from absorption of radiation by the body.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 96 of 109

Glossary (cont.)

Mode: Used to define the condition of the plant. For the purposes of the EALs there are five (5) modes:

- Power Operations: The *reactor* is *critical* and generating power.
- Startup: The *reactor* is being started.
- Hot Shutdown: The *reactor* is NOT *critical*, with *reactor coolant system* temperature greater than 212°F
- Cold Shutdown: The *reactor* is NOT *critical*, with *reactor coolant system* temperature less or equal to 212°F
- Refueling: The *reactor* is NOT *critical*, with *reactor coolant system* temperature less or equal to 212°F and the *reactor pressure vessel* head is not bolted on to the *reactor*.
- Defueled: All *reactor Fuel Assemblies* are removed from the *reactor pressure vessel*. This condition is not considered an operating mode.

Non-condensable Gas: Any gas which, under normal operating pressures, cannot be condensed (turned into a liquid). While gases such as steam are condensable, gases such as nitrogen, oxygen and hydrogen are not. Those *non-condensable gases* which accumulate in the *main condenser* are removed and are called *off-gas*.

Nuclear Disintegration: A spontaneous nuclear transformation which results in the emission of energy and/or mass from an atom's nucleus. The emitted energy and/or mass is referred to as radiation.

Off-gas: *Non-condensable* gases removed from the *main condenser*, some of which are radioactive. *Off-gas* is treated by the *Off-gas System*.

Off-gas System: Plant components and equipment designed to filter and delay the release of radioactive *non-condensable gases*.

Off-site Dose Calculation Manual (ODCM): The document which specifies the methods for determining the impact of radiological releases and discharges from the station.

Off-site Electrical Power: That electrical power which is supplied to the MNGP site from off-site electric power transmission lines. This power is delivered to the on-site distribution networks (*buses*) via power supply *transformers*.

On-site Electrical Power: That electrical power which is produced by electric *generators* located physically on-site. These sources are totally independent of off-site electric transmission lines.

Operating Basis Earthquake (OBE): An earthquake of an intensity greater than the plant was designed to withstand for continued plant operation.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 97 of 109

Glossary (cont.)

Owner-Controlled Area (OCA): That property around the plant bounded by the outer-most fence.

Plant Process Computer: A computer system which monitors thousands of plant process parameters and provides indications and alarms to the plant operator.

Plant Transient: A sequence of events which causes plant conditions to change rapidly. A *reactor SCRAM* is considered a plant transient.

Primary Containment: The structure which houses the *reactor pressure vessel* and piping of the *reactor coolant system*. The primary containment consists of the *drywell* and *torus (suppression pool)* connected by vent pipes. The primary containment acts as the third *fission product barrier*.

Primary Containment Integrity: A condition in which the *primary containment* structure is intact and all systems which operate to ensure its effectiveness as a *fission product barrier* are functional.

Primary Containment Isolation System (PCIS): A system which initiates automatic closure of appropriate pipelines to provide timely protection against the gross release of radioactive materials from the *primary containment*.

Primary System: Any fluid system which connects directly to the *reactor pressure vessel* such that a reduction in *reactor* pressure will cause a decrease in the pressure in the fluid system.

Protected Area (PA): The area around and including the plant structures protected by a double chain link fence for either the plant or the *ISFSI* and to which access is controlled by the station's Security Force.

Protective Action Guidelines (PAGs): Radiation exposure guidelines established by the Environmental Protection Agency which are used to determine the appropriate protective actions to be taken on the part of emergency workers and the general public. These protective actions include sheltering and evacuation.

Radwaste: Radioactive waste materials. Radwaste may be in a solid, liquid or gaseous form. Radwaste generated at MNGP is treated and processed by the Radwaste System.

Reactivity: A term which describes the number of neutrons available to carry on the nuclear chain reaction. Withdrawing *control rods* adds positive reactivity because fewer neutrons are absorbed, so more are available to cause a fission.

Reactor: Those components which, together, support the controlled fission process and the generation of steam for the purpose of producing power. Components include the *reactor core*, *reactor pressure vessel*, *control rods* and *reactor coolant system*.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 98 of 109

Glossary (cont.)

Reactor Building: The reinforced concrete structure which houses the *primary containment*, refueling and *spent fuel* storage facilities and reactor auxiliary equipment. The reactor building structure is the primary component of the *secondary containment*.

Reactor Building Vent: That part of the reactor building ventilation system which directs the reactor building air to the outside atmosphere. Located on top of the *reactor building*, the discharge is continuously monitored for abnormal amounts of radiation and would be isolated if radiation levels approach federal limits. Should the Reactor Building Vent isolate, all Reactor Building Ventilation would be diverted to the *Standby Gas Treatment (SBGT)* system.

Reactor Control Panels: Panels inside the *control room* that contain the equipment controls, switches, gauges, and instrumentation used by the plant operators to operate, monitor, and control the reactor and it's support systems.

Reactor Coolant: The water which serves to remove the heat energy from the *core*. Typically, water is referred to as 'reactor coolant' only when it is located within a *reactor coolant system*.

Reactor Coolant Activity: With respect to radiation, the number of nuclear disintegrations occurring in the *reactor coolant* water per unit of time. The *reactor coolant* activity is directly related to the amount of radioactive material in the *reactor coolant* water.

Reactor Coolant Pressure: An operating parameter of the *reactor coolant system* measured by instrumentation and monitored by the plant operators in the *control room*.

Reactor Coolant System (RCS): Those pipes and components which act to transfer and process *reactor coolant*. Typically, the term 'reactor coolant system' refers to those systems which are closely related to the *reactor pressure vessel* (i.e. the 'Recirculation System' and the 'Reactor Water Cleanup System' are referred to as 'reactor coolant systems').

Reactor Coolant Temperature: An operating parameter of the *reactor coolant system* measured by instrumentation and monitored by the plant operators in the *control room*.

Reactor Core Isolation Cooling (RCIC) System: A core cooling system which uses a steam turbine driven pump to inject water into the *reactor pressure vessel* while the vessel is at a high pressure.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 99 of 109

Glossary (cont.)

Reactor Mode Switch: A control switch located in the control room whose position determines the mode (startup, shutdown, etc.) the *reactor* is in. The various positions of the mode switch enable and/or disable certain *reactor* control functions:

- Shutdown - position used during *shutdown* condition
- Refuel - position used while moving *reactor fuel*
- Startup/Hot Standby - position used during reactor startup
- Run - position used during normal operation.

Reactor Power: The amount of energy (power) generated by the *fission process* inside the reactor core.

Reactor Pressure Vessel (RPV): The RPV is a large steel structure which is designed to provide a volume in which the *reactor core* can be submerged in *reactor coolant*. The RPV acts as part of the second *fission product barrier*.

Reactor Protection System (RPS): A system which initiates automatic reactor SCRAMs to provide timely protection against conditions which threaten *fission product barrier* integrity.

Reactor Safety System: A plant system which performs a function critical to reactor safety.

Reactor Vessel Head: The top of the reactor pressure vessel that is removed during refueling to enable access to the fuel assemblies and other internal components.

Refuel Floor: The upper most floor of the *reactor building*. The *refuel floor* is where reactor *refueling* operations are conducted. This involves the periodic replacement and storage of *spent fuel*.

Refueling: The process of removing used *fuel assemblies* and replacing them with new *fuel assemblies*.

Refueling Cavity: The refueling cavity is the area formed above the reactor vessel when the reactor vessel head is removed to allow movement and replacement of the *spent fuel assemblies*. This area is normally filled with water (reactor coolant) during *refueling* operations to provide radiation shielding and cooling.

Restricted Area Boundary: The outer boundary of the *owner controlled area* at which the public would be allowed unrestricted access.

Safety Relief Valve (SRV): A valve which serves to automatically reduce *reactor pressure vessel* pressure should pressure become excessively high. SRVs also provide a backup mechanism of *reactor pressure vessel pressure control*. There are 8 SRVs mounted on the main steam lines connected to the *reactor pressure vessel*.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 100 of 109

Glossary (cont.)

Safety System: A plant system which performs a function critical to plant safety.

Safety System Equipment: Equipment (pumps, valves, breakers, etc.) required for safe operation of the plant, cooling down the plant, and/or placing it in a *cold shutdown* condition. This includes equipment related to the ECCS.

SCRAM: The rapid insertion of all control rods into the core for the purpose of making the reactor *sub-critical (shutdown)*. A scram can be initiated automatically by the *reactor protection system* or manually by the plant operators.

Secondary Containment: The secondary containment structure is comprised of the *reactor building, standby gas treatment system*, and the associated ventilation systems. The secondary containment serves to limit the release of radioactive materials should all three *fission product barriers* fail.

Seismic Instrumentation: A device which detects and records ground acceleration (earthquakes) and provides an alarm to plant operators if ground acceleration exceeds preset values on-site.

Shift Manager(SM): The plant's senior U.S. Nuclear Regulatory Commission (NRC) licensed operations individual on-site. The SM holds a NRC Senior Reactor Operators license and has ultimate responsibility for the safe operation of the plant.

Shutdown (Shut Down): The condition (or actions taken to establish) of the plant when the reactor is *sub-critical*. When the reactor is 'shutdown' no significant heat is being generated from the *fission process* (although significant *decay heat* might still be generated). The *fission process* has been stopped effectively.

Site Boundary: The outer bounds of the Owner-Controlled property surrounding the MNGP.

Spent Fuel: Nuclear reactor fuel that has been used to the extent that it can no longer effectively sustain a chain reaction.

Spent Fuel Pool: A large, deep pool of purified water which is used to store the spent fuel and other radioactive components prior to their shipment off-site. In addition to cooling, the water covering the spent fuel provides radiation shielding so that the refueling floor is accessible. The spent fuel pool is located on the *refueling floor* of the *reactor building*.

Standby Gas Treatment (SBGT): A system which serves to process and filter the waste products of various plant systems. The SBGT system provides a method to remove radioactive particles and gaseous waste products from the *reactor building* and *primary containment* ventilation systems.

Sub-critical: In reference to the *reactor*, incapable of sustaining a chain reaction (fission). The reactor is *shutdown* when sub-critical.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 101 of 109

Glossary (cont.)

Suppression Pool: That portion of the primary containment which serves both as a *heat sink* during a *loss of coolant accident* or *safety relief valve* discharge and as a source of water for *numerous emergency core cooling systems*. The *suppression pool* is located at the base of the *drywell* and is approximately one-half full of water.

Technical Specifications: A document which prescribes the conditions and limitations under which the plant must be operated. The Technical Specifications are a part of the plant's operating license.

Top of Active Fuel: The elevation within the *reactor core* below which enriched uranium *fuel* is used.

Torus: That portion of the primary containment which serves both as a *heat sink* during a *loss of coolant accident* or *safety relief valve* discharge and as a source of water for *numerous emergency core cooling systems*. The torus is a large doughnut-shaped structure approximately on-half full of water which is located at the base of the *drywell*.

Total Effective Dose Equivalent: The sum of external exposure doses and internal doses.

Transformer: An electrical device which is used to either increase or decrease the voltage of electricity. MNGP has transformers which reduce off-site transmission line voltage from 345,000 to 4160 volts for use by plant equipment.

Turbine Building: The plant structure that contains the steam turbine, electrical *generator*, *main condenser*, and support equipment.

Unisolable: An open or breached system line that cannot be isolated, remotely or locally.

Unplanned: A parameter change or an event, known or unknown, which is not the result of an intended evolution or an expected plant response to a transient.

Vital Area: An area within the plant process buildings which contains *vital equipment*.

Vital Equipment: That plant equipment which has been designated as being vital to the safe *shutdown* and cooling of the reactor. Particularly that equipment which is required under emergency conditions.

Vital Plant Structures: Those plant buildings and structures which house *vital areas*.

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 102 of 109

Acronyms

This is a list of acronyms commonly used in emergency planning.

ADS	Automatic Depressurization System
AC	Alternating Current
ANI	American Nuclear Insurers
ATWS	Anticipated Transient without Scram
BEOF	Backup Emergency Operations Facility
BPO	Bulk Power Operations
BWR	Boiling Water Reactor
DC	Direct Current
DOE	Department of Energy
DOT	Department of Transportation
EAL	Emergency Action Level
ECCS	Emergency Core Cooling System
ENS	Emergency Notification System (NRC)
EOC	Emergency Operations Center
EOF	Emergency Operations Facility
EOP	Emergency Operating Procedure
EPA	Environmental Protection Agency
EIPs	Emergency Plan Implementing Procedures
EPZ	Emergency Planning Zone
ERF	Emergency Response Facility
ESF	Engineered Safety Features
FEMA	Federal Emergency Management Agency
FRMAC	Federal Radiological Monitoring Assessment Center
FRMAP	Federal Radiological Monitoring and Assessment Plan
GE	General Emergency
HPCI	High Pressure Coolant Injection
HPCS	High Pressure Core Spray

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 103 of 109

Acronyms (cont.)

HPN	Health Physics Network (NRC)
INPO	Institute of Nuclear Power Operations
IRC	Incident Response Center (NRC)
ISFSI	Independent Spent Fuel Storage Installation
JIC	Joint Information Center
KI	Potassium Iodide
LOCA	Loss of Coolant Accident
LPCI	Low Pressure Coolant Injection
LPCS	Low Pressure Core Spray
MSIVs	Main Steam Isolation Valves
NRC	Nuclear Regulatory Commission
NUE	Notification of Unusual Event
OBE	Operating Basis Earthquake
ODCM	Off-site Dose Calculation Manual
OSC	Operational Support Center
PA	Public Address
PAGs	Protective Action Guidelines
PAR	Protective Action Recommendation
RAC	Regional Advisory Committee
RAFT	Radiological Assessment Field Team
REAC	Radiological Emergency Assessment Center
RF	Radio Frequency
RHR	Residual Heat Removal
RO	Reactor Operator
RPS	Reactor Protection System
RPV	Reactor Pressure Vessel
SAE	Site Area Emergency
SFCP	State Forward Command Post
SOP	Standard Operating Procedures
SPDS	Safety Parameter Display System
SRC	State Radiological Coordinator

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 104 of 109

Acronyms (cont.)


SRO	Senior Reactor Operator
STA	Shift Technical Advisor
TS	Technical Specifications
TSC	Technical Support Center

<i>MONTICELLO NUCLEAR GENERATING PLANT</i>		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 105 of 109

PLANT INFORMATION

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 106 of 109

Plant Information



Plant Cut Away Drawing

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 107 of 109

Plant Information

Location:

On a 1,400 acre site three miles northwest of Monticello, Minnesota and about 40 miles northwest of Minneapolis.

Capacity:

671 Megawatts

Generator:

Speed.....1,800 revolutions per minute

Voltage.....22,000 volts, 3-phase, AC

Cooling.....Rotor by hydrogen

Turbine:

TypeTandem compound, four flow Steam

Temperature540°Fahrenheit (282°Centigrade)

Steam Pressure950 pounds per square inch

Steam Flow6,700,000 pounds per hour

Substation Transformer Output:

Voltage Step-up (115,000), (230,000) and (345,000) volts

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 108 of 109

Plant Information (cont.)

Reactor:

Type Boiling water, direct cycle
Coolant Water
Moderator Water
Core Coolant Flow Rate 154,000 gallons per minute
Feedwater Inlet Temperature 376°Fahrenheit (191°Centigrade)
Steam Outlet Temperature 543°Fahrenheit (284°Centigrade)
Coolant Pressure (inlet) 1,038 pounds per square inch
Steam Capacity 6,770,000 pounds per hour
Heat Output 5,699,710,000 BTU's per hour

Fuel Core:

Pellets:

Material Uranium dioxide (UO₂)
Enrichment 2.99 to 3.24% U-235
Length 0.275 inches
Diameter 0.411 inches
Number Approximately 15,800,000
Total Weight, Uranium 190,000 pounds (95 tons)

Rods: Material Zircaloy-2
Cladding Thickness 0.032 inches
Outside Diameter 0.483 inches
Length 12.9 feet
Number Approximately 30,000 with fuel

Control Blades: Material Stainless Steel Tubing
Neutron Absorber Boron Carbide, hafnium
Blade Length 12.9 feet (4.4 meters)
Blade Width 9.75 inches (24.77 centimeters)
Number 121

MONTICELLO NUCLEAR GENERATING PLANT		EAL-RM
TITLE:	EAL REFERENCE MANUAL	Revision 0
		Page 109 of 109

Plant Information (cont.)

Reactor Vessel:

Material Carbon steel clad with stainless steel
Height 63 feet 2 inches
Inside Diameter 17 feet 2 inches
Wall Thickness 5.187 inches
Design Temperature 562°Fahrenheit
Design Pressure 1250 pounds per square inch

Containment:

Material Steel Shell w/Reinforced concrete
Height 105 feet 10.875 inches above ground
Lining 0.687 - 2.5 inches steel
Volume 134,200 cubic feet
Design Pressure 56 pounds per square inch @ 281°F

Condenser:

Material Stainless steel tubing
Number of Tubes 40,112
Tubing Length 30 to 40 feet
Condensing Surface 399,000 square feet
Cooling Water Flow 292,000 gallons per minute
Heat transfer rate 3,762,000,000 BTUs per hour

Cooling Towers(2):

Type Induced draft, evaporative
Height 61 feet
Length 270 feet
Water Flow 151,000 gallons per minute each